

December 12, 1975

ANSI

Mr. Marvin Hitt, Director
Office of Long Term Care
Department of Health, Education
and Welfare
300 South Wacker Drive
Chicago, Illinois 60606

Re: Proposed State of Minnesota
Criteria for Compliance with
ANSI Standards

Dear Mr. Hitt:

The following is an attempt to establish a formal set of State interpretations for use by surveyors and office staff for the determination of compliance with the ANSI Standards as applied to health care facilities. Some of the questions in the Federal survey form need definite interpretation as to application which is presently left to judgement of the individual surveyors. The Federal interpretations in the Long Term Care Manual provide only partial answers in terms of specific requirements, and do not provide a complete tool for uniform assessment of handicap provisions. Even the ANSI Standard is silent on specific requirements in certain areas. It is the intention with these interpretations to establish reasonable criteria for compliance which are MEASURABLE.

The Federal Survey Form requires responses in terms of "yes" or "no" or "met" or "not met". Determinations for compliance or non-compliance must obviously be based on specific criteria. It would therefore appear that the Department should first establish uniform conditions for acceptable compliance which can be observed and documented and which can be based on established policies and physical plant provisions that are measurable. Only in cases where compliance cannot be established in accordance with such criteria would a waiver request be processed. Such a procedure would reduce the number of waivers to be processed without jeopardizing the health and safety of the patients or residents.

There are basically two areas of special provisions for the handicapped which must be addressed: 1) Accessibility and useability of the physical plant by persons with mobility problems and 2) alarm signals and warning signs for persons who are deaf and blind.

A. Accessibility and Useability - General

State licensing regulations for all care facilities restrict the use of floors above or below an accessible entry floor level to AMBULATORY patients or residents in multi-story facilities, unless an elevator is provided. When the public and non-ambulatory patients have access to a floor which meets the proposed criteria and

UNIVERSITY OF MINNESOTA
TWIN CITIES

Boynton Health Service
410 Church Street S.E.
Minneapolis, Minnesota 55455

AUG 31 1979

UNIV OF MINN.
HEALTH SCIENCE
PLANNING OFFICE

August 31, 1979

MEMORANDUM

To: Paul Maupin, Coordinator, Health Science Planning Office,
4104 Powell Hall, East Bank Campus

From: Donald Herron, University Safety Officer, Department of
Environmental Health and Safety *DH*

Subject: Federal Inspection, July 18, 1979

My response to highlighted Items 8 and 12 in Federal Report,
Minn.-18 (HP) Health Sciences Expansion B/C is as follows:

8. Provide a system of visual alarms in the fire alarm system for
the benefit of persons with hearing disabilities.

Visual alarms were not provided for Unit B/C because
Section 504 (April 1977) mandated compliance with the
ANSI Standard only for facilities constructed after
June 1977. (See enclosure dated 8-22-78.) It is my
understanding that ground breaking is considered to
be the cut-off date for purposes of determining
"construction" date. Therefore, because Unit B/C
ground breaking occurred in 1976, the requirements
of 504 were not applicable. (Unit F will have a
system of warning lights.)

To provide for the safety of handicapped individuals
in clinic areas of Unit B/C, a fire warden program is
in development where specific individuals will be
assigned specific tasks, one of which is to provide for
compromised individuals - temporarily or permanently
handicapped.

12. The activation of a manual fire alarm system will cause the
respective zone to negativize even though the fire hazard is not in the
zone.

I know of no alarm system which can "read" a situation
to determine if the proper pull station was pulled.
Posted fire procedures in Unit B/C advise occupants
who discover a fire to pull the nearest alarm pull box;
additional instructions advise occupants of where the
pull stations are located. Internal publications and
instructions also emphasize the need to pull the nearest
pull station. This problem is a recognized weakness of
all zoned, coded fire alarm systems. In this case, it
is even more important that a pull station on the fire
floor is pulled, otherwise, an improper message will be
aired for that floor.

DH: db

Enclosure



DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE

REGION V

300 SOUTH WACKER DRIVE
CHICAGO, ILLINOIS 60606

TKL ✓
RET ✓
RFB ✓
MRB ✓
RCS ✓
HPL ✓

OFFICE OF
THE REGIONAL DIRECTOR

April 23, 1976

ANSI

RECEIVED

APR 28 1976

DIVISION OF
HEALTH FACILITIES

Hans P. Larsen, Chief ✓
Section of Engineering & Technical Services
Division of Health Facilities
Minnesota Department of Health
717 Delaware Street S.E.
Minneapolis, Minnesota 55440

Dear Mr. Larsen:

We regret the delay in responding to your letter concerning proposed State of Minnesota criteria for compliance with ANSI standards.

Federal regulations requiring compliance with ANSI specifications are to allow the one person in seven who has a permanent physical disability to have access to and use of buildings and facilities which house Federally funded long term care facilities. This segment of the general population represents human resources of inestimable value and of great economic significance to the nation that should not be excluded from these buildings and facilities. The specifications are purposely written in a general manner, leaving specific measurements and judgments to the surveyor on site who can then evaluate whether the facility, as built, is successful in allowing handicapped, as well as non-handicapped ambulatory visitors and patients to use the facility. We shall comment on each of the points which you made in your letter:

Section A - Accessibility and Useability - General

This Section does not address the philosophy underlying the ANSI requirements.

A State licensure provision restricting use of floors to ambulatory persons, etc. does not give a handicapped person access to these floors. The barrier floors may contain accommodations and services beyond basic requirements which give meaning to the program, and contribute to the quality of life in the facility. Thus, the total facility cannot be considered in compliance with ANSI requirements; only the floor or area that is accessible may be considered in compliance with ANSI requirements.

Again, restricting admissions to Supervised Living Facilities which are certified as ICF/MR does not address the needs of handicapped visitors.

Department of Health, Education
and Welfare
Chicago, Illinois 60606

December 12, 1970

out such special signals or signs, but licensed for supervised independent type living would be considered in compliance provided that such facilities do not house or employ persons with hearing or sight disabilities.

Sincerely yours,

Hans P. Larsen, Chief

Engineering Services Section
Division of Health Facilities

HPL:os

MEMORANDUM

O.M.

DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE
HEALTH CARE FINANCING ADMINISTRATION
HEALTH STANDARDS AND QUALITY BUREAU
OFFICE OF STANDARDS AND CERTIFICATION

TO : Acting Directors
Health Standards and Quality
Regions I-X

DATE: AUG 22 1978

*ANN MARIE
TO ALL PERB
STAFF +
RETURN TO
ME.*

FROM : Acting Director
Office of Standards and Certification

SUBJECT: Division of Long Term Care Policy Memorandum No. 17, ANSI
Requirements for Simultaneous Audible and Visual Warning Signals

This policy is issued as a result of the concern from Regional Offices with respect to the requirements for simultaneous audible and visual warning signals.

The current skilled nursing and intermediate care facility regulations for the physically handicapped, effective since January 17, 1974, require the facility to provide simultaneous audible and visual warning signals. This requirement has been discussed with the Department's Office of Civil Rights (OCR) which has the responsibility for the enforcement of Section 504 of the Rehabilitation Act of 1973. The OCR states that the visual warning signal requirement of the alarm system need not be enforced for facilities constructed prior to June 1977, the effective date of regulations implementing the Act. In that these regulations supersede the skilled nursing and intermediate care facility standards for the physically handicapped, the decision of the OCR will be followed. However, long-term care facilities are expected to provide other means of warning deaf patients of fire. There are several ways this can be accomplished. For example, all staff can be trained to quickly alert deaf patients of a fire; more frequent fire drills can be held; deaf patients can be located near the nurses' station to make them more accessible to the nursing service staff; and the facility can inform the patient, in writing, of the actions taken by the facility to protect them and what they are to do in case of fire. Other actions may be taken as well to protect the deaf patients.

Edward L. Kelly
Edward L. Kelly

RECEIVED

AUG 29 1978

HCHA/11508
Region V - Chicago

*Copy for: Stee
Hall
Bennett*

The intent of the regulation is to allow handicapped persons, including visitors, the same freedom of the entire facility that ambulatory persons enjoy. A waiver of this provision may be considered in some instances.

An appropriate number of toilet rooms must be supplied to accommodate patients, visitors and staff. ANSI specifications require an appropriate number of toilet rooms accessible to and useable by the physically handicapped. The ratio of at least one to eight generally will be sufficient; the surveyor on site must make a determination of adequacy.

Section B - Accessibility and Useability - Specifics

Your specifications for a handicap entrance door omit the recommendation for kick plates, the requirements for a 5 foot level area on the side of the door swing(s), and a level area one foot beyond the edges of the door. The eight pound pressure to open the door is a maximum; facilities should be encouraged to make adjustments which will reduce this to five pounds.

Exterior walks must be at least 48 inches wide, rather than the 32 inches specified in your letter, and 60 inches is preferable.

Stairs acceptable to Life Safety Code purposes should also conform to the recommendations in 5.4 of ANSI specifications which attempt to make buildings in their entirety, accessible and useable by handicapped persons who may be staff, or visitors, as well as patients.

Elevators used by physically handicapped should be 60x60 or 56x63, (not 56x53 inches) in order to allow turning space for a wheelchair. In addition to your specifications, the requirements for doors and doorways should be met.

Non-slip ramps in existing facilities would be satisfactory pursuant to the specifications in your letter. ANSI specifications recommend two handrails and extensions beyond the top and bottom. By merely stating the basic minimum requirement, these recommendations may not be considered when new ramps are constructed.

The specifications for toilet seats in existing facilities generally are satisfactory. The preferred depth of 5 feet should be stated as such. If Minnesota State regulation grab bars do not parallel specifics in ANSI 5.6.2(4), an amendment must be considered. Toilet seats must be 20 inches from the floor, and this may be accomplished by an inexpensive extension.



UNIVERSITY OF MINNESOTA
TWIN CITIES

University Hospitals and Clinics
420 Delaware Street S.E.
Minneapolis, Minnesota 55455

March 20, 1979



To: Wally Mellum, B/C Construction
From: Tom O'Dea, Biomedical Engineering *TO*
Subject: Ambulatory Surgery Rooms

The ambulatory surgery operating rooms and post-anesthesia recovery room were checked for equipotential grounding on March 20, 1979. There were less than 20 millivolts between any two conductive surfaces and any conductive surface and ground.

The isolated power systems for the operating rooms were also tested on March 20. All were found to be in compliance, except for the detection of a balanced resistive fault in all rooms. Mr. Coffin has informed me that the LIM's need not meet this criteria.

Thus, those rooms that are connected meet our requirements.

TO/cm

UNIT B/C - PHASE I
CHANGE ORDER ANALYSIS

As of July 31, 1979

FEDERAL Project #Minn - 18 - H.P.

I. Sheehy Construction (General Contractor):

Original Contract:	\$15,305,000.00	
Change Orders 1 through 27 28	+12,564.00	12,191.00
Reimbursables 11-27554 11-27558	- 5,499.00	12,211.00
	<u>< 1,006.00 ></u>) = 6505
Revised Contract Amount	<u>OK \$15,312,065.00</u>	<u>15,286,304.00</u>

II. Hayes Contractors (Mechanical):

Original Contract:	\$ 6,878,650.00	
Change Orders 1 through 29 Mod 178-E 11-43775	(105,165.40)	
	<u>< 3,570.00 ></u>	
Revised Contract Amount	<u>OK \$ 6,770,484.60</u>	<u>6,769,914.60</u>

III. Premier Electric Company:

Original Contract:	\$ 3,343,090.00	
Change Orders 1 through 24 25	+263,568.24	262,516.24
Reimbursables	-198,956.65	269,170.24
Revised Contract Amount	<u>OK \$ 3,407,693.59</u>	<u>3,396,436.00</u>

Unit B/C
Change Order Analysis

Clemis Electric

Original Contract:

3,343,090.00

Change Order # E-1
Deductive Alternates # 184,700.00

Change Order # E-2
Rainstate Alternates 689,000.00

Change Order # E-3
Mod 31-E <300,771>

Change Order E-4
Mod. 17-E, 19-A + 60-A <478,271>

Change Order E-5
Mod 68-P + 71-E 597,980.00

Change Order E-6
Mod 47-P, 52-P, 53-P, 67-P + 74-P 909,010.00

Change Order E-7
Mod 45-E, 56-P, 59-E, 64-A
+ 70-P 11,743,140.00

Change Order E-8
Mod 81-P, 82-P, 85-P, 90-P, 91-E
95-P, 112-P, 116-P <1862,000>

Change Order E-9
Mod - 69-P, 73-P, 94-P, 96-P
97-P, 98-P + 102-P 8,253,400.00

Change Order #10
Mod 79-E, 106-A, 126-E +
131-P <1,142,000>

Change Order E-11
Mod 125-P + 132-P 316,900.00

1

2

3

4

5

6

7

8

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40

Unit B/C Change Order Analysis

Removal Electric

Change Order E-12

mod 111-P, 120-P, 122-P
129-P, 149-E & 170-P

35312.00

Change Order E-13

mod 55-R, 152-P, 154-P

15821.00

Change Order E-14

mod 144-P, 155-P, 164-P,
167-P, 180-E, 182-E

9062.00

Change Order E-15

mod 153-P & 166-P

12021.00

Change Order E-16

mod 88-P, 186-A, 195-A
& 202-P

1659.00

Change Order E-17

mod 86-P

151.00

Change Order E-18

mod - 234-E

2904.00

Change Order E-19

mod 238-E

2863.00

Change Order E-20

mod 51-P, 66-P, 165-P
241-E

7144.00

Change Order E-21

mod 150-E, 176-E & 242-E

13105.00

Change Order E-22

connections

(12793.00)

Change Order E-23

mod 87-P

1578.00

1

2

3

4

5

6

7

8

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

Unit B/C
Change Order Analysis

Penn Electric

Change Order E-24
Mch 204E, 247-E + 80-P 2476.00

263,560.24

263,560.24

Adjusted Contract Amt

#3079,629.76

UNIT B/C - PHASE-I
Change Order Analysis

Bernier Electric Co

Contingency Reimb

TOTAL

Change Order #1:

Mod. 3-D Deduct alt. 1847000

1847000

#2: ~~Remstate~~ alt.

+689000

689000

#3: Mod. 21-E

<300771>

<300771>

#4: mod 17-E

- 189726

19-A

+ 42182

60-A

+ 99747

<47827>

#5: mod. 68-P

- 129852

71-E

+ 189650

59798

#6: mod 47-P

53000

52-P

744745

53-P

54065

67-P

N/C

74-P

57200

854945

54065

909010

#7: mod 45-E

157300

56-P

16614

59-E

309600

64-A

15600

70-P

680200

1174314

#8: mod 81-P

6500

82-P

247600

85-P

51400

90-P

234500

91-E

18400

95-P

80600

112-P

N/C

116-P

<250000>

<1862000>

fixed

1

2

3

4

5

6

7

8

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

Unit BK - Phase I
Change Order Analysis

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40

Primer Electric Co.

CONTINGENCY REIMB TOTAL

Change Order #9: Mod. 69-P
73-P
94-P
96-P
97-P
98-P
102-P

2261.00
300.00
16936.00
3584.00
17596.00
51221.00
7173.00

83534.00

Change Order #10: Mod. 79-E
106-A
126-E
131-P

- 1249.00
- 170.00
+ 46.00
+ 231.00

- 1373.00 231.00

< 1142.00

Change Order #11: Mod. 125-P
132-P

1213.00 1213.00
743.00
1956.00

3169.00

Change Order #10: Mod. 111-P
120-P
122-P
129-P
169-E
170-P

2576.00
12992.00
6319.00
9283.00
348.00
2795.00

35313.00

Change Order #13: Mod. 55-A
152-P
154-P

202.00
2711.00
12908.00

202.00 15619.00

15821.00

Change Order #14: Mod. 144-P
155-P
164-P
167-P
180-E
182-E

4997.00
665.00
99.00
1085.00

720.00
1496.00

2216.00 6846.00

9062.00

1 2 3 4 5 6 7 8

	1	2	3	4	5	6	7	8
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
32								
33								
34								
35								
36								
37								
38								
39								
40								

Unit B/c - PHASE I
Change Order Analysis

Premier Electric Co

		CONTINGENCY	Reimb.	TOTAL
1	Change Order #15:			
2	Mod. 153-P	661400		
3	146-P		540700	
4		<u>661400</u>	<u>540700</u>	1202100
5				
6	Change Order #16:			
7	Mod. 88-P	40700		
8	136-A	54700		
9	195-A	N/C		
10	202-P		70500	
11		<u>95400</u>	<u>70500</u>	165900
12				
13	Change Order #17: mod. 86-P		15100	15100
14				
15	Change Order #18: Mod. 234-E	<u>290400</u>		290400
16				
17	Change Order #19: Mod. 238-E	<u>286300</u>		286300
18				
19	Change Order #20: Mod. 51-P	164600		
20	66-P	495100		
21	165-P		4600	
22	241-E		50100	
23		<u>659700</u>	<u>54700</u>	714400
24				
25	Change Order #21: mod 150-E		1402800	
26	176-E	- 123500		
27	242-E	21200		
28		<u>- 92300</u>	<u>1402800</u>	1310500
29				
30	Change Order #22: CORRECT MOD 153-E		<1402800>	
31	176-E	123500		<1279300>
32				
33	Change Order #23: Mod. 87-P	<u>157800</u>		157800
34				
35	Change Order #24: Mod 204-E	48200		
36	247-E	112400		
37	80-P		87000	
38		<u>160600</u>	<u>87000</u>	247600
39				
40	S-TOTAL	6460359	1,989,665	<u>8,450,024</u>

1

2

3

4

5

6

7

8

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

Original Contract:

4,878,650.00

Change Order # 1:

mod 2-D - deductive alterations
m-21, m-22, m-23

36,550.00

Change Order # 2:

mods 6-E, 21-E, 22-E, 23-E, 24-E,
27-P, 34-E

< 1,576,870.00 >

Change Order # 3:

mod 20-E

< 3,600.00 >

Change Order # 4:

mods 28-E, 32-E, 35-E + 49-A

2,900.00

Change Order # 5:

mods 17-E, 19-A, 36-E, 37-A
+ 46-E

< 3,860,000.00 >

Change Order # 6:

mod 54-E

< 1,044.40 >

Change Order # 7:

mod 57-E

1,019.00

Change Order # 8:

mods 38-E + 47-P

< 3,848.00 >

Change Order # 9:

mods 58-E, 59-E, 62-E + 64-A

< 4,527.00 >

Change Order # 10:

mods 76-A, 85-P, 134-E

1,881.00

Change Order # 11:

mod 101-P

< 944.00 >

Change Order # 12:

mods 79-E, 126-E, 127-A

< 2,943.00 >

1 2 3 4 5 6 7 8

	1	2	3	4	5	6	7	8
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
32								
33								
34								
35								
36								
37								
38								
39								
40								

B/C - PHASE I
Change Order Analysis

Hayes Contractors

Page 2 of 3

Change Order m-13
mods 104-P, 107-E, 108-E, 109-A,
114-E, 157-A 811000

Change Order m-14
mod. 168-E <584600>

Change Order m-15
mods 55-A + 178-E 2615400

Change Order m-16
mods 139-A + 145-E 739600

Change Order m-17
mod 179-E 70900

Change Order m-18
mod 183-E + 194-E 731300

Change Order m-19
mod 187-E, 193-E + 206-E 601100

Change Order m-20
mod 199-E 124900

Change Order m-21
mods 200-E, 215-A, 216-E,
223-E + 224-E 453600

Change Order m-22
mods 205-E, 225-E + 227-E <237900>

Change Order m-23
mods 228-E + 230-E 61500

Change Order m-24
mod 235-E 17500

Change Order m-25
mod 51-P + 121-A 1981300

1

2

3

4

5

6

7

8

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

B/C - PHASE I
Change Order Analysis

Hayes Contractors

Page 3 of 3

Change Order M-26:

Mod 150-P, 176-E & 244-E

1412500

Change Order M-27:

Mod 150-E & 244-E TO CORRECT

<1536000>

Change Order M-28:

Mod 212-A + 243-E

1371000

Change Order M-29-

Mod 249-E

75800

<10516540>

#677348460

1 2 3 4 5 6 7 8

1								1
2								2
3								3
4								4
5								5
6								6
7								7
8								8
9								9
10								10
11								11
12								12
13								13
14								14
15								15
16								16
17								17
18								18
19								19
20								20
21								21
22								22
23								23
24								24
25								25
26								26
27								27
28								28
29								29
30								30
31								31
32								32
33								33
34								34
35								35
36								36
37								37
38								38
39								39
40								40

UNIT B/C PHASE I
Change Order Analysis

Hayes Contract

	1	2	3	4	5	6	7	8
1	Change Order 1:				Contingency		Total	
2		mod	2-D		<u>365500</u>		365500	
3								
4	2:	"	6-E		N/C			
5		"	21-E		<12675000>			
6		"	22-E		<350000>			
7		"	23-E		<1600000>			
8		"	24-E		<600000>			
9		"	27-P		<22500>			
10		"	34-E		<521200>		<5768700>	
11								
12	3:	"	20-E		<360000>		<360000>	
13								
14	4:	"	28-E		658200			
15		"	32-E		703000			
16		"	35-E		<768600>			
17		"	49-A		<302600>		290600	
18								
19	5:	"	17-E		<3250000>			
20		"	19-A		230900			
21		"	36-E		<34200>			
22		"	37-A		83300			
23		"	46-E		<890000>		<3860000>	
24								
25	6:	"	54-E		104440		104440	
26								
27	7:	"	57-E		101900		101900	
28								
29	8:	"	38-E		<384800>			
30		"	47-P		N/C		<384800>	
31								
32	9:	"	58-E		272100			
33		"	59-E		82100			
34		"	62-E		<800000>			
35		"	64-A		43100		<452700>	
36								
37	10:	"	76-A		38900			
38		"	85-P		54600			
39		"	134-E		94600		188100	
40								

1								1
2								2
3								3
4								4
5								5
6								6
7								7
8								8
9								9
10								10
11								11
12								12
13								13
14								14
15								15
16								16
17								17
18								18
19								19
20								20
21								21
22								22
23								23
24								24
25								25
26								26
27								27
28								28
29								29
30								30
31								31
32								32
33								33
34								34
35								35
36								36
37								37
38								38
39								39
40								40

Unit B/C - PHASE - I
Change Order Analysis

Hayes Contract

1	2	3	4	5	6	7	8
1	Chang. Order # 11: mod.	101-P		Contingency	<94400>		Total <94400>
2							
3	12: mod.	79-E			<581600>		
4	"	126-E			86900		
5	"	127-A			<u>200400</u>		<294300>
6							
7	13: mod.	104-P			N/C		
8		107-E			<46100>		
9		108-E			<292700>		
10		109-A			<36500>		
11		114-E			1047500		
12		157-A			<u>138800</u>		811000
13							
14	14: mod.	168-E			<584600>		<584600>
15							
16	15: mod.	55-P			2258400		
17		178-E			<u>357000</u>		2615400
18							
19	16: mod.	139-A			190300		
20		145-E			<u>549300</u>		739600
21							
22	17: mod.	179-E			<u>70900</u>		70900
23							
24	18: mod.	183-E			672500		
25		194-E			<u>58800</u>		731300
26							
27	19: mod.	187-E			509300		
28		193-E			65500		
29		206-E			<u>26200</u>		601100
30							
31	20: mod.	199-E			124900		124900
32							
33	21: mod.	200-E			194900		
34		215-A			134700		
35		216-E			50100		
36		223-E			8800		
37		224-E			<u>65100</u>		453600
38							
39							
40							

1 2 3 4 5 6 7 8

1								1
2								2
3								3
4								4
5								5
6								6
7								7
8								8
9								9
10								10
11								11
12								12
13								13
14								14
15								15
16								16
17								17
18								18
19								19
20								20
21								21
22								22
23								23
24								24
25								25
26								26
27								27
28								28
29								29
30								30
31								31
32								32
33								33
34								34
35								35
36								36
37								37
38								38
39								39
40								40

UNIT B/C - PHASE I
Change Order Analysis

Hayes Contractors

	2	3	4	5	6	7	8
1	Change Order #22:	Mod. #	205-E	Contingency	<240000>		Total
2			225-E		10000		
3			227-E		11000		<237900>
4							
5	23:	Mod. #	228-E		24600		
6			230-E		36900		61500
7							
8	24:	Mod. #	235-E		17500		17500
9							
10	25:	Mod. #	51-P		400000		
11			128-A		1581300		1981300
12							
13	26:	Mod. #	150-P		1402800		
14			176-E		<123500>		
15			244-E		133200		1412500
16							
17	27:	Corrections			<1536000>		<1536000>
18							
19	28:	Mod. #	212-A		101800		
20			243-E		1269200		1371000
21							
22	29:	Mod. #	249-E		75800		75800
23							
24							<u>10516540</u>
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							

1

2

3

4

5

6

7

8

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40

UNIT B/C - PHASE I
Change Order Analysis

Sheehy Construction

Page 1 of 3

Original Contract

\$15,305,000.00

Change Order #1:

mod 1-D - deduct alternate 141,000.00

Change Order G-2

modos 14-P, 18-A, 26-P, 29-E + 30-E <128744.00>

Change Order G-3

modos 5-E, 27-P, 40-E + 16-P <47680.00>

Change Order G-4

modos 28-E, 32-E + 41-E <55073.00>

Change Order G-5

modos 17-E, 19-A, 37-A + 46-E <1108.00>

Change Order G-6

modos 43-A, 44-A + 48-A 10819.00

Change Order G-7

modos 63-P + 65-P N/A

Change Order G-8

modos 47-P, 74-P, 77-P, 92-E,
93-E + 100-E 35426.00

Change Order G-9

modos 42-E, 58-E, 64-A, 115-E,
117-P + 118-E <18684.00>

Change Order G-10

modos 76-A, 90-P, 91-E
+ 137-A <234.00>

Change Order G-11

modos 99-A, 124-E, 143-E,
146-E, 148-E <12258.00>

1								1
2								2
3								3
4								4
5								5
6								6
7								7
8								8
9								9
10								10
11								11
12								12
13								13
14								14
15								15
16								16
17								17
18								18
19								19
20								20
21								21
22								22
23								23
24								24
25								25
26								26
27								27
28								28
29								29
30								30
31								31
32								32
33								33
34								34
35								35
36								36
37								37
38								38
39								39
40								40

Unit B/C - Phase I
Change Order Analysis
Sheets Construction

Page 2 of 3

1	Change Order G-12-	
2	Mod. 127-A, 136-A, 149-P + 158-E	1683300
3		
4	Change Order G-13-	
5	Mod. 156-P	N/C
6		
7	Change Order G-14-	
8	Mod. 66-P + 162-P	100600
9		
10	Change Order G-15	
11	Mod. 55-A + 128-A	438900
12		
13	Change Order G-16	
14	Mod. 139-A, 181-E + 184-E	551700
15		
16	Change Order G-17	
17	Mod. 179-E + 188-E	88500
18		
19	Change Order G-18	
20	Mod. 186-A, 198-P + 203-E	111100
21		
22	Change Order G-19	
23	Mod. 208-E, 209-E, 210-E	
24	+ 211-E	570900
25		
26	Change Order G-20	
27	Mod. 199-E + 214-P	160600
28		
29	Change Order G-21	
30	Mod. 219-E + 220-P	2443200
31		
32	Change Order G-22	
33	Mod. 201-E + 229-E	<170500>
34		
35	Change Order G-23	
36	Mod. 236-E	<400000>
37		
38	Change Order G-24	
39	Mod. 51-P + 239-E	1593700
40		

1

2

3

4

5

6

7

8

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40

Unit B.P. - ~~Blow~~
Change Order Analysis

Heavy Construction

Page 3 of 3

Change Order # G-25

Mod. 165-P, 237-P, 245-E, 246-E 7507.00

Change Order # G-26

Mod. Corrections <1699.00>

Change Order # G-27

Mod. 248-E & 231-P 11572.00

12564.00 12564.00

Adjusted Contract Amt.

*15317564.00

UNIT B/C - PHASE I

Change Order Analysis

Shady Construction

	1	2	3	4	5	6	7	8
					Contingency	REimb.	Total	
1	Change Order 1: mod. 1-D				141000.00		141000.00	
2								
3								
4	2: mod 14-P				9496.00			
5			18-A		<31000.00>			
6			26-P		<22000.00>			
7			29-E		<29700.00>			
8			30-E		<55540.00>		<128744.00>	
9								
10	3: mod. 5-E				<24680.00>			
11			27-P		N/C			
12			40-E		<23000.00>			
13			16-P		N/C		<47680.00>	
14								
15	4: mod. 28-E				N/C			
16			32-E		2064.00			
17			41-E		<57137.00>		<55073.00>	
18								
19	5: mod. 17-E				<1131.00>			
20			19-A		185.00			
21			37-A		N/C			
22			46-E		<162.00>		<1108.00>	
23								
24	6: mod. 42-A				5346.00			
25			44-A		3000.00			
26			48-A		2473.00		10819.00	
27								
28	7: mod. 63-P				N/C			
29			65-P		N/C		N/C	
30								
31	8: mod. 47-P				5315.00			
32			74-P		1257.00			
33			77-P		<334.00>			
34			92-E		1752.00			
35			93-E		28086.00			
36			100-E		<650.00>		35426.00	
37								
38								
39								
40								

1 2 3 4 5 6 7 8

1								1
2								2
3								3
4								4
5								5
6								6
7								7
8								8
9								9
10								10
11								11
12								12
13								13
14								14
15								15
16								16
17								17
18								18
19								19
20								20
21								21
22								22
23								23
24								24
25								25
26								26
27								27
28								28
29								29
30								30
31								31
32								32
33								33
34								34
35								35
36								36
37								37
38								38
39								39
40								40

Unit B/C - Phase I
Change Order Analysis

Shelby Construction

Contingency REimb Total

Line	Description	Contingency	REimb	Total
2	Change Order # 9: Mod. 42-E	<261700>		
3	58-E	224000		
4	64-A	69300		
5	115-E	<570000>		
6	117-P	<290000>		
7	118-E	<1040000>		<1868400>
9	10: Mod. 76-A	25600		
10	90-P	17300		
11	91-E	53700		
12	137-A	<120000>		<23400>
14	11: Mod. 99-A	124500		
15	124-E	<350000>		
16	143-E	<90000>		
17	146-E	2316200		
18	148-E	<76500>		<1225800>
20	12: Mod. 127-A	28100		
21	136-A	<112000>		
22	149-P	125000		
23	158-E	1642200		1683300
26	13: Mod. 156-P	NK		NK
28	14: Mod. 66-P	NK		
29	162-P	100600		100600
31	15: Mod. 55-A	374800		
32	128-A	64100		438900
34	16: Mod. 139-A	12500		
35	181-E		549900	
36	184-E	-10700		551700
38	17: Mod. 179-E	41100		
39	188-E	47400		88500

Unit B/C - Phase I
 Change Order Analysis
 Heavy Construction

		Contingency	Reinst	Total
1	Change Order 18: mod. 186-A	28600		
2	198-P	N/C		
3	203-E	82500		111100
4				
5	19: mod. 208-E	- 263500		
6	209-E	732800		
7	210-E	43600		
8	211-E	58000		570900
9				
10	20: mod. 199-E	69100		
11	214-P	91500		160600
12				
13	21: mod. 219-E	2406900		
14	220-P	86300		2443200
15				
16	22: mod. 201-E	- 122900		
17	229-E	- 49600		<170500>
18				
19	23: mod. 236-E	<400000>		<400000>
20				
21	24: mod. 51-P	N/C		
22	239-E	1593700		1593700
23				
24	25: mod. 165-P		115400	
25	237-P		N/C	
26	245-E	31400	23100	
27	246-E	580800		750700
28				
29	26: Correction	<31400>	<138500>	<169900>
30				
31				
32	27: mod. 248-E	1157200		
33	231-P	N/C		1157200
34				
35			549900	\$1256400
36				
37				
38				
39				
40				

Unit B/C - Phase I
Change Order Analysis

As of July 31, 1979

FEDERAL Project # MINN-18-H.P.

I Shady Construction (General Contractor):

Original Contract:

\$1,530,000.00

Change Order / thru 27-

+ 125,640.00

Reimbursable

- 54,990.00

Revised Contract Amount

\$1,531,206.50

II Hays Contractors (Mechanical):

Original Contract:

\$687,650.00

Change Order / thru 29-

<105,165.40>

Revised Contract Amt

\$677,348.60

III Premier Electric Co.

Original Contract:

\$334,090.00

Change Order 1-24

+ 263,562.40

Reimbursable

- 198,956.65

Revised Contract Amt

\$340,763.59

Note: A complete analysis of each contract is attached.

There are other contracts ongoing in Building B/C as we are currently infilling the remaining shell space. In some cases the work areas overlap.

~~Therefore~~ Therefore, we maintain complete records so that each portion correctly accounts for their funds and obligations.

1 2 3 4 5 6 7 8

	1	2	3	4	5	6	7	8	
1									1
2									2
3									3
4									4
5									5
6									6
7									7
8									8
9									9
10									10
11									11
12									12
13									13
14									14
15									15
16									16
17									17
18									18
19									19
20									20
21									21
22									22
23									23
24									24
25									25
26									26
27									27
28									28
29									29
30									30
31									31
32									32
33									33
34									34
35									35
36									36
37									37
38									38
39									39
40									40



DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE

REGION V

300 SOUTH WACKER DRIVE
CHICAGO, ILLINOIS 60606

OFFICE OF THE
PRINCIPAL REGIONAL OFFICIAL

August 9, 1979

Our Reference: MINN-18 (HP)
Health Science Expansion B/C
University of Minnesota
Minneapolis, Minnesota

AUG 13 Rec'd

UNIV. OF MINN.
HEALTH SCIENCE
PLANNING OFFICE

Final Inspection - July 18, 1979

Mr. Paul J. Maupin
Health Science Planning Coordinator
University of Minnesota
4104 Powell Hall
Minneapolis, Minnesota 55455

Dear Mr. Maupin:

A final inspection was made at subject facility on July 18, 1979 on the new construction of Building B/C. The remainder of the project consists of renovation construction in Diehl Hall, which shall be identified with a suffix and handled as a separate project through review and construction.

Persons in attendance were:

- Victor Scott, University Of Minnesota
- Paul J. Maupin, University of Minnesota
- Oliver W. Hughes, University of Minnesota
- Jim Hastert, University of Minnesota
- Paul Kopietz, University of Minnesota
- Richard Hendricks, University of Minnesota
- Wallace Mellum, University of Minnesota
- Duane E. Blanchard, HSAE, Architects and Engineers
- Ken Fick, Sheehy Construction Company
- Ray Anderson, Hayes Contractors
- Earl Romnes, Westinghouse Elevator Co.
- Fred Janke, Premier Electric
- Samuel R. Curiale, P.E., DHEW/ROFEC-Chicago

Construction is 99+ complete with 100% occupancy. The facility is esthetically attractive externally and internally, and workmanship in construction appears to have been exceptionally good.

Please advise this office when all of the items listed below have been accomplished and/or resolved.

1. Submit to this office certification from the Architect/Engineer when all systems and items of equipment have been adjusted, tested and approved. Include the following:

OK Ventilation air balancing report showing actual cfm vs. design cfm. This report shall not be submitted until reviewed and approved with signature by the design engineer.

OK b. Letter from the fire department that they have inspected and approved the fire alarm system.

OK c. Manufacturer's certification that the flame spread rating of the floor carpeting does not exceed 75.

OK d. Certified test approving the x-ray shielding by a radiologist or physicist.

OK e. Certified test of air tightness of all fume ducts per specifications.

OK f. Letter from the University of Minnesota certifying to a complete test of operations (including smoke dampers) of the smoke control system.

OK g. Certification that the "Rubatex" pipe insulation has a flame spread rating not exceeding 25, and a smoke developed rating not exceeding 150.

OK h. Test report on the equipotential grounding systems per NFPA No. 56A.

OK 2. The insulation on fittings and equipment were noted to be wrapped with canvas, contrary to our review letters and HSAE's response. Please respond.

OK 3. Mark all filter manometers for the maximum static points for filter cleaning or changing.

4. Handicap Toilet Rooms:

OK a. Have all tilt type mirrors permanently in tilt position rather than latched back to walls.

OK b. There are several handicap toilet stalls noted to have only one wall-mounted grab bar, such as on the 12th and 3rd floors. Check all handicap toilet stalls.

OK c. Complete identification of all handicap toilet rooms.

OK 5. Eleventh floor Animal O.R.'s - these rooms are not equipped with isolated power or conductive flooring, therefore no inhalation gases are permitted. Post signs to this effect.


OK 6. The chute door on the 9th floor was lacking a latching device. Correct.

MINN-18 (HP)
University of Minnesota
Minneapolis, Minnesota

- OK* 7. Remove debris and temporary hold-open devices on all fire dampers. Check for proper operations to fully closed positions.
- OK* 8. Provide a system of visual alarms in the fire alarm system for the benefit of persons with hearing disabilities.
- OK* 9. Minor O.R.'s, Recovery Room, and Holding Prep Room: All of these areas are equipped with equipotential grounding systems, however, none of the plug-in jacks are used to connect the movable equipment having conductive surfaces. Though these life saving devices were installed, they are not being used. It is incumbent on the Owner, to assure maximum safety to patients in accordance with NFPA No. 56A.
- OK* 10. Several faucets in Clinical Laboratory were without red tags for the vacuum breaker loop systems. If these faucets are not connected thereto, provide vacuum breakers or anti-hose adapters.
- OK* 11. Vacuum breakers were not found for any of the floor flush drains in the dog areas in Diehl Hall. If these are not connected to the vacuum breaker loop systems, provide vacuum breakers.
- OK* 12. The activation of a manual fire alarm pull station will cause the respective zone to negativize even though the fire hazard is not in that zone. Request an investigation be made to determine what is involved, including cost, to remove this condition. Please respond.
- OK* 13. Payrolls were spot checked and all appeared to be in order.
- OK* 14. A Form FEC 2-14 is required to be completed with all cost data and change order information in order to close out this project on a partial basis for the new construction. A final FEC 2-14 report is necessary on total completion of the project including the renovation construction in Diehl Hall. The required gathering of information is in process with Mr. Paul Maupin for subsequent completion.
- OK* 15. A copy of Form FEC 4-24a is included for your information.

For further discussions on the above, please contact Samuel R. Curiale, P.E. at (312) 353-2757.

Sincerely yours,



Sal A. Cannella, R.A.
Chief, Design and Engineering
Division of Regional Operations
Facilities Engineering
and Construction

Enclosure



UNIVERSITY OF MINNESOTA
TWIN CITIES

Health Sciences Planning Office
Physical Planning
4103 Powell Hall, Box 75
500 Essex Street S.E.
Minneapolis, Minnesota 55455
(612) 373-8981

August 23, 1979

TO: Mr. Oliver Hughes
Construction Superintendent

FROM: Paul J. Maupin *Paul*
Health Sciences Planning Coordinator

SUBJECT: Unit B/C - Phase I
Federal Inspection - July 18, 1979

I have attached a copy of the Federal report submitted to this office on August 9, 1979 relative to the July 18, 1979 inspection.

We have highlighted those areas that fall under your responsibility. Please submit your response to this office within 10 working days.

PJM: jm

DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE
OFFICE OF FACILITIES ENGINEERING AND PROPERTY MANAGEMENT

FINAL REPORT ON CONSTRUCTION

1. Project No. <u>MIND-18-HP</u>														
2. Project Type <u>NEW CONSTRUCTION</u>														
3. Applicant <u>UNIV of MIND</u>														
4. Project Location <u>516 DELAWARE ST. J.E.</u> <u>MIND MAIN 5932</u>														
5. Project Description (as completed)														
5a. The project has been constructed to conform with applicable Federal statutes and regulations. <u>yes</u>														
6. Date of Final Inspection <u>7-18-79</u>		7. Contract Completion Date (if known)												
8. Date of Substantial Completion <u>12-78</u>		9. Date of Occupancy (if known) <u>JAN & FEB, 1979</u>												
10. Participants at Final Inspection														
<table border="0"> <tr> <td><u>V. SCOTT</u></td> <td><u>Duane Blanchard</u></td> </tr> <tr> <td><u>PS Martin</u></td> <td><u>Ken Fick</u></td> </tr> <tr> <td><u>OW Hughes</u></td> <td><u>Ray Anderson</u></td> </tr> <tr> <td><u>P. Kowitz</u></td> <td><u>Earl Romms</u></td> </tr> <tr> <td><u>D. Hendrick</u></td> <td><u>Fred Janke</u></td> </tr> <tr> <td><u>W. Mellum</u></td> <td><u>Sam Curiale</u></td> </tr> </table>			<u>V. SCOTT</u>	<u>Duane Blanchard</u>	<u>PS Martin</u>	<u>Ken Fick</u>	<u>OW Hughes</u>	<u>Ray Anderson</u>	<u>P. Kowitz</u>	<u>Earl Romms</u>	<u>D. Hendrick</u>	<u>Fred Janke</u>	<u>W. Mellum</u>	<u>Sam Curiale</u>
<u>V. SCOTT</u>	<u>Duane Blanchard</u>													
<u>PS Martin</u>	<u>Ken Fick</u>													
<u>OW Hughes</u>	<u>Ray Anderson</u>													
<u>P. Kowitz</u>	<u>Earl Romms</u>													
<u>D. Hendrick</u>	<u>Fred Janke</u>													
<u>W. Mellum</u>	<u>Sam Curiale</u>													
11. a. Final A E and Construction Related Costs (Type of Construction - New <input checked="" type="checkbox"/> Addition <input type="checkbox"/> Alteration <input type="checkbox"/>														
	<u>Total Costs</u>	<u>Ineligible Costs</u>												
b. Building Cost	\$	\$												
Built-in Equipment														
Site Work														
Central Utility Plant														
Total Construction														
A/E Fees														
Other A E Costs														
Total A E Costs														
Construction Management Fees														
TOTAL	\$	\$												

c. The items previously ruled ineligible for Federal participation are as follows: (List by specific identification and cost)

d. It is recommended that the following additional items also be found ineligible for Federal participation. (List by specific identification and cost)

12. Summary of Construction and Built-in Equipment Contracts

<u>Contractor</u>	<u>\$ Base Contract</u>	<u>\$ Change Orders</u>	<u>Total \$ Cost</u>
Premier	3,343,590 ⁰⁰	+263,560.24	3,607,150.24
Hays	6,773,484 ⁰⁰	<105,125.50	6,773,484.00
Shelby	15,305,000 ⁰⁰	+12,564 ⁰⁰	15,317,564 ⁰⁰ (2)

(2) 5490.00

(1) 198,956.65 REING FROM OTHER SOURCE

13. A tabulation of areas contained in the completed facility is attached.
(HEF Projects Only) Check

Date

Regional Engineer

Instructions: For Office of Education and National Institutes of Health, all items on the form shall be completed. For Health Facilities projects, items 11, 12, and 13 may be omitted unless requested by Program.

University
of
Minnesota
memo

date August 23 1979

to Bob Swanson
from Paul Maupin *Paul*

Attached is a copy of the Federal report following the July 18, 1979.
Please respond to the items highlited.



DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE

REGION V

300 SOUTH WACKER DRIVE
CHICAGO, ILLINOIS 60606

OFFICE OF THE
PRINCIPAL REGIONAL OFFICIAL

August 9, 1979

Our Reference: MINN-18 (HP)
Health Science Expansion B/C
University of Minnesota
Minneapolis, Minnesota

Final Inspection - July 18, 1979

AUG 13 Rec'd

UNIV. OF MINN.
HEALTH SCIENCE
PLANNING OFFICE

Mr. Paul J. Maupin
Health Science Planning Coordinator
University of Minnesota
4104 Powell Hall
Minneapolis, Minnesota 55455

Dear Mr. Maupin:

A final inspection was made at subject facility on July 18, 1979 on the new construction of Building B/C. The remainder of the project consists of renovation construction in Diehl Hall, which shall be identified with a suffix and handled as a separate project through review and construction.

Persons in attendance were:

- Victor Scott, University of Minnesota
- Paul J. Maupin, University of Minnesota
- Oliver W. Hughes, University of Minnesota
- Jim Hastert, University of Minnesota
- Paul Kopietz, University of Minnesota
- Richard Hendricks, University of Minnesota
- Wallace Mellum, University of Minnesota
- Duane E. Blanchard, HSAE, Architects and Engineers
- Ken Fick, Sheehy Construction Company
- Ray Anderson, Hayes Contractors
- Earl Romnes, Westinghouse Elevator Co.
- Fred Janke, Premier Electric
- Samuel R. Curiale, P.E., DHEW/ROFEC-Chicago

Construction is 99+ complete with 100% occupancy. The facility is esthetically attractive externally and internally, and workmanship in construction appears to have been exceptionally good.

Please advise this office when all of the items listed below have been accomplished and/or resolved.

1. Submit to this office certification from the Architect/Engineer when all systems and items of equipment have been adjusted, tested and approved. Include the following:

- a. Ventilation air balancing report showing actual cfm vs. design cfm. This report shall not be submitted until reviewed and approved with signature by the design engineer.
 - b. Letter from the fire department that they have inspected and approved the fire alarm system.
 - c. Manufacturer's certification that the flame spread rating of the floor carpeting does not exceed 75.
 - d. Certified test approving the x-ray shielding by a radiologist or physicist.
 - e. Certified test of air tightness of all fume ducts per specifications.
 - f. Letter from the University of Minnesota certifying to a complete test of operations (including smoke dampers) of the smoke control system.
 - g. Certification that the "Rubatex" pipe insulation has a flame spread rating not exceeding 25, and a smoke developed rating not exceeding 150.
 - h. Test report on the equipotential grounding systems per NFPA No. 56A.
2. The insulation on fittings and equipment were noted to be wrapped with canvas, contrary to our review letters and HSAE's response. Please respond.
 3. Mark all filter manometers for the maximum static points for filter cleaning or changing.
 4. Handicap Toilet Rooms:
 - a. Have all tilt type mirrors permanently in tilt position rather than latched back to walls.
- * ~~_____ several handicap toilet stalls and the only~~
 mounted grab bar, such as on the 12th and 3rd floors. Check all handicap toilet stalls. *discuss with [unclear]*
- c. Complete identification of all handicap toilet rooms.
- * ~~_____ floor Animal O. P. _____~~ these rooms are not equipped with isolated power or conductive flooring, therefore no inhalation gases are permitted. Post signs to this effect. *discuss with [unclear] - 1/17/77 discussed with [unclear]*
6. The chute door on the 9th floor was lacking a latching device. Correct. *Q. [unclear]*

MINN-18 (HP)
University of Minnesota
Minneapolis, Minnesota

7. Remove debris and temporary hold-open devices on all fire dampers. Check for proper operations to fully closed positions.
8. Provide a system of visual alarms in the fire alarm system for the benefit of persons with hearing disabilities.
9. Minor O.R.'s, Recovery Room, and Holding Prep Room: All of these areas are equipped with equipotential grounding systems, however, none of the plug-in jacks are used to connect the movable equipment having conductive surfaces. Though these life saving devices were installed, they are not being used. It is incumbent on the Owner, to assure maximum safety to patients in accordance with NFPA No. 56A.
10. Several faucets in Clinical Laboratory were without red tags for the vacuum breaker loop systems. If these faucets are not connected thereto, provide vacuum breakers or anti-hose adapters.
11. Vacuum breakers were not found for any of the floor flush drains in the dog areas in Diehl Hall. If these are not connected to the vacuum breaker loop systems, provide vacuum breakers.
12. The activation of a manual fire alarm pull station will cause the respective zone to negativize even though the fire hazard is not in that zone. Request an investigation be made to determine what is involved, including cost, to remove this condition. Please respond.
13. Payrolls were spot checked and all appeared to be in order.
14. A Form FEC 2-14 is required to be completed with all cost data and change order information in order to close out this project on a partial basis for the new construction. A final FEC 2-14 report is necessary on total completion of the project including the renovation construction in Diehl Hall. The required gathering of information is in process with Mr. Paul Maupin for subsequent completion.
15. A copy of Form FEC 4-24a is included for your information.

For further discussions on the above, please contact Samuel R. Curiale, P.E. at (312) 353-2757.

Sincerely yours,



Sal A. Cannella, R.A.
Chief, Design and Engineering
Division of Regional Operations
Facilities Engineering
and Construction

Enclosure

Project # MINN 1749 Institution UNIV. OF MINN. Building B/C

Address _____ City MINNEAPOLIS State MINN C.D. _____


CHAPTER 3

MINIMUM MANDATORY REQUIREMENTS FOR ACCESSIBILITY

The material in this chapter applies to all HEW Federally Assisted projects, including new construction and alteration projects, as required by the ANSI A117.1-1961 (R1971) Standard.


3.1 Walks

- a. Public walks shall be made to form a continuing common surface uninterrupted by steps or abrupt changes in level.
- b. A walk shall have a level platform at the top which is a minimum of 60 by 60 inches if a door swings out toward the platform or the walk. This platform shall extend at least 12 inches beyond each side of the doorway. If the door does not swing toward the platform or the walk, there shall be a level platform at least 36 inches deep and 60 inches wide, extending at least 12 inches beyond each side of the doorway.



3.2 Ramps

- a. Ramps shall have a maximum gradient of 8.33 percent, or one foot rise in 12 feet of run.
- b. Ramps shall have non-slip surfaces.
- c. Each ramp shall be provided with a level platform at the top at least 60 by 60 inches if a door swings out toward the platform or the ramp. If the door does not swing toward the platform or the ramp, there shall be a level platform at least 36 inches deep and 60 inches wide. All platforms shall extend at least 12 inches beyond each side of a door.
- d. There shall be a straight clearance of at least 72 inches at the bottom of each ramp.
- e. Ramps shall be provided with level landings at 30 foot intervals and at all changes in direction.



- ✓ f. Ramps shall be provided with handrails 32 inches in height on at least one side and preferably both sides. The rails must be smooth and extend at least 12 inches beyond the top and bottom of the ramp.

✓ 3.3 Entrances

- ✓ a. At least one primary entrance to each building must be usable by persons in wheelchairs.
- ✓ b. At least one entrance accessible by wheelchair must be located on a level which is accessible to the building elevators.

3.4 Doors


- ✓ a. Doors must have a clear opening of at least 32 inches when open and must be operable by a single effort.
- ✓ b. The floor on both the inside and outside of each door must be level for at least 60 inches from the door in the direction of the swing. The floor shall extend at least 12 inches beyond each side of the door.
- ✓ c. Thresholds shall be flush with the floor if possible. Sharp inclines and abrupt changes in level must be avoided at doorsills.

3.5 Floors

- ✓ a. Floors must be on a common level throughout a given story, or be connected by ramps as described above.
- ✓ b. Floors must have non-slip surfaces.

3.6 Stairs

- ✓ a. Steps shall not have square or abrupt nosings.
- * b. Stairs shall have handrails 32 inches high measured vertically from the stair nosing. At least one handrail must extend at least 18 inches beyond both the top and the bottom step.



* Trog is 14"
Bottom over 18"


36"


3.7 Elevators

- ✓ a. Elevators must be accessible at the level of the major building entrance which is usable by the handicapped. These elevators must give access to all building levels normally used by the public.
- ✓ b. Elevator cab size must allow for the movement of a wheelchair sufficient for the independent use and operation of the elevator. Space for a 180 degree turn is not required in all cases, but is recommended where necessary for accomplishing the usual function of the elevator.
- ✓ c. Door clear opening width must be 32 inches minimum.
- ✓ d. All essential controls which can be approached for unilateral vertical reach from a wheelchair shall be mounted at a maximum height of 54 inches to 78 inches. It is recommended that a maximum height of 60 inches be observed. Controls requiring a diagonal reach from a wheelchair shall be mounted no higher than 48 inches from the floor.

3.8 Toilet Facilities

- ✓ a. An appropriate number of toilet rooms shall be accessible to and usable by the physically handicapped.
- ✓ b. Accessible toilet rooms shall have sufficient space to allow for wheelchair traffic.
- ✓ c. At least one toilet stall in each toilet room serving the handicapped shall have:
 - ✓ (1) A minimum width of 36 inches and a depth of at least 56 (and preferably 60) inches.
 - ✓ (2) A door (where doors are used) 32 inches wide which swings out.





- ✓ (3) Wall-mounted grab bars on each side, 1-1/2 inches in diameter, 1-1/2 inches clear of the wall, and mounted securely at ends and center 33 inches high and parallel to the floor. * 29" To Top

- ✓ (4) A water closet with seat 20 inches above the floor.

- ✓ d. At least one lavatory in each toilet room serving the handicapped shall be mounted with a 29-inch minimum clearance underneath the apron of the fixture.

- ✓ e. Men's toilet rooms shall have wall-mounted urinals with the rim 19 inches above the floor, or shall have floor-mounted urinals which are at the same level as the main floor of the toilet room.

- ✓ f. Mirrors and shelves shall be mounted above accessible lavatories at as low a height as possible, but not to exceed 40 inches from the bottom of the mirror to the floor.


- ✓ g. At least one towel dispenser or towel rack and one each of other dispensers and disposal units shall be mounted no higher than 40 inches above the floor. * = 47"

3.9 Drinking Fountains

- ✓ a. An appropriate number of drinking fountains or other water dispensers which are usable by the physically handicapped shall be provided at accessible locations.
- ✓ b. The fountain must be hand-operated or hand-and-foot operated with up-front water jet and controls.

3.10 Controls

- ✓ a. All essential or frequently used controls shall be located within reach of persons in wheelchairs.



UNIVERSITY OF MINNESOTA
TWIN CITIES

Interior Design and Graphics
Office of Physical Planning
530 Johnston Hall
101 Pleasant Street S.E.
Minneapolis, Minnesota 55455
(612) 373-2030

SEP 4 Rec'd
UNIV. OF MINN.
THE CLINIC
PHYSICAL PLANNING

29 August, 1979

To: Paul Maupin

From: Lee Meyer

Subject: BC Phase I Federal Inspection (restroom identification)


In reference to your inquiry into the identification of the handicapped facilities in BC, I presume that the deficiencies are in the lack of a handicapped symbol for the restrooms internal to the clinic waiting areas. The major public restrooms fronting corridors were identified with the acrylic signs, featuring raised copy and screened handicapped symbol.

The restroom signs for the areas internal to the clinics can be modified by providing appropriate inserts for the sign holders. I have ordered inserts for the signs as noted on the attached plan set, and will have them installed. This should be corrected within a week or so.

Paul, if you have any other questions regarding this, please give me a call.


LM

enc.






BASEMENT

[Handwritten notes and signatures in cursive script, mostly illegible due to fading and bleed-through.]




SQUARE ITEMS





EIGHTH FLOOR
SIGN LOCATIONS



NINTH FLOOR

1-18
 1-17
 1-16
 1-15
 1-14
 1-13
 1-12
 1-11
 1-10
 1-9
 1-8
 1-7
 1-6
 1-5
 1-4
 1-3
 1-2
 1-1

HSAE

HEALTH SCIENCES ARCHITECTS AND ENGINEERS INC
UNIVERSITY PARK PLAZA SUITE 704 2829 UNIVERSITY AVENUE S.E. MINNEAPOLIS, MINNESOTA 55414 (612) 378-3833

31 August 1979

SEP 8 Rec'd

UNIV. OF MINN.
HEALTH SCIENCE
PLANNING OFFICE

Mr. Paul J. Maupin
Health Sciences Planning Coordinator
University of Minnesota
4104 Powell Hall
Minneapolis, Minnesota 55455

RE: Unit B/C-Phase I
Federal Inspection July 18, 1979

Dear Mr. Maupin:

In response to your memorandum to me dated August 23, 1979, we offer the following comments on the highlited items marked on the enclosed ROFEC letter dated August 9, 1979.

1a. As you are aware, ventilation air balancing is being performed by Mechanical Data Corporation under separate independent contract awarded by the University. We will, however, be happy to review the air balance report of actual cfm vs. design cfm when the document is complete and submitted to us by this Contractor or by the University.

1b. We understand the Contractor has performed the specified testing of the fire management system of which the fire alarm system is a part. The results of this testing apparently were submitted to University Engineering and Construction. If a Fire Department inspection and certification of the system is required, this should be arranged by the appropriate University authority.

1c. The Contract Documents of the project indicate floor carpet is "not-in-contract". University Interiors contracted this work without our direct participation and, therefore, we cannot verify the flame spread rating. The floor carpet specifications for subsequent phases of B/C Shell Space Completion are specified to have a flame spread not exceeding 75.

1d. University Engineering and Construction indicates they are unaware of X-Ray shielding tests having been performed. You may recall the basic radiation protection system was designed in accordance with recommendations by J. Thomas Payne, Radiological Physicist, University Department of Radiology. Our specification section 13750 Radiation Protection further indicates these tests were to be performed by the Owner as follows:

PETE MERZ

DAVE KERKOW
OR
DON HERRON

JEFF HAGAN



E. Furnished by Owner:

1. Provide and pay for testing of rooms and spaces.

1.2 TESTING

A. After all X-Ray protection has been installed, the University's staff (Registered X-Ray Physicist), will test the entire installation with a monitoring device in accordance with National Bureau of Standards Handbook 76, Section 4. Any part of the work which is found to be deficient in required X-Ray protection (as determined by University) shall be corrected by the Contractor to test satisfactorily at no additional cost to the University.

The requested certified tests should be provided by the University's Registered X-Ray Physicist.

1e. The fume hood duct system leakage testing has been performed by the Independent Balancing Contractor who should provide the necessary certification.

1f. We understand the Contractor has performed the specified testing of the fire management system of which the smoke control system is a part. The results of this testing apparently were submitted to University Engineering and Construction. The appropriate University authority should provide whatever letter is necessary to indicate compliance and understanding of the operation of the system.

1g. Manufacturer's literature indicates "Rubatex" pipe insulation has a flame spread rating not exceeding 25 and a smoke developed rating not exceeding 100. We suggest the Mechanical Contractor submit to the University the manufacturer's certification indicating the appropriate ratings.

h. We understand that the Electrical Contractor has performed testing of the equipotential grounding system and the satisfactory results were submitted to University Engineering and Construction.

Furthermore, we are aware that the Ambulatory Surgery conductive flooring installed under the General Contract did not meet the specified NFPA 56A requirements. Ultimately, we were given direction by University Engineering and Construction to process modification 253-E (item no. 2) dated 25 July 1979 which allowed a credit to the Contract for failure of conductivity testing of this floor area.

9. Since this item seems to be an operational rather than a design consideration, the University Departmental Users should provide the reasons why movable equipment with conductive surfaces are not plugged into jacks equipped with the equipotential ground system.

PETE
MERZ

DAVE
KERKOW

LIM
HASTERT

DAVE
KERKOW

G. WART

Mr. Paul J. Maupin
31 August 1979
Page Three

Please advise me if you need any further assistance in responding to the subject letter from ROFEC.

Sincerely yours,

HEALTH SCIENCES ARCHITECTS AND ENGINEERS, INC.

A handwritten signature in black ink that reads "Duane E. Blanchard". The signature is written in a cursive style with a large, prominent initial "D".

Duane E. Blanchard

DEB/kn

cc: John Patterson



UNIVERSITY OF MINNESOTA
TWIN CITIES

Health Sciences Expansion
Construction Office
611 Delaware Street S.E.
Minneapolis, Minnesota 55414

Paul
9/7/79

September 7, 1979

MEMO

SEP 6 *Rec'd*

TO: Joycene Maroney

FROM: James Hastert

JH

UNIV. OF MINN.
HEALTH SCIENCE
PLANNING OFFICE

RE: Unit B/C, Health Sciences Expansion
Federal Inspection Letter Dated August 9, 1979

Answers to Memo dated August 23, 1979

- 2. Letter sent to contractor asking for a response to number 2.
- 10. Item #10 Physical Plant has changed faucet use in one case. Contractor has installed tags on unmarked faucet.
- 11. Flushing rim floor drains are on vacuum breaker loop.

Answer to Memo dated September 6, 1979

- 1G Check Addendum #2, page 22, Item 100 and Mod. 54-E. Materials are enclosed.



UNIVERSITY OF MINNESOTA
TWIN CITIES

Physical Planning
Design Office
62 Folwell Hall
9 Pleasant Street S.E.
Minneapolis, Minnesota 55455
(612) 373-2048

SEP 11 Rec'd

UNIV. OF MINN.
HEALTH SCIENCE
PLANNING OFFICE

September 10, 1979

Paul J. Maupin
Health Sciences Planning Coordinator
University of Minnesota
4104 Powell Hall
Minneapolis, Minnesota 55455

Re: Unit B/C-Phase I

Dear Paul:

This is in response to your request of September 6, 1979.

As indicated in Mr. Blanchard's letter, testing and balancing of the air and hydronic systems is being performed by Mechanical Data on a contract initiated by this office.

I have discussed the need for a final report with Mr. Nelson of Mechanical Data. However, he reminded me that it has been difficult to finalize certain systems because of Phase II construction. Subsequent phased construction, (III, IV, and VI) stand to add further complications.

By copy of this memo, I am directing Bob Hudalla of my staff to review status of Phase I testing and balancing with Mechanical Data and resolve how a final report can be completed and submitted as required.

Very truly yours,


E. B. Merz
Assistant Supervising Engineer

EBM:aep

cc: Paul Kopietz
Bob Hudalla



ABBOTT-NORTHWESTERN HOSPITAL CORPORATION

September 13, 1979

SEP 11 Rec'd

Mr. Paul J. Maupin
Health Sciences Planning Office
4103 Powell Hall, Box 75
500 Essex Street, S.E.
Minneapolis, MN 55455

UNIV. OF MINN.
HEALTH SCIENCE
PLANNING OFFICE

Dear Paul:

Received your letter of September 6 concerning the radiation shielding protection measurements for the B/C Complex.

These measurements were made by me in February, 1979 and all of the rooms were in compliance. The Test Survey Reports are on file in the Physics Office of the Department of Radiology. I am presently no longer with the University and my replacement is Ron Droege, Ph.D., who is responsible for this information. As I indicated, the test results are in file in his office and he can be contacted at 373-8739. All rooms were in compliance and no additional shielding or construction modifications need to be made.

If you have any questions concerning this, feel free to contact me at 874-4060.

Sincerely,

J. Thomas Payne, Ph.D.
Certified Radiological Physicist

JTP:vma

cc: Ron Droege, Ph.D.
Box 292, Mayo
University of Minnesota Hospitals
Minneapolis, MN 55455



UNIVERSITY OF MINNESOTA
TWIN CITIES

Engineering and Construction Division
~~Physical Plant Operations~~ Physical Plant Operations
26 Folwell Hall
9 Pleasant Street S.E.
Minneapolis, Minnesota 55455



September 13, 1979

SEP 17 Rec'd

UNIV. OF MINN.
HEALTH SCIENCE
PLANNING OFFICE

TO: Paul Maupin
FROM: Dave Kerkow *DBK*
RE: Unit B/C - Phase I
July 18, 1979 Federal Inspection

The items you have highlighted in your memo of September 6, 1979 and attachments are supervision of construction responsibilities.

Whatever was required to be tested by the Contractor under the specifications would have been supervised and reported to Wally Mellum if it fell under the electrical contract.

Any response required should come from Wally and probably through Paul Kopietz. I have informed Paul of your memo.

If any assistance is required by Construction Supervision in order to respond, they will contact me.

DBK/sjh

cc: Paul Kopietz



UNIVERSITY OF MINNESOTA
TWIN CITIES

Health Sciences Planning Office
Physical Planning
4103 Powell Hall, Box 75
500 Essex Street S.E.
Minneapolis, Minnesota 55455
(612) 373-8981

October 11, 1979

TO: Joycene Maroney
FROM: Robert Swanson *RS*
SUBJECT: Phillips-Wangensteen Building
Unit B/C - Phase I
H.E.W. Facility Site Visit

Item 4b. Several Handicapped toilet stalls were designed with only one grab bar for the following reason:

During the contract document preparation of Building B/C - Phase I, the Hospital requested that several "Attendant" size Handicapped toilet stalls be provided in the Clinical Areas of the building; therefore, the architects, under the assumption that these stalls would be utilized by a patient with help of an attendant, provided one grab bar.

Item 5. The required signs "No Inhalation Gases Permitted" are in process. Mr. Coggins of the Surgery Department is funding this item through Dick Hendrick's Physical Plant Office.

- a. Ventilation air balancing report showing actual cfm vs. design cfm. This report shall not be submitted until reviewed and approved with signature by the design engineer.
 - b. Letter from the fire department that they have inspected and approved the fire alarm system.
 - c. Manufacturer's certification that the flame spread rating of the floor carpeting does not exceed 75.
 - d. Certified test approving the x-ray shielding by a radiologist or physicist.
 - e. Certified test of air tightness of all fume ducts per specifications.
 - f. Letter from the University of Minnesota certifying to a complete test of operations (including smoke dampers) of the smoke control system.
 - g. Certification that the "Rubatex" pipe insulation has a flame spread rating not exceeding 25, and a smoke developed rating not exceeding 150.
 - h. Test report on the equipotential grounding systems per NFPA No. 56A.
2. The insulation on fittings and equipment were noted to be wrapped with canvas, contrary to our review letters and HSAE's response. Please respond.
 3. Mark all filter manometers for the maximum static points for filter cleaning or changing.
 4. Handicap Toilet Rooms:
 - a. Have all tilt type mirrors permanently in tilt position rather than latched back to walls.
 - ~~*~~ b. There are several handicap toilet stalls noted to have only one wall-mounted grab bar, such as on the 12th and 3rd floors. Check all handicap toilet stalls.
 - c. Complete identification of all handicap toilet rooms.
 5. Eleventh floor Animal O.R.'s - these rooms are not equipped with isolated power or conductive flooring, therefore no inhalation gases are permitted. Post signs to this effect.
 6. The chute door on the 9th floor was lacking a latching device. Correct.



UNIVERSITY OF MINNESOTA
TWIN CITIES

Physical Plant Maintenance and Operations
200 Shops Building
319 15th Avenue S.E.
Minneapolis, Minnesota 55455

OCT 22 Rec'd

October 18, 1979

TO: P. J. Maupin, Coordinator, HSPO
FROM: R. H. Hendricks, Superintendent, HSPP
Subject: Unit BC, Phase I, federal inspection
of July 18, 1979

In response to H.E.W. report dated August 9, 1979:

Item 3

We have set all filter manometer maximum static pressure indicators at 0.45 inches of water per the manufacturer's recommendation.

Item 4a

University Hospital Engineers have been requested to set all handicap toilet mirrors in the tilt position since all of these facilities are in the hospital portions of the building.

Item 6

The contractor has replaced the missing trash chute latching mechanism in Rm. 9-210 (Rm. 9-095 architect number).

RHH:dai



UNIVERSITY OF MINNESOTA
TWIN CITIES

University Hospitals and Clinics
420 Delaware Street S.E.
Minneapolis, Minnesota 55455

OCT 22 Rec'd
UNIV. OF MINN.
HEALTH SCIENCE
PLANNING OFFICE

October 18, 1979

TO: Paul Maupin
FROM: Greg Hart
SUBJECT: Federal Inspection Response

In response to item number 9 of the July 18th Federal inspection of Unit B/C:

We will be installing redundant ground cables on all devices with conductive cases not presently having such cables, and will instruct operating personnel in the appropriate use of such grounding systems. Our Biomedical Engineering Department will be providing technical assistance in this regard.

I apologize for the lateness of this response. Should you need any further information, please advise.

GH/sjm

November 30, 1979

Mr. Pete Merz
University of Minnesota
9 Pleasant Street S. E.
88 Folwell Hall
Minneapolis, Minnesota 55455


Subject: Fume Hood Test Sheets
University of Minnesota
Health Science Expansion - Unit B/C - Phase I

Dear Mr. Merz:

Enclosed please find three (3) additional pages to the above subject report. These pages are to be inserted in Section 2 of 3: Air Distribution: Exhaust Air and Return Air.

As we had tested these fans so many times and attended numerous meetings regarding these fans, the paper work was separated from the rest of the report and we inadvertently turned in the report without the fume hood data.

Yours truly,



Donald W. Nelson

DWN:neb

EXHAUST FAN TEST

Job Name Health Science Expansion - Unit B/C - Phase I

FAN NO.	FE-1C	FE-2C	FE-3C	FE-6C	FE-7C	FE-8C
MFG. MODEL	Champion	Champion	Champion	Champion	Champion	Champion
MODEL NO.	20-TC G	20-TC G	20-TC G	20-TC F	20-TC G	20-TC G
MOTOR HP	3	3	3	2	3	3
VOLTAGE	480	480	480	480	480	480
AMP. RATING	4.0	4.0	4.0	2.8	4.0	4.0
ACTUAL AMP.	3.9/4.0/4.0	4.0/4.0/4.0	3.8/3.8/3.9	2.8/2.7/2.8	4.0/4.1/4.0	3.9/4.0/3.9
Velocity at Hood Face	132	116	101	115	110	111
REQUIRED SP	5.0	4.4	4.0	4.7	4.4	4.3
ACTUAL SP	5.4	5.1	4.4	6.9	6.3	4.38/+ .45
REQUIRED CFM	1,500	1,350	1,350	850	1,350	1,350
ACTUAL CFM	1,480	1,520	1,550	940	1,410	1,340
LOCATION	161-12th	161-12th	158-12th	156-basement	144-11th	144-11th
Fan RPM	2,750	2,770	2,735	2,760	2,720	2,710
Inlet CFM	1,480	1,396	1,410	863	1,350	1,390

NOTES:

EXHAUST FAN TEST

Job Name Health Science Expansion - Unit B/C - Phase I

FAN NO.	FE-9C	FE-4C	FE-5C	FE-10	FE-11	FE-12
MFG. MODEL	Champion	Champion	Champion	Champion	Champion	Champion
MODEL NO.	20-TC G	20-TC G	20-TC G	20-TC H	20-TC G	20-TB D
MOTOR HP	3	2	2	5	3	1
VOLTAGE	480	480	480	480	480	480
AMP. RATING	4.0	2.8	2.8	6.0	4.0	1.7
ACTUAL AMP.	3.8/3.9/3.9	2.7/2.6/2.7	2.6/2.5/2.5	5.6/5.8/5.8	3.7/3.8/3.8	1.5/1.7/1.6
Velocity at Hood Face	115	125	130	105	130	115
REQUIRED SP	5.0	5.9	5.0	6.2	6.4	5.2
ACTUAL SP	5.4	7.4	6.1	8.9	7.0	5.5
REQUIRED CFM	1,500	850	600	1,500	1,125	350
ACTUAL CFM	1,510	880	680	1,300	1,190	340
LOCATION	158-12th	123 Mezz.	Basement	---	383 1st W.	122 Mezz.
Fan RPM	2,730	2,730	2,750	2,740	2,650	2,150
Inlet CFM	1,390	820	610	1,110	1,060	325


NOTES:

EXHAUST FAN TEST

Job Name Health Science Expansion - Unit B/C - Phase I

FAN NO.	FE-13					
MFG. MODEL	Champion					
MODEL NO.	20-TB D					
MOTOR HP	1					
VOLTAGE	480					
AMP. RATING	1.7					
ACTUAL AMP.	1.5/1.7/1.6					
ACTUAL RPM	2,315					
REQUIRED SP	3.2					
ACTUAL SP	5.27					
REQUIRED CFM	350					
ACTUAL CFM	405					
Inlet CFM	360					
Velocity at Hood Face	110					

NOTES:



UNIVERSITY OF MINNESOTA
TWIN CITIES

Department of Radiology
Medical School
Box 292 Mayo Memorial Building
420 Delaware Street S.E.
Minneapolis, Minnesota 55455

December 4, 1979

Wally Mellum
Health Sciences Expansion
Construction Office
611 Delaware Street
Minneapolis, Minnesota 55415



Dear Wally,

Enclosed is a copy of a letter from J. Thomas Payne to Mr. Paul Maupin of the Health Sciences Planning Office. The letter states that the required measurements have been performed and that no additional shielding or construction modifications need to be made. I have verified that the Test Survey Reports referred to in that letter are in my office for the following rooms: 1-266, 1-267, 1-269, 1-271, 1-272 (all in the B/C complex).

Sincerely,

Ronald T. Droege
Ronald T. Droege, Ph.D.
Assistant Professor
Department of Radiology
University of Minnesota Hospitals

RTD/sjm
Enclosure



ABBOTT-NORTHWESTERN HOSPITAL CORPORATION

September 13, 1979

Mr. Paul J. Maupin
Health Sciences Planning Office
4103 Powell Hall, Box 75
500 Essex Street, S.E.
Minneapolis, MN 55455

Dear Paul:

Received your letter of September 6 concerning the radiation shielding protection measurements for the B/C Complex.

These measurements were made by me in February, 1979 and all of the rooms were in compliance. The Test Survey Reports are on file in the Physics Office of the Department of Radiology. I am presently no longer with the University and my replacement is Ron Droege, Ph.D., who is responsible for this information. As I indicated, the test results are in file in his office and he can be contacted at 373-8739. All rooms were in compliance and no additional shielding or construction modifications need to be made.

If you have any questions concerning this, feel free to contact me at 874-4060.

Sincerely,

J. Thomas Payne, Ph.D.
Certified Radiological Physicist

JIP:vma

cc: Ron Droege, Ph.D.
Box 292, Mayo
University of Minnesota Hospitals
Minneapolis, MN 55455



UNIVERSITY OF MINNESOTA
TWIN CITIES

Health Sciences Expansion
Construction Office
611 Delaware Street S.E.
Minneapolis, Minnesota 55414


December 14, 1979

TO: Paul Kopietz

FROM: Wally Mellum, Electrical Construction Superintendent

Per your request find commitments which I hope will satisfy certification requests as stated in H.E.W. letter to Paul Maupin dated 18, July 1979 covering Items 1.d. 1. f. and 1. h.

Please call if further details needed.



UNIVERSITY OF MINNESOTA
TWIN CITIES

Health Sciences Expansion
Construction Office
611 Delaware Street S.E.
Minneapolis, Minnesota 55414

December 14, 1979

TO: The Files, Unit B/C, Health Sciences Expansion

WMM
FROM: Wally Mellum, Electrical Construction Superintendent


SUBJECT: Specification Division 16
Section 16900 Fire Management and Environmental
Control System

RE: Complete test of system. Alarm, Smoke Control and
Smoke Removal for Phase I and II

All initiating devices and control systems have been checked
and found to function as intended. The following devices
and systems are included:

- A. (274) Alarm initiating devices each initiate common
and/or specific sequence of operations as dictated
by assigned Event Initiated Programs (EIP's).
- B. (24) Air-handling systems - "Smoke Control Modes"
assigned to systems"
- C. (43) Area smoke dampers - dampers controlling supply
air to a section of a floor -
- D. (1) Damper associated with the air relief shaft
serving Unit "A".

UNIV. OF MINN. B/C
HONEYWELL JOB #914-76042



SMOKE DAMPER SCHEDULE (43)




ADDRESS	DUCT CODE	FLOOR	LOCATION
4.07.04	S3CB-1	BSMT	FAN S3C DISCHARGE
2.15.01	S8C1-6	1	RM 1-339
2.15.02	S8C1-7	1	RM 1-333
2.15.03	S6C1-8	1	RM 1-293
2.15.04	S7C1-1	1	RM 1-289
4.12.04	S5C1-2	1	RMS 1-124 & 1-116
4.15.04	S5C1-1	1	RM 1-203 & EAST OF 1-165
4.17.04	S4C1-3	1	RMS 1-161 & 1-154
4.19.03	S2C1-5	1	RM 1-460 SO. OF 1-460B
2.22.02	S6C2-5	2	WEST OF 2-200D
2.22.03	S7C2-6	2	EAST OF 2-200D
2.22.04	S8C2-6	2	RM 2-337
4.22.04	S2C2-4	2	EAST OF CORE 33
4.26.04	S5C2-1	2	NORTH OF 2-197
4.27.01	S4C2-1	2	NORTH OF 2-199
4.27.02	S4C2-2	2	EAST & WEST OF 2-199
2.33.01	S7C3-3	3	RM 3-166
2.33.02	S6C3-2	3	WEST OF 3-164
4.33.03	S2C3-1	3	RM 3-116
4.33.04	S4C3-1	3	N.W. EXIT
4.44.01	S6C4-2	4	WEST OF RM 4-240E
4.44.02	S4C4-1	4	EAST OF RM 4-217
4.44.03	S2C4-1	4	RM 4-124
4.52.04	S2C5-2	5	EAST OF RM 5-122
4.53.01	S4C5-2	5	EAST OF RM 5-217
2.61.04	S17C6-3	6	RM 6-248A
2.62.01	S16C6-2	6	CORR. WEST OF RM 6-246A
4.62.02	S13C6-1	6	CORR. AT RM 6-219
2.81.03	S17C8-5	8	EAST OF CORE
5.83.02	S16C8-4	8	WAITING RM WEST OF RM 8-172
5.83.03	S17C8-3	8	RM 8-118
5.83.04	S13C8-3	8	CORR. EAST OF RM 8-300A
2.91.02	S16C9-4	9	WEST OF RM 9-170
2.91.03	S17C9-5	9	RM 9-172
5.93.04	S17C9-3	9	RM 9-126
5.94.01	S13C9-3	9	LINK CORR. AT RM 9-300A
5.94.04	S16C9-2	9	CORE 26
3.10.04	S15C11-3	11	RM 11-142
5.13.03	S13C11-2	11	WEST LINK CORR. AT RM 11-201
5.13.04	S14C11-1	11	EAST LINK CORR. AT RM 11-176



UNIVERSITY OF MINNESOTA
TWIN CITIES

Engineering and Construction Division
~~Physical Planning Office~~ Physical Plant Operations
26 Folwell Hall
9 Pleasant Street S.E.
Minneapolis, Minnesota 55455

January 9, 1980

TO: Paul J. Maupin
FROM: Victor E. Scott 
RE: Unit B/C Phase I - Federal Inspection Items

Pursuant to your letter request to Mr. Paul E. Kopietz dated October 11, 1979, regarding items enumerated in the Federal Inspection letter underlined in red, the following information is furnished:

1. One copy of the Testing and Balancing report, in three volumes.
2. Two copies of the letter from the City of Minneapolis Fire Marshall attesting that he has approved the fire management system.
3. Two copies of the approval in connection with the x-ray shielding.
4. Two copies of the certified tests for all the fume ducts.
5. Two copies of the testing of the smoke control systems.
6. Two copies of the test report on equipotential grounding systems.

If there is any additional information you may require, please let us know.

VES/amf

cc: Paul E. Kopietz



DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE

REGION V

300 SOUTH WACKER DRIVE
CHICAGO, ILLINOIS 60606

OFFICE OF THE
PRINCIPAL REGIONAL OFFICIAL

March 28, 1980

Our Reference: Min - 18(HP)
Health Science Expansion B/C
University of Minnesota
Minneapolis, Minnesota

APR 7 1980

UNIVERSITY OF MINNESOTA
HEALTH SCIENCES PLANNING

Mr. Paul Maupin
Health Sciences Planning Coordinator
University of Minnesota
4104 Powell Hall
Minneapolis, Minnesota 55455

Dea

Dear Mr. Maupin:


Thank you for your letter of February 19, 1980 responding to our final inspection report of August 9, 1979. We have several comments on the materials you have submitted, using the like-numbers of our inspection report.

- 1a. There are a number of deficiencies noted by Mechanical Data Corporation in their two volumes of air balance analysis report. Our comment in our final inspection report requested that the air balancing report be reviewed and approved with signature by the design engineer, who is to accept or act on the deficiencies noted by Mechanical Data Corporation. The design engineer from his calculations must determine if the actual environmental condition that was established, is approved relative to the design environmental condition.
- 1e. Respond to our comment.
- 1h. The final results of 20 millivolts between any two conductive surface is in excess of the requirement of a maximum 5 millivolts in accordance with paragraph 3351, NFPA No. 56A, 1973 and paragraph 517-51(b)(1), NFPA No. 70, 1971.
2. Respond to our comment.
7. Respond to our comment.
12. Our comment apparently was misunderstood. It is not desirable to have the manual pull stations activate the smoke control system because a manual pull station not located in the fire zone can wrongly negate

Page 2-Paul Maupin

a zone adjacent to a fire zone and cause smoke and fire to easily spread to that zone. If this is the case, it may be very simple to rewire the pull stations to only activate the fire alarm. Only the automatic alarm initiating devices, which can only be activated by smoke and/or fire shall cause negatizing of a smoke zone. Please respond.

Sincerely,

A handwritten signature in cursive script that reads "Daniel Jacobs".

Daniel Jacobs, P. E.
Acting Chief, Design and Engineering
Division of Regional Operations for
Facilities Engineering
and Construction

DEPARTMENT OF HEALTH & HUMAN SERVICES

NEW Final Inspection
Office of the Principal Unit &c
Regional Official

Region V
300 S. Wacker Drive
Chicago, IL 60606

DEC 3 1981



Our Reference: Minn.-18(HP)
Health Science Expansion B/C
University of Minnesota
Minneapolis, Minnesota

Mr. Paul Maupin
Health Sciences Planning Coordinator
University of Minnesota
4104 Powell Hall
Minneapolis, Minnesota 55455

Dear Mr. Maupin:

As of this date we have not received a reply to our letter of March 28, 1980 regarding the items still outstanding from our final inspection report of August 9, 1979. In order for us to proceed to close this project out we need a satisfactory answer to all items listed in the final inspection report.

Final grant funds cannot be recommended for disbursement until the outstanding items are corrected and all costs are submitted for our review.

Inquiry relative to comments contained herein may be directed to Thomas J. O'Shea, P.E. at this address, or by telephone on 312/886-5516.

Sincerely,

Richard A. Polinski, P.E.
Chief, Design and Engineering Branch
Regional Operations for Facilities
Engineering and Construction

inspec
J.O.M.L.
Niche Ball
Unit-F.



UNIVERSITY OF MINNESOTA
TWIN CITIES

Health Sciences Planning Office
Physical Planning
Health Sciences Complex
Box 726 Mayo Memorial Building
Minneapolis, Minnesota 55455
(612) 373-8981

PF

December 14, 1981

Richard A. Polinski, P.E.
Chief, Design and Engineering Branch
Regional Operations for Facilities
Engineering and Construction
Region V
300 S. Wacker Drive
Chicago, Ill. 60606

Reference: Minn-(18)
Health Sciences Expansion Unit B/C
University of Minnesota
Minneapolis, Minnesota

Dear Mr. Polinski:

Attached please find the cover letter sent to Mr. George Winter responding to the outstanding items from your final inspection report of August 9, 1979. As you will note, we have submitted information regarding all inquiries and to date have not received any indication that additional information is required. Please check with Mr. Winter regarding this matter.

Additionally, we would appreciate your scheduling final inspections on the following projects:

Jackson/Owre/Millard/Lyon Complex	Minn-HP-05C-070
Unit F Pharmacy/Nursing	Minn-HP-5C-63 and Minn-NU-5C-77
Diehl Hall Remodeling Project	Minn-HP-18-A


It would be most beneficial to the University to have these inspections done sometime late February or early March.

Very truly yours,


Paul J. Maupin
Health Sciences Planning Coordinator

cc: Thomas J. O'Shea
Vic Scott

May 13, 1981



Mr. George L. Winter, P.E.
Design and Engineering
Division of Regional Operations
for Facilities Engineering &
Construction
Department of Health and Human Services
16th Floor
300 South Wacker Drive
Chicago, Illinois 60606

RE: Minn-18(HP)
Health Sciences Expansion B/C
University of Minnesota
Minneapolis, Minnesota

Dear Mr. Winter:

In response to your letter dated March 28, 1980, regarding your final inspection report of the above referenced project, the following information is furnished:

1. Certification of the design engineer in connection with the Mechanical Data Corporation air balance analysis report. The reports you have in your office. We are also sending at this time, their comments and our course of action to make the necessary corrective measures requested, which are in progress as of this time. This should cover items 1a and 1e of your letter.
2. Item 1h, a copy of a memo to Mr. Dave Kerkow dated January 22, 1981 in regards to testing of the equipotential grounding systems.
3. Item 2, Thermal Insulation information in regards to fittings and equipment covering used on the project. Letter from E & S Insulation Co. is furnished, dated March 30, 1981.
4. Item 7, All necessary action requested for the temporary hold-open devices on fire dampers have been completed.

Page 2

Mr. George L. Winter, P.E.

May 13, 1981

5. Item 12, correspondence and responses to this item are forwarded for your review as furnished by Mr. Bob Swanson, Asst. Health Science Planning Corrdinator, dated April 14, 1981.

If there is any additional information you may require, please notify this office.

Very truly yours,

V.E.Scott

Federal Projects Coordinator

VES/gtm