


**IRON ORE COOPERATIVE RESEARCH
01/01/98 - 06/30/00**

**PROCESS MODELING OF
PELLET INDURATION FURNACES**

COLERAINE MINERALS RESEARCH LABORATORY

July 13, 2000

By 
Dr. R. A. Davis
UMD Chemical Engineering

By 
D. L. Englund
UMD/NRRI/CMRL

Approved by 
R. L. Wiegel
Director - CMRL

Project #5698112
CMRL/TR-00-10
NRRI/TR-2000/32

University of Minnesota - Duluth
Natural Resources Research Institute
5013 Miller Trunk Highway
Duluth, Minnesota 55811

Submitted to:
Minnesota Dept. of Natural Resources
Division of Minerals

PROCESS MODELLING OF PELLET INDURATION FURNACES

Executive Summary

Section 1 Description of Minntac Line 6 and Meters

Section 2 Medusa: Material and Energy Balance Calculation

Section 3 Model Validation and Process Analysis

Section 4 Figures

Section 5 Appendices

The authors wish to acknowledge **Mr. Raymond Potts** for his contribution to this project. Ray was responsible for coordinating installation and calibration of the mass flow sensors, scheduling plant tests and collection of plant data. He also helped answer numerous questions regarding the cooler design as well as locating necessary information.

The authors and the Minnesota Department of Natural Resources also acknowledge the financial contribution of **Svedala Industries** in support of minerals research in Minnesota.

Executive Summary:

This report completes a two-year collaborative effort between Minntac, NRRI Coleraine Minerals Laboratory and UMD Chemical Engineering, aimed at modeling the Minntac Line 6 Grate-Kiln induration system. The goals of this research were twofold:

1. Develop numerical models of existing taconite induration operations.
2. Demonstrate application of these models for process analysis leading to improved process efficiency defined by increased productivity and reduced fuel costs.

We have shown through the combination of an overall mass and energy balance model (MEDUSA) with a computational fluid dynamics model (CFD Cooler), that induration furnace performance can be predicted. Furthermore, a range of cooler operating conditions has been simulated and used to predict optimum furnace performance. Furnace productivity is dependent on primary and secondary cooling fan flow settings, and we have defined an operating window that demonstrates this effect. Within this window, grate feed rate can vary by as much as 30 WLTPH depending on fan flows. Additionally it may be possible to increase Line 6 production by as much as 94,500 LTPY with the installation of a wall in the Line 6 cooler, if certain operating conditions can be met. This represents a 3% maximum production increase on an annual basis.

The techniques developed during this study can be used to evaluate a wide range of process variables, such as additional recoup ducts, increased fan capacities, cooler wall locations, installation of a ported kiln, and furnace firing cycles. With additional research, it may even be possible to adapt the operating window concept for prediction of product quality parameters. An extensive effort has been made to validate the models against a range of plant operating conditions. The synergism of combining the models provides a powerful tool for evaluating proposed furnace modifications.

This study demonstrates how the models can be used to evaluate the installation of an overbed dividing wall in the cooler. An overbed dividing wall will break the interaction between the 3A and 3B fans. This will permit the 3B fan to be placed under automatic control, allowing the cooler to operate consistently near its optimum. Currently, the 3B is operated in manual control to avoid interfering with 3A fan performance; under these conditions cooler flow may or may not be optimized in a consistent manner. Cooler performance should not be hindered by installation of the wall if waste gas fan flow is maximized. This requires a review of the current control philosophy. Plant production could increase by as much as 94,500 LTPY, if the wall is installed, waste gas fan maximized, and 3B fan placed under automatic control. The actual production increase depends on how far annual plant production, currently under manual control, deviates from the predicted optimum. This deviation has not been determined in this study, however, plant personnel should be able to estimate it from historical cooler fan operation.

The plant data collected for model validation was also analyzed on individual (test by test) and collective (test composite) basis. Several important observations emerged from the plant data:

1. The Line 6 process fans exhibited frequent, but not periodic, cycling throughout the test period. The frequency of the oscillations was sufficient to prevent the machine from achieving steady state conditions. If the furnace behavior exhibited during the 15 day test period was typical of plant operation, this line is seldom under stable operating conditions.

A direct consequence of this type of operation is lost production and higher than necessary fuel consumption. Product quality is most likely also affected, but these affects are more difficult to predict. The factors responsible for these oscillations need to be identified and corrected.

2. The Line 6 waste gas fan does not appear capable of keeping up with the preheat fans once they open up beyond 45% fan damper. When this condition occurs, the waste gas fan is operating at 100% fan damper, but drying zone overbed pressure increases above the set point. Under these conditions, the waste gas fan cannot exhaust air fast enough and productivity is limited as a result.
3. The control strategy for the waste gas fan should also be evaluated. There were periods of time when the waste gas fan operated between 60 and 80% damper and maintained the overbed pressure set point (approximately $-0.6 \text{ inH}_2\text{O}$). Because recoup flow is directly proportional to pressure drop between the furnace and cooler, these periods of lower fan flow represent lost energy recovery through the recoup system, which in turn limits productivity. Recoup flow should be maximized with maximum waste gas fan flow. An extended test (5-10 days) was recommended. In this test, the waste gas fan should be held at 90-100% damper, to determine the impact on Line 6 operation.

A summary of the steps required to accomplish the project goals follows. Four objectives were carried out to complete this project. They were:

1. Install mass flow meters on Minntac Line 6 and collect operating data to validate the models.
2. Develop and validate an overall material and energy balance model called MEDUSA.
3. Develop and validate a Computational Fluid Dynamics (CFD) model of the Line 6 cooler.
4. Perform an analysis of Line 6 using these models, and, if possible, propose operating changes.

The MEDUSA model is an overall mass and energy balance type model and is used to evaluate process changes in terms of the whole process. The MEDUSA model can be used independently of the CFD Cooler model, but it requires accurate estimates of process airflow. The Line 6 cooler as it now exists has no overbed dividing wall, which makes the estimation of cooler flow splits between the parallel flow duct (kiln), the recoup ducts, and the vent stack very difficult without extensive in-plant air flow surveys.

The CFD Cooler model is ideally suited to providing the individual duct flow information required by MEDUSA. Through the use of an experimental design, a series of cooler operating conditions were simulated, and then used to define predictive linear equations for gas flow and temperature in the cooler outlets. Four control variables were used to define these operating conditions. They were pellet ferrous iron content entering the cooler, pellet production rate, primary cooling (3A) fan mass flow, and secondary cooling (3B) fan mass flow. A cooler parametric series (27 simulations) was performed for each physical modification to the cooler.

Initially, a number of physical modifications were to be evaluated. They included a comparison of recoup B duct location between Line 6 and Line 7, a comparison of the current cooler (no overbed dividing wall) with a cooler including an overbed dividing wall (two locations evaluated), and the addition of a third recoup duct. Most of these comparisons were dropped when it became apparent that a separate series of simulations would be required for each option. Two complete series were performed simulating the current plant cooler and the cooler with an overbed dividing wall offset one wind box into the primary cooling zone.

Before the cooler simulation series could be performed, both models were validated. A series of plant tests was performed and used to tune the models over a wide range of plant operating conditions. The goal was to make sure both models successfully predicted trends in the plant data. An exact numerical value match was not required between plant and model.

When the validation phase was completed, two CFD Cooler parametric series were performed. The results were analyzed using statistical software. Information from the parametric series was correlated with linear equations that predict cooler flow and temperature responses to changes in operating conditions. Operating windows were defined to show acceptable 3A and 3B fan flow ranges. The windows were bounded on the low flow side by a maximum vent stack temperature and bounded on the high flow side by a maximum primary cooling overbed pressure, which can be related to firing hood pressure. The linear equations for cooler outlet conditions, specifically kiln secondary air flow and total recoup flow, were embedded in MEDUSA, to give it predictive cooler capability. This model is referred to as the hybrid MEDUSA/CFD.

A series of fan flow combinations was taken from the window and analyzed using the MEDUSA/CFD hybrid. This model was also modified to find the optimum feed rate based on the input cooling fan combinations and target preheat fan gas and kiln solids discharge temperatures. Fuel flow rate was held constant, but fuel consumption on BTU/LT basis varied with the optimized feed rate. The simulation results showed that plant productivity and fuel consumption were affected by cooler fan performance. For the current cooler, it was shown that feed to the grate could vary by as much as 30 WLTPH depending on the combination of fan flows. The operating window showed that there was an optimum combination of fan flows for maximum production and minimum fuel consumption.

A series of plant tests was conducted in February and March 2000, using the operating window defined by computer simulation as a guide to specify fan flows. The test conditions were intended to run the plant through the range of flows found in the window. Plant data was logged for each test and analyzed. A total of nine tests were conducted. These tests were composited into a single database, from which two plant data models were derived. One model used the same control variable criteria (feed rate, and cooling fan mass flows) as the CFD model, with the exception of pellet ferrous iron content, which was not measured in the plant. The second model used the MEDUSA/CFD control response criteria (3A and 3B mass flow). The plant models were then compared against the appropriate computer model, using a variety of response variables for comparison. In general, the trends exhibited in the plant data models agreed with the corresponding trends in the simulation based models.

1 Description of Minntac Line 6 and Meters

| <u>Page No</u> | <u>Text Heading</u> |
|----------------|-------------------------------------|
| 1.1 | 1.1 Line 6 |
| 1.1 | 1.2 Meters and Probes |
| 1.2 | 1.2.1 Thermal Sensing Meter |
| 1.3 | 1.2.2 Pressure Differential Meter |
| 1.4 | 1.3 Conclusions and Recommendations |

1.1 Line 6

Seven indurating lines have been constructed at Minntac for producing taconite pellets. Only five are operable at this time – lines 3 through 7. Line 6 was chosen for this modeling project because it is one of the two newest lines; construction was completed in 1978. All the lines at Minntac use Svedala grate-kiln systems for induration. The line 6 grate is 144 ft long and 15 ft wide. It is a two-pass, downdraft machine divided into three chambers above the grate and two windboxes beneath it. The sizes of the chambers are designated in eight ft long bays. The first section of the grate is the first stage downdraft drying section (DD1). It contains six active bays above the grate. The second section is the second stage of downdraft drying (DD2). It contains three active bays above the bed. There is a common windbox below the DD1 and DD2 furnaces consisting of nine bays total. The third section is the preheat section (PH). It contains seven active bays and has a dedicated windbox the same length. The kiln is 21 ft in diameter and 130 ft long. It can be fired with #2 fuel oil, coal or natural gas (preferred). Natural gas was used in all of the tests for this project. The cooler is an annular cooler with a mean diameter of 56 ft. Pallets are eight ft wide. The line has five process fans. There are two 900 HP cooling fans (labeled 3A and 3B), two 1500 HP preheat fans (labeled 1A and 1B), and one 3500 HP waste gas fan (labeled WG or #2 fan). A schematic of the furnace-kiln-cooler is shown in section 3, Figure 2.

Line 6 was originally constructed with a low temperature recoup system. In this system process gas was drawn from the second cooling stage of the cooler into the preheat fan cyclone system through two separate ducts – one for each preheat fan. Because of temperature restrictions on the preheat fans, the air had to be tempered with the addition of ambient air. It was later converted into a high temperature system by adding DD2. Process gas drawn from the cooler is now directed to the DD2 furnace without being tempered, permitting more efficient operation.

1.2 Meters and Probes

Mass flow meters were installed in seven process gas streams to provide real time process gas flow rate data. In addition, an extensive data logging system was developed that allowed up to 100 data points to be monitored during any time frame between 10 seconds and 24 hours. A maximum of 1500 readings could be collected. Data could be averaged within a selected time frame or an instantaneous value recorded. The data could be transferred to computer spreadsheets, such as Excel, for further manipulation.

All the meters used for this project utilized probes installed within the gas stream. They were installed in the following locations: The 3A fan inlet duct, the 3B fan outlet duct prior to the cooler, the cooler vent stack, the east (1B) recoup duct, the west (1A) recoup duct, the 1A fan inlet duct, the 1B fan inlet duct and the waste gas stack after the wet scrubber.

Originally, two different types of meters were used – thermal sensing (heat loss differential) and pressure differential. The thermal sensing meters were installed in all locations except for the recoup ducts where temperatures exceed the manufacturer's recommendations. Multiple-point pressure differential meters were installed in recoup ducts. Pressure differential meters require an air purge system to keep the probes clear of particulate buildup, which increases the cost of installation and operation of this type of meter relative to the thermal meters.

1.2.1 Thermal Sensing Meter

All probes in the thermal sensing meters were multi-point and self-averaging. All of them, including the one in the waste gas stack were constructed of 316 SS with a nickel braze. The manufacturer offered as an option, probes constructed of Hastelloy C. Consideration was given to purchasing this option for the waste gas meter because of the corrosive atmosphere within the stack. After reviewing the gas composition, it was believed the 316 SS would withstand the conditions within the stack and the decision was made to use it instead of the Hastelloy. After less than a month, the meter in the waste gas stack failed. The body of the probe was relatively undamaged and the failure occurred because thermal elements were badly corroded. It is unlikely the use of the Hastelloy C would have prevented this. The waste gas meter was replaced with a single point pressure differential meter. The pressure differential meter was found to be accurate and did not drift but the flow in the stack was stratified making it necessary to apply a factor to output values. In addition, the Line 6 waste gas stack was equipped a CEM system that was not part of this project. That system included an ultra sonic mass flow meter. Experience with the ultra sonic meter will also be discussed relative to accuracy and dependability later in this section.

Within the first year of operation, there appeared to be considerable drift in the remaining thermal meters. Some of this may have been due to the temperatures of the streams measured. Generally this type of meter is recommended for gas streams below certain temperatures. This temperature varies somewhat by manufacturer. The manufacturer of the meters used on line 6 indicated they could be used in streams up to 850°F. It was later learned that other sources indicate they should not be used in streams over 550°F. The meters were originally calibrated against pitot traverses done across the various ducts. After a year of operation all the thermal meters except the one installed in the 3A fan inlet duct had drifted considerably and differed from pitot traverses (calibration checks) by as much as 30%. It is probably not coincidental that the 3A duct meter performed better than the others since this is one of the coolest and cleanest streams measured.

Overall operating experience with the thermal sensing meters was poor. This is the first time thermal sensing mass flow meters have been used in process gas streams within a taconite indurating facility. Because of this, there was no experience to draw upon in selecting the meters other than the manufacturer's recommendations. Three different manufacturers supplied meters for this project. All three asked for and were given as much

information about the gas streams as was available. Two of the three suppliers appear to have overestimated the ability of their meters to withstand the conditions encountered.

All experience with the meters was not bad. Meter operating experience was obtained and, with the exception of the original waste gas meter, all the meters provided significant usable data. The thermal type meters performed well in the 3A and 3B ducts but not in the other applications where they had a tendency to drift. It was reported earlier that the 3B meter had drifted but a review of relevant data indicated it had been accurate for about 15 months before it started drifting. Good quality data was obtained during the entire project from the 3A meter. After it was determined that the 3B meter had drifted out of calibration, usable data was obtained by doing pitot traverses and applying factors to the meter's output. It appears thermal meters would work in other moderate to low temperature applications with routine calibration.

1.2.2 Pressure Differential Meter

The multi-point, pressure differential meters installed in the recoup ducts were very accurate but could not withstand the temperatures within the ducts. However, they remained very accurate up to the point when they failed and provided 15-18 months of accurate data.

The multi-point meters installed in the recoup ducts did not drift but failed because of the heat within the ducts. These meters were described by the manufacturer as "multi-point, self-averaging, Pitot Fechheimer airflow traverse probes with integral airflow direction correcting design". Two probes were installed in each duct – one vertically and one horizontally. They were constructed of Inconel 601 and were expected to withstand temperatures up to 1900°.

The output from the 1B recoup meter was lost after 15 months of operation. It was not possible to inspect the probes until the line was down for its annual repair several months after that. When the probes were inspected it was learned there was extensive heat damage (creep) to all four probes. No temperatures greater than 1750 °F were noted or recorded during the life of the probes within the 1B duct and temperatures were typically 200-300 degrees lower within the 1A duct. The CFD modeling indicated temperature stratification of about 200° within the ducts. Because of this, it is possible that temperatures greater than 1900° existed but were not detected in the 1B duct. However even with the 200° stratification, the temperature would not have exceeded 1650° in the 1A duct. It is most likely that the probes failed at temperatures that were within the expected range and less than 1900°. It should be noted that the manufacturer of these meters was different than the manufacturer of the thermal meters.

The single-point pressure differential meter installed in the waste gas stack was very dependable and did not drift. It was accurate at the measurement point but did not provide an accurate measurement for the entire gas stream because of stratification of the flow within the stack. The ultra sonic meter installed in the waste gas stack was also very dependable but subject to the same measurement problems as the pressure differential meter. Usable data was obtained from both meters by using multiple pitot traverses to develop factors to account for the stratification.

1.3 Conclusions and Recommendations

Future application of process gas measurement technology in this and other plants will benefit from the experience gained in this project. Because taconite processing plants like almost all plants are not built with measuring instrumentation in mind, obtaining the desired accuracy will always be a problem. Routine calibration will be necessary and frequent calibration will be necessary in some applications. In addition most of the gas streams are at elevated temperatures and contain abrasive taconite dust. Some streams also contain corrosive chemical species. Selection of meters for future projects must take these factors into account. Generally installation of probes within ducts should be avoided with two exceptions - cooling air which is cool and clean and in cases where accuracy is critical.

In selecting meters for future work, there are a number of viable options for the low temperature gas streams. Thermal meters would work well in clean ambient streams such as the cooling air but should be avoided for other applications (waste gas). Thermal meters are difficult to install (with probes placed within the stream) and depending upon location can be difficult to maintain. They also have a tendency to drift at intermediate temperatures. Single-point ultra sonic meters are not recommended for any application in taconite indurating facilities. However, ultra sonic meters can be purchased which will traverse entire ducts and this type would perform well in the low temperature streams. They would not be affected by the atmosphere (including the particulate material) within the stream and are easy to install. Multi-point pressure differential meters would also work on the low temperature streams. Because they do not drift like the thermal or ultra sonic type they are the most accurate but they are difficult to install and have slightly higher operating and installation costs.

For the intermediate temperature (400-1200°) gas streams such as those in the preheat fan ducting and cooler vent stacks the multi-point pressure differential meters would be the instruments of choice. They are the most accurate by far since both the thermal and ultra sonic types have a tendency to drift in these temperature ranges. They have the disadvantages of being difficult to install and needing to be routinely back flushed with compressed air. The presence of particulate material in the intermediate temperature streams makes back flushing the meters necessary but the experience during this project relative to plugging – with back flushing- was very positive. During the 15-18 months the recoup meters were operable, there were no instances of plugging recorded despite the fact, the recoup ducts on Line 6 are known to contain significant amounts of particulate material.

The recoup streams are the most difficult to measure. This project indicated there are three options for measuring temperature and flow in recoup streams: 1) Install probes constructed of Inconell 601 and replace them every 1-2 years, 2) Find an alloy that will handle higher temperatures (may be cost prohibitive), 3) Calculate recoup flows using CFD modeling. Depending upon the cost of alloys for probes, this may be the most promising but it's only applicable if the meters are used in conjunction with CFD modeling.

Despite all the problems with the meters, enough usable data were obtained to allow the completion of the other parts of the project. In many instances, it was also informative to know if the mass flow of a stream changed relative to other streams. This could be done even when the meters were out of calibration. In addition to the other parts of the project a lot of knowledge gained relative to the mass flows of gas streams within the line and the

nature of mass flow measurement in taconite indurating facilities. The ultimate value of all this has yet to be determined.

2 Medusa: Material and Energy Balance Calculations

| <u>Page No</u> | <u>Text Heading</u> | <u>Tables</u> | <u>Figures</u> |
|----------------|------------------------------------|---------------|----------------|
| 2-1 | 2.1 Introduction | | |
| 2-2 | 2.2 Zones | | 2.1-2.2 |
| 2-3 | 2.3 Mass Transfer | | |
| 2-3 | 2.3.1 Drying | | 2.3 |
| 2-5 | 2.3.2 Flux Calcination | | |
| 2-5 | 2.3.3 Magnetite Oxidation | | |
| 2-7 | 2.4 Heat Transfer Model | | |
| 2-7 | 2.4.1 Traveling Grate/Cooler Model | | 2.2 |
| 2-9 | 2.4.2 Rotary Kiln Model | | |
| 2-10 | 2.4.3 CFD Cooler Model | | |
| 2-11 | 2.4.4 Model Calibration | | |
| 2-11 | 2.5 Model Implementation | | |
| 2-12 | 2.5.1 Medusa.for | | 2.4 |
| 2-12 | 2.5.2 Medusa.exe | | |
| 2-12 | 2.5.3 Medusa.ctl | | |
| 2-12 | 2.5.4 Name.dat | | |
| 2-12 | 2.5.5 Name.fld or Name.met | | |
| 2-13 | 2.5.6 Medusa.rst | | |
| 2-13 | 2.6 Graphical User Interface | 2.1 | |
| 2-13 | 2.6.1 File Manager | | 2.5 |
| 2-14 | 2.6.2 Pellet Bed | | 2.6 |
| 2-14 | 2.6.3 Furnace Zones I & II | | 2.7-2.8 |
| 2-14 | 2.6.4 Rotary Kiln | | 2.9 |
| 2-15 | 2.6.5 Process Gas | | 2.10 |
| 2-15 | 2.6.6 Leakage | | 2.11 |
| 2-15 | 2.6.7 Gas Distribution | | 2.12 |
| 2-15 | 2.7 Results | 2.2 | 2.13-2.15 |
| 2-16 | 2.8 Summary | | |
| 2-16 | 2.9 Nomenclature | | |
| 2-18 | 2.9 References | | |

2.1 Introduction

A mathematical model of heat and mass transfer in the grate-kiln induration furnace was developed to explore the effects of process changes on the overall performance of the machine. The model was implemented in a FORTRAN program entitled Medusa. The furnace model was developed as a series of zones arranged according to the solid flow and process gas distribution. In the model, solids move sequentially through the zones from the feed end of the machine where pellets are initially dried, to the cooler where fired pellets are cooled and thermal energy is recouped by the process gas. The mechanisms for heat transfer include: convection between the process gases and solid surfaces, such as pellets and walls; conduction within the pellet bed and walls; radiation exchange between gas and exposed solid surfaces; and fuel combustion, calcinations and magnetite oxidation heat generation or consumption. The net radiation method was used in the kiln. Mass transfer mechanisms included: evaporation and condensation of moisture in the pellets; flux decomposition and carbon dioxide evolution; and magnetite oxidation. The furnace model was built around the following assumptions:

1. Steady-state operation
2. Two dimensional profiles in bed length and depth; ignores changes in bed width.
3. Fueled by natural gas.
4. No solids mixing on grate or cooler.
5. First-order mixing of solids in rotary kiln zone.
6. Perfect gas phase mixing in each grate or cooler zone above and below the bed of solids.
7. No gas mixing within the bed of solids in grate or cooler zones.
8. Gas flow distribution is known a priori.
9. Individual pellets are isothermal.

2.2 Zones

A zone is defined as a section of the furnace model where the process gases are considered well mixed, or homogeneous in temperature and composition. A zone may be configured with any combination of process gas entering from other zones as well as air from outside the furnace or leakage to the zone (no leakage is permitted from a zone to the surroundings). Leakage is also permitted between adjacent zones; above or below the bed on the grate. The process gas leaving a zone may be distributed to any other zone in the model. The furnace modeled for this project may be divided into seven zones in the following order, as illustrated in Figure 2.1: first and second drying stages, preheat stage, kiln, and three cooling stages. Air is used in the annular cooler to lower the pellet bed temperature. Air supplied to the first cooler zone leaves as secondary air to the kiln. The air from the second cooler zone is transferred to the second stage dryer where the thermal energy is recouped to drive the moisture from the green balls at the front end of the machine. Finally, the air from the third cooler zone is vented. The process gas leaving the preheat zone is routed to the second stage drying zone for additional heat recovery. The air leaving the two drying zones

is vented as waste gas. Leakage to the zones was added above bed on the grate and below bed in the preheat zone.

The solid bed traveling on the grate or annular cooler is modeled as horizontal layers of well-mixed solids, as illustrated in Figure 2.2. The composition and temperature of a solid layer is considered to be locally uniform, changing only in the flow direction due to heat transfer and chemical reaction with the gas phase. It was determined by trial-and-error that 20 layers provided satisfactory results.

The Minntac cooler was difficult to model using the Medusa assumptions because there are no physical structures separating the three hypothetical cooler zones. The annular shape of the cooler was mapped to two-dimensional space by using an average bed diameter to calculate the average pellet residence time in the cooler. The length of each cooler zone was estimated by comparing the measured pressure drop across the bed to the predicted pressure drop using the Ergun equation for pressure drop in porous media:

$$\frac{\Delta P}{L_b} = \frac{1.75 \rho_g u_g^2}{d_p} \left(\frac{1 - \epsilon_b}{\epsilon_b^3} \right) + \frac{150 \mu_g u_g (1 - \epsilon_b)^2}{d_p^2 \epsilon_b^3} \quad (2.1)$$

where L_b is the bed depth, ρ_g is the gas density, u_g is the superficial gas velocity, d_p is the average pellet diameter, ϵ_b is the bed porosity, and μ_g is the gas viscosity. Given a pressure drop across the bed, gas volumetric flow rate, bed width, and bed depth, Equation (2.1) was solved for the length indirectly from the superficial gas velocity:

$$z_c = V_g / u_g w_c \quad (2.2)$$

where z_c is the length of the cooler zone, V_g is the volumetric flow rate of the gas through the cooler zone, and w_c is the width of the cooler zone.

This approach for estimating a cooler zone length provided reasonable results for the machine under a specific set of operating conditions. However, the relative lengths of each zone would need to be adjusted for each new set of flow conditions. A computational fluid dynamic (CFD) model of the cooler avoids this problem by allowing the gases to mix and distribute according to the operating conditions. A model of the cooler using CFD is discussed in under the section entitled, CFD Cooler Model.

2.3 Mass Transfer Models

The mathematical models for mass transfer and reaction in the pellet bed are described here. The models includes drying, flux decomposition, and magnetite oxidation. All of the models assume homogeneous, isothermal pellets. Only the magnetite oxidation model accounts for changes in the composition of magnetite in the radial coordinate direction of the pellet.

2.3.1 Drying

Green balls are dried by contact with heated air in the first two stages of the furnace. The model for drying includes a warming period, followed by a constant drying period. Chemically bound water is ignored in this model. During the warming period, the moist pellets are heated to the boiling temperature of water. The rate of evaporation was modeled

in terms of convection mass transfer of water vapor from the pellet surface to the under-saturated air:

$$\frac{dX_w}{dz} = \frac{k_w a A_l M_w (C_{we} - C_{w,b})}{m_{sl}} \quad (2.3)$$

where X_w is the mass fraction of water in the pellet, z is the length dimension in the direction of the traveling grate, C_{wb} is the bulk gas phase water concentration, and m_{sl} is the mass flow rate of the solids layer, A_l is the cross sectional area of the bed layer, M_w is the molecular weight of water, a is the pellet surface area per unit bed volume:

$$a = \frac{6(1 - \varepsilon_b)}{d_p} \quad (2.4)$$

C_{we} is the equilibrium gas phase concentration of water, calculated assuming Raoult's law:

$$y_w = P_w^v / P_T \quad (2.5)$$

$$C_{we} = y_{we} P / R_g T \quad (2.6)$$

where y_w is the mole fraction of water in the gas phase, P_T is the total pressure of the gas phase (assumed 1 atm), and P_w^v is the vapor pressure of water. The vapor pressure was calculated from an Antoine correlation for pure water vapor pressure (Reid, et al, 1987). The mass transfer coefficient, k_g , was calculated from the dimensionless correlation for fluid in a packed bed of spheres (Seader and Henley, 1998):

$$\frac{k_g d_p}{D_g} = 2.0 + 1.1 \left(\frac{u_g d_p}{\nu_g} \right)^{0.6} \left(\frac{\nu_g}{D_g} \right)^{1/3} \quad (2.7)$$

where d_p is the average pellet diameter, D_g is the diffusivity of water in the gas phase, u_g is the superficial gas velocity (calculated assuming a bed voidage of one), and ν_g is the kinematic viscosity of the gas. The viscosity was approximated from the Chapman-Enskog theory for gas mixtures as described by Reid, et al (1987). The diffusivity of the water in air was correlated from the data in Mills (p. 947; 1999):

$$\begin{aligned} D_{w-air} / (m^2/s) &= 1.87 \times 10^{-10} (T/K)^{2.072}; 280 < T < 450K \\ D_{w-air} / (m^2/s) &= 2.75 \times 10^{-9} (T/K)^{1.632}; 450 < T < 1070K \end{aligned} \quad (2.8)$$

During the constant rate period, the rate of moisture evaporation from a pellet was modeled in terms of the rate of heat transfer to the pellet:

$$\frac{dX_w}{dz} = - \frac{q'_s}{\lambda_w m_{sl}} \quad (2.9)$$


where q'_s is the heat transfer rate to the solid bed per unit length and λ_w is the latent heat of water vaporization. The same equations apply under conditions of condensation. The heat consumed by evaporation was calculated as

$$q_v' = \lambda_w m_{sl} \frac{dX_w}{dz} \quad (2.10)$$

A flow chart for the drying algorithm is shown in Figure 2.3.

2.3.2 Flux Calcination

The flux was assumed to be a mixture of calcium carbonate (75 wt%) and magnesium carbonate (25 wt%). The flux decomposition reaction was assumed to be irreversible. The reaction expression is



The kinetics of flux calcination was modeled assuming homogeneous, isothermal pellets. The rate of flux decomposition is first order with respect to the mass fraction of flux:

$$\frac{dX_f}{dz} = \frac{-k_f X_f}{u_s} \quad (2.12)$$

where X_f is the mass fraction of flux in the solid bed, u_s is the linear bed velocity, and k_f is the flux decomposition reaction rate constant. The reaction rate constants for flux decomposition are as follows (Thurlby, 1988):

$$k_{Mg}/s^{-1} = 2.50 \times 10^5 \exp\left(-\frac{1.12 \times 10^4}{T/K}\right) \quad (2.13)$$

$$k_{Ca}/s^{-1} = 8.30 \times 10^6 \exp\left(-\frac{1.83 \times 10^4}{T/K}\right) \quad (2.14)$$

Since the activation energy for magnesium carbonate is smaller, this compound is consumed first, followed by the decomposition of calcium carbonate.

The rate of carbon dioxide production was used in the gas phase material balance:

$$F_{CO_2} = \frac{2m_{sl}}{M_f} \frac{dX_f}{dz} \quad (2.15)$$

where M_f is the molecular weight of flux. The calcination reaction is endothermic. The rate of heat consumption by this reaction is

$$q_f' = \Delta H_f m_{sl} \frac{dX_f}{dz} \quad (2.16)$$

where ΔH_f is the endothermic heat of flux decomposition.

2.3.3 Magnetite Oxidation

The magnetite oxidation reaction expression is



The shrinking core model (SCM) was used to adequately describe the kinetics of magnetite oxidation. SCM assumes that the reaction proceeds topochemically from the outside in along a sharp reaction front to the center of the pellet. The model also assumes homogeneous, isothermal pellets. The overall rate of reaction is a function of convective mass transfer of oxygen from the bulk air to the pellet surface, diffusion through an ash layer of hematite surrounding the unreacted magnetite core, and surface reaction at the interface between the ash layer and core.

$$\frac{dr_c}{dz} = \frac{-4(C_{O_2b} - C_{O_2e})}{u_s \rho_c \left[\frac{1}{k_{ox}} + \frac{r_c}{D_e} \left(1 - \frac{r_c}{r_p} \right) + \frac{1}{k_g} \left(\frac{r_c}{r_p} \right)^2 \right]} \quad (2.18)$$

where r_c is the unreacted core radius, r_p is the pellet radius, C_{O_2b} is the bulk gas oxygen concentration, r_c is the molar density of the magnetite core, C_{O_2e} is the equilibrium gas oxygen concentration, and k_g is the convective mass transfer coefficient, calculated from the dimensionless correlation in Equation (2.7) for O_2 in air. The equilibrium partial pressure of oxygen with magnetite and hematite is calculated from the following expression for the change in the free energy of the reaction (Gaskell, D.R., 1981):

$$\Delta G^\circ / (J/mol) = -RT \ln \left[\frac{1}{(P_{O_2} / atm)} \right] = -472900 + 272.68(T/K) \quad (2.19)$$

where P_{O_2} is the partial pressure of O_2 in the gas. Rearrangement of Equation (2.19) for P_{O_2} gives

$$P_{O_2e} / atm = \exp \left[32.794 - \frac{56873}{T/K} \right] \quad (2.20)$$

The equilibrium concentration was calculated assuming ideal gas behavior:

$$C_{O_2e} = P_{O_2e} / R_g T \quad (2.21)$$

The Arrhenius expression for the forward reaction rate constant, k_{ox} , for magnetite oxidation used in this work is (Thurlby, 1988):

$$k_{ox} / (m/s) = 1.16 \times 10^8 (T/K) \exp \left(-\frac{1.983 \times 10^4}{T/K} \right) \quad (2.22)$$

The diffusivity of oxygen in air was correlated from the data in Mills (1999):

$$D_{O_2} / (m^2/s) = 1.535 \times 10^{-9} (T/K)^{1.665} \quad (2.23)$$

The effective diffusivity was calculated as follows.

$$D_e = D_{O_2} \varepsilon_p / \tau_p \quad (2.24)$$

where ε_p is the porosity of the pellet and τ_p is the tortuosity of the pore structure of the pellet. The tortuosity was correlated from the data of Papanastassiou and Bitsianes (1973):

$$\tau_p = 1 + 0.2538 \left(\frac{1 - \varepsilon_p}{\varepsilon_p} \right) + 0.2213 \left(\frac{1 - \varepsilon_p}{\varepsilon_p} \right)^2 \quad (2.25)$$

This correlation has the features that $\tau \rightarrow 1$ as $\varepsilon_p \rightarrow 1$ and $\tau \rightarrow \infty$ as $\varepsilon_p \rightarrow 0$. Also, for randomly packed uniform spheres, $\varepsilon_p \cong 0.38$, $\tau \cong 2.0$.

The mass fraction of magnetite was related to the core radius as follows.

$$\frac{dX_m}{dz} = \frac{3X_{mi}}{r_p} \left(\frac{r_c}{r_p} \right)^2 \frac{dr_c}{dz} \quad (2.26)$$

where X_m is the mass fraction of magnetite in the green ball and X_{mi} is the initial mass fraction of magnetite. The conversion of magnetite was calculated as follows.

$$x_m = 1 - \left(\frac{r_c}{r_p} \right)^3 \quad (2.27)$$

The rate of oxygen consumption by reaction with magnetite was used in the material balance for the gas phase:

$$F_{O_2} = \frac{m_{sl}}{4M_m} \frac{dX_m}{dz} \quad (2.28)$$

where M_m is the molecular weight of magnetite. The oxidation reaction is exothermic. The heat generation rate per unit length is a function of the change in the magnetite core radius:

$$q'_{ox} = \frac{m_{sl} \Delta H_{ox}}{4M_m} \frac{dX_m}{dz} \quad (2.29)$$

where ΔH_{ox} is the heat of oxidation reaction per mole of O_2 reacted.

2.4 Heat Transfer Model

The mathematical models for heat transfer on the grate, in the kiln, and cooler are described here. Pellets are assumed to be isothermal. The grate and cooler models are identical. The results from the CFD simulations were incorporated into the overall Medusa model by replacing the original calls to the grate code with least-squares regressions of the CFD data for cooler gas flow and temperature as functions of the kiln solids discharge conditions and the gas feed to the cooler.

2.4.1 Traveling Grate/Cooler Model

The bed of solid pellets traveling on the grate or cooler was modeled as a system of discrete layers as illustrated in Figure 2.2. The temperature of the solids was assumed to be locally uniform in each layer. These assumptions permit the change in the gas temperature calculation:

$$T_{go} = T_s + (T_{gi} - T_s) \exp\left(\frac{-haA_l}{F'_g \bar{c}_{pg}}\right) \quad (2.30)$$

where T_{go} is the temperature of the gas exiting the bed layer, T_{gi} is the temperature of the gas entering the bed layer, T_s is the average temperature of the solids layer F'_g is the molar flow rate of gas per unit length, and \bar{c}_{pg} is the average heat capacity of the gas in the solid layer. The heat transfer coefficient is calculated from the dimensionless correlation:

$$\frac{hd_p}{\kappa_g} = 2.0 + 1.1 \left(\frac{u_g d_p}{\nu_g}\right)^{0.6} \left(\frac{\nu_g \bar{c}_{pg}}{\kappa_g}\right)^{1/3} \quad (2.31)$$

where κ_g is the gas thermal conductivity. Correlations of the thermal conductivity of the process gases available from Reid, et al (1987) are used in Medusa.

The heat transfer rate per unit length between the gas and solids is calculated from an energy balance:

$$q'_{gs} = F'_g \bar{c}_{pg} (T_{gi} - T_{go}) \quad (2.32)$$

The energy balance for the solids in each layer is

$$m_{sl} c_{ps} \frac{dT_s}{dz} = q'_{gs} + q'_v + q'_f + q'_{ox} \quad (2.33)$$

where q' is the heat transfer rate per unit length. The subscripts gs, v, f, ox refer to heat transfer between the gas and solids, heat of vaporization, heat of flux decomposition, and heat of magnetite oxidation, respectively. The model of the rectangular bed consists of an equation similar to Equation (2.33) for each layer of the bed. The model for the solids flow resulted in a system of 20 coupled non-linear, first-order, ordinary differential equations for each bed layer in each grate/cooler type zone.

The specific heat of the solids was calculated as a weighted average of the composition:

$$c_{ps} / (J/kg \cdot K) = \frac{X_c c_{pc}}{M_c} + \frac{X_f c_{pf}}{M_f} + \frac{X_h c_{ph}}{M_h} + \frac{X_m c_{pm}}{M_m} + \frac{X_w c_{pw}}{M_w} + \frac{X_i c_{pi}}{M_i} \quad (2.34)$$

The heat capacity of each species was correlated for temperature (TAPP, 1991):

The grate models only two dimensions: length and depth. The annular cooler was modeled like the grate by calculating an average length based on the average radius of the cooler bed:

$$z_c = \frac{\pi(d_i + d_o)}{2} \quad (2.35)$$

where d_i is the inner diameter and d_o is the outer diameter.

2.4.2 Rotary Kiln Model

The model for the rotary kiln is based on a first order mixing rule for the pellets and the net radiation method for heat transfer. The bed of pellets in the kiln was modeled as two regions: a mantle surrounding a core. Mixing between the mantle and core is assumed to follow a simple first order mixing rule:

$$\frac{dT_m}{dt} = (T_a - T_s) \quad (2.36)$$

$$\frac{dT_c}{dt} = (T_a - T_c) \quad (2.37)$$

where the average temperature of the solids was the weighted average of the core and mantle temperatures:

$$T_a = \frac{f_c c_{pc} T_c + (1 - f_c) c_{ps} T_s}{f_c c_{pc} + (1 - f_c) c_{ps}} \quad (2.38)$$

An energy balance around the mantle includes radiation heat transfer exchange between the solids and the wall and flame as well as convection with the secondary air. The net-radiation model of Thornton and Batterham (1982) is used to calculate the radiation heat exchange between the exposed wall of the kiln, the surface of the bed of solids and the flame. Radiation exchange with the secondary air was found to be insignificant in the kiln. The models of Tscheng and Watkinson (1979) for convective and conductive heat transfer in rotary kilns are also used in the model for heat transfer other than radiation between the gases, wall, and solids.

A tanks-in-series model of the kiln was used to perform the local material and energy balances. This approach is a departure from the differential approach used for the grate/cooler material and energy balances. The tanks-in-series model results in a system of non-linear algebraic equations.

The kiln was divided into a sequence of small divisions. It was found by trial-and-error that 100 divisions was satisfactory. The mantle and core were assumed to be perfectly mixed within each division. The energy balance for the solids in each kiln division was

$$m c_p (T_{in} - T_{out}) + q_{rs} + q_{gs} + q_{ws} + q_{ox} - q_c = 0 \quad (2.39)$$

The energy balance for the flame and secondary air streams in each kiln division were calculated according to the tanks-in-series model:

$$\left(\sum F_i H_i \right)_{in} - \left(\sum F_i H_i \right)_{out} + q_{gs} + q_{gw} + q_r = 0 \quad (2.40)$$

where F_i and H_i are the molar flow rate and enthalpy of species i in the gas stream, q_{gs} and q_{gw} are the convective heat transfer rates between the gas, solids and wall, and q_r is the net heat transfer rate to the gas stream. The enthalpy of each species was calculated in terms of the average heat capacity:

$$H = H^\circ + \bar{c}_p (T - T_r) \quad (2.41)$$

where H° is the heat of formation and T_r is the reference temperature of formation.

The convective heat transfer rate between the gas and solids, and gas and wall is described by the following equation:

$$q_{gs} = A_s h (T_{sa} - T_s); q_{gw} = A_w h (T_{sa} - T_w) \quad (2.42)$$

where A_s and A_w are the surface areas of exposed solids and wall, respectively, in the kiln division.

The temperature of the wall was calculated from a steady-state energy balance through the wall. The net heat transfer rate to the wall was equated with the composite heat transfer rate through the wall:

$$\sum q_w = U_{wo} z_k (T_w - T_\infty) \quad (2.43)$$

where z_k is the length of a kiln division, T_w and T_∞ are the inside wall surface temperature and ambient outside air temperature, respectively, and U_{wo} is the overall heat transfer coefficient for the outside wall area:

$$U_{wo} = \frac{2\pi}{\frac{1}{\kappa_{kr}} \ln\left(\frac{r_k}{r_{ki}}\right) + \frac{1}{\kappa_{ks}} \ln\left(\frac{r_{ki}}{r_{ko}}\right) + \frac{1}{h_o r_{ko}}} \quad (2.44)$$

where κ is the thermal conductivity of the kiln refractory or steel skin and r is the radius of the kiln refractory, inside skin or outside skin, respectively.

The combustion model assumes mixed-is-burned according to the methane combustion reaction:



The model assumes the fuel (natural gas) is methane. The surface areas of the flame and secondary air streams were calculated proportional to the relative temperature and mass flow rate each stream:

$$A_f = \frac{F_f T_f (\pi r_k^2 - A_b)}{F_f T_f + F_{sa} T_{sa}}; A_{sa} = \pi r_k^2 - A_b - A_f \quad (2.46)$$

where A , F , T are the cross sectional area, molar flow rate, and temperature of the flame and secondary air streams respectively, A_b is the solids bed cross sectional area, and r_k is the internal kiln radius.

The model equations for the rotary kiln were solved by relaxation on ordinary iteration. The wall temperature was particularly difficult to converge due to the highly non-linear radiation terms involved. The kiln zone model is solved in an inner loop before the overall solution procedure is completed.

2.4.3 CFD Cooler Model

CFD is not constrained by the limiting assumptions used to develop Medusa. The splits of the air flows to the kiln, recoup and vent are not required a priori; they are determined by the model. The other advantage of CFD is three dimensional modeling. Using CFD to

model the cooler overcomes the limitation of Medusa's two dimensions. A parametric study of the effects of production rate, magnetite concentration entering the cooler, and cooling air rates was performed on the CFD cooler model. The results were correlated by multivariable linear regressions. Regressed equations for secondary air flow and temperature and recoup flow and temperature were substituted into Medusa for the cooler model.

$$F_{rcp} / (kmol/s) = 1.78 - 0.145X_m - 1.31 \times 10^{-3} [m_s / (kg/s)] \quad (2.47)$$

$$T_{rcp} / K = 1.49 \times 10^3 + 4.81 \times 10^2 X_m + 6.70 [m_s / (kg/s)] \quad (2.48)$$

$$F_{sa} / (kmol/s) = 1.42 + 5.49 \times 10^{-2} X_m + 1.33 \times 10^{-3} [m_s / (kg/s)] \quad (2.49)$$

$$T_{sa} / K = 1.67 \times 10^3 + 2.82 \times 10^2 X_m + 1.47 [m_s / (kg/s)] \quad (2.50)$$

Equations (2.47) through (2.50) were programmed directly into the FORTRAN program for Medusa. Modifying Medusa at the program level should be done with caution. Users are encouraged to consult with Richard Davis before attempting to change the original code.

2.4.4 Model Calibration

The model was calibrated to the plant data by adjusting the leakage of ambient air on the grate and cooler. The leakage to a zone was assumed to be proportional to the length of the zone and the square root of the pressure drop across the leak into the zone, according to the Bernoulli equation:

$$F_{leak} \propto L_b \sqrt{\Delta P_{leak}} \quad (2.51)$$

The temperature of the solids exiting the kiln and the temperature of the gas leaving the preheat zone were used as the target temperatures. The leakage was adjusted until the difference between the model predictions for the target temperatures and the plant data for these temperatures was minimized. The minimization function was the least squares expression:

$$f = \sum (T_p - T_m)^2 \quad (2.52)$$

where T_m was the measured temperature in the plant and T_p was the model predicted temperature. Powell's "dog leg" optimization method was used to search for the minimum (Press, et al, 1987). It was assumed for the conditions of the simulation that there was a unique global minimum within the plant operating conditions. Repeating the search for the minimum at different starting conditions validated this assumption; the same solution for the minimum was reached.

2.5 Model Implementation

The mathematical model equations were solved using standard numerical algorithms for solving systems of differential/algebraic equations. The algorithms were coded into computer programs and a graphical user interface was developed to make the code generic, independent of any particular machine. Hence, the models and their implementation may be

used for any grate-kiln system, independent of the dimensions or configuration. All of the files are available at the Medusa web site

<http://www.d.umn.edu/~rdavis/research/medusa/medusa.htm>

2.5.1 Medusa.for

The model equations were solved numerically using standard FORTRAN algorithms. The program is designed to pass information between subroutines using common statements. The differential equations used to model the grate or cooler were solved by a variable-step second-order Runge-Kutta method. The main program initializes the variables using typical target values for taconite pellet induration furnaces. Initialization subroutines are located at the end of the program. SI (metric) units were used in the model solutions for convenience in the calculations. Field (English) units are an option in the user interface described below. The solution is iterative due to the nonlinear nature of the radiation and chemical reaction models. The solids temperature trajectories were calculated based on the initial guesses for the zone gas temperatures and flow rates. The zone gas temperatures and flow rates are upgraded from the solids temperatures. This cycle is repeated until the zone gas and solids temperatures converge. A block diagram of the solution algorithm is shown in Figure 2.4.

2.5.2 Medusa.exe

A compiled version of the FORTRAN program MEDUSA.EXE executes the calculations. MEDUSA.EXE is called from a graphical user interface (GUI) described in the next section. The required operating parameters are read from a data file. The GUI is also used to control the duration of the calculations or stop the calculations premature to convergence.

2.5.3 Medusa.ctf

The GUI creates a control file named Medusa.ctf. This file contains the name of the data and results files and the maximum number of overall convergence iterations. Upon execution, Medusa.exe first reads Medusa.ctf to get the name of the data file. This file is also read before each overall solution iteration. The GUI controls the iterations by changing the maximum iteration number while the program is executing.

2.5.4 Name.dat

The GUI is used to create a data file that is read by Medusa.exe. The user provides the name of the file in the GUI. The GUI adds the identifying extension .DAT. The data file contains all of the required input parameters for solving the Medusa model equations for a particular case. Experienced users may find it convenient to modify the .DAT file instead of using the GUI. Use caution when modifying the .DAT file without the aid of the GUI. Errors in input are difficult to trace.

2.5.5 Name.fld or Name.met

The results from the model solution are written to the output file. The user provides the name of the output file in the GUI. The extension .FLD indicates FIELD (English) units. SI (Metric) units are indicated by a .MET extension. The output file first lists the input data for

identification purposes. The results for residence time, average temperature and average composition are tabulated for each zone. The profiles through the bed are given for the end of a zone. The zone gas flows are also tabulated. A material balance for the gas phase is included at the end of the output file that includes the zone gas compositions.

2.5.6 Medusa.rst

The converged temperatures and flow rates of the process gas in each zone are written to the file Medusa.rst. The process gas temperatures and flow rates are used to initialize the model solution. When the restart feature is selected, the data in Medusa.rst are read into Medusa.exe as the initial guesses for the unknown gas characteristics. This file only used after the first implementation of the model to speed up convergence. Medusa.rst is generally not available for the first run.

2.6 Graphical User Interface

A graphical user interface was developed to provide a convenient tool for creating the data files needed by the executable Medusa model. The interface was created with Microsoft Excel using Visual Basic for Applications. The interface requires MS Excel 97 or higher. The interface is organized as an Excel workbook with seven sheets. Examples of each sheet are presented in Figures 2.5 through 2.12. The model calculates on the SI unit basis. The GUI accepts both SI and Field (English) units. Common unit conversions are listed in Table 2.1.

2.6.1 File Manager

The File Manager Sheet, shown in Figure 2.5, is used to create the data, results, and control files. The data and results files are named by the user in the box entitled: Results File Name. The results file lists the date and title supplied by the user. It is important to select the system of units before entering numerical data: Field (English) or SI (metric). The selection of units changes the headings for required units of all dimensional parameters in the other sheets. It is important to note that changing the type of units does not automatically convert the numbers in the sheets into the new dimensions; only the headings change. If the user decides to change the unit designator on the File Manager sheet, it is the responsibility of the user to supply the corresponding numerical values that match the new unit set. Table 2.1 lists several common unit conversions for this system. The program gives the data file name an extension .DAT. The model results file name is given an extension corresponding to the type of units selected: .FLD for Field units, of .MET for metric units. In addition, there are two other control files that are generated. The executable program to manage the input and output file names and control the number of overall solution iterations uses the file MEDUSA.CTL. MEDUSA.CTL is also used to stop the executable program before convergence using the GUI to generate the results file containing the model results from the last iteration. The other file is MEDUSA.RST. This file is generated at the end of the model calculations and contains a new set of initial guesses for the model. Using restart calls this file for the initial guesses for the next execution of MEDUSA.EXE. Generally, restart speeds up the convergence. This file is not available the first time MEDUSA.EXE is executed.

The What-if feature on the File Manager allows the user to run the model for a range of Fuel or Solids feed rates. This feature allows the user to explore the affects of changing

either solids or fuel rates on the model without creating a new data file for each change. Up to ten runs may be selected for any range of the what-if variable. The base case is defined by the parameters supplied to the other sheets in the GUI.

The other features of the File Manager sheet are described next. The Maximum Medusa Cycles is used to limit the number of overall solution iterations to stop the program is reasonable convergence times are not achieved. The Optimization radio button should only be checked if the user has a modified version of MEDUSA.EXE that uses the inherent optimization algorithm. A WWW site is maintained that has current versions of the programs and a help file for using Medusa.

The three buttons located in the lower right corner are used to generate the data file after all the required parameters are supplied, launch the executable version of Medusa, and prematurely stop the program execution.

2.6.2 Pellet Bed

The Pellet Bed sheet, shown in Figure 2.6, lists all of the parameters required by Medusa to define the characteristics of the solids feed and pellet bed. The sheet is divided into sections for pellet chemistry, pellet characteristics, green ball feed conditions, and bed characteristics. Recommended values are given for some parameters based on experience with the model. The recommendations are only intended to serve as a guide. The user should consider using alternative values to adjust the model solutions to match plant data where appropriate. The heat transfer resistance and Convection Enhancement Factors are useful for adjusting the rates of heat transfer between the process gases and the bed of pellets.

2.6.3 Furnace Zones I & II

The Furnace Zone GUIs are shown in Figures 2.7 and 2.8. The first spreadsheet for furnace zones is used to define the machine type: grate-kiln or straight-grate. The principal firing zone is also identified. The firing zone is used by the what-if calculations described under File Manager. Furnace Zones I is used to name the zones and provide the physical dimensions of each zone. In the case of a straight grate machine, the depth of the hearth layer is also listed. The hearth layer depth should be set to zero for grate-kiln machines. However, the hearth layer may be used in grate-kiln models to artificially model additional heat transfer with the traveling grate.

The second sheet for furnace zones permits the user to specify a different bed porosity (voidage) in each zone. The porosity is used in the GUI to calculate a bed depth given a linear bed velocity, or a linear bed velocity given a bed depth. The bed density is based on the pellet chemistry defined in the Pellet Bed sheet.

2.6.4 Rotary Kiln

The Rotary Kiln data sheet is shown in Figure 2.9. The rotary kiln zone is unique to the grate-kiln model. The straight-grate model ignores the parameters supplied to this sheet. The required parameters for the kiln are self-explanatory. A ported kiln model is available, though untested. To use the ported kiln feature, the user must decide on the length and location of a single section of the kiln that is ported. The model assumes that the gas is evenly distributed along the length of the ported kiln section. The kiln is divided into 100

sections, starting at the pellet feed end of the kiln. The location of the ported section is defined relative to the lower section number and the length of the kiln. For example, consider a 150 ft long kiln with a 50 ft long ported section that starts at 50 ft from the feed end. The length of a section is 1.5 ft/section. The location of the start section is at $(50 \text{ ft}) / (1.5 \text{ ft/section}) = 33.33$ sections. The location of the end of the ported section is at $(50 + 50 \text{ ft}) / (1.5 \text{ ft/section}) = 66.67$. To ensure that the modeled ports encompass the entire length of the ported section, the start location is rounded down to the lowest integer value of 33, while the end location is rounded up to the next highest integer value of 67. Thus, the start and end divisions are at 33 and 67, respectively.

2.6.5 Process Gas

The ambient gas temperature, fuel, primary air, and secondary air feed rates to the zones are set in the Process Gas sheet, shown in Figure 2.10. The ability to fix the temperatures of the secondary air independently builds flexibility into the model set-up. This feature may be useful when using Medusa to model a portion of the entire furnace. For example, the user may model the grate alone, fixing the temperatures and flow rates of the recoup air to the second drying stage and the secondary air from the kiln. The direction of flow through the bed on the grate or cooler is set here for each zone. The user may explore the effects of updraft versus downdraft flow in each zone independently. The outside air temperature and humidity are also set on this sheet.

2.6.6 Leakage

The Leakage GUI is shown in Figure 2.11. The Medusa model includes capabilities of accounting for leakage into the machine as well as leakage between zones, either above or below the bed. The model does not allow for leakage from the machine. In the case of interzone leakage, the model permits the leakage to occur in one of two directions. Leakage to and from adjacent zones is a feature that may be useful to model mixing in the gas phase where there are no physical separations between the zones, such as the Minntac cooler. The temperature of the air leaking into the machine is also set on this sheet.

2.6.7 Gas Distribution

The Medusa model requires that the distribution of process gases be set for each zone. The Gas Distribution sheet, shown in Figure 2.12, is arranged for the user to set-up the gas distribution in terms of the volume percent of the gas leaving a zone being distributed to the other zones. The gas is leaving the zone in the left column and distributed to a zone listed along the top row. For example, the user may set-up the model for 30% of the preheat zone gas directed to the first drying stage and 70% of the preheat exit gas directed to the second drying stage.

2.7 Results

The Medusa model was solved for the parameters as shown in the GUI. Sample results from the program are listed in Table 2.2. Temperature and composition profiles for the drying, preheat, and kiln zones are plotted in Figures 2.13 through 2.15. The average solids temperature is plotted in Figure 2.13 as a function of position. When compared to the average solids temperature profile plotted with residence time in Figure 2.14, it is clear that

the zone with the largest residence time is the rotary kiln. The composition of flux, magnetite, and water are plotted in terms of mass fraction in Figure 2.15. Figure 2.15 shows that the model predicts that the pellets are completely dry before the preheater, and that most of the flux decomposes in the preheater before the solids enter the kiln. The model also predicts that oxidation starts slowly in the dryers, increases in the preheater, then slows in the kiln. This is probably due to the poor mixing of air with the solids in the kiln.

Plots of the data generated by Medusa are readily created in Excel. The procedure involves copying the rows of data of interest and pasting into Excel. The data are pasted into a single column. Parsing the data using that intrinsic feature of Excel that creates columns separates the individual data columns. Once the data are available in the spreadsheet, they are easily manipulated according to the needs of the user.

2.8 Summary

The Medusa model is designed for overall material and energy balances around grate-kiln induration furnaces. The model assumes that gases are well mixed and requires the process gas flow distribution. The mathematical model consists of a system of nonlinear, algebraic and first-order ordinary differential equations. The solution of the coupled system of equations requires iteration on the unknown variables. The solution method consists of standard numerical methods programmed in FORTRAN. A graphical user interface was created with Excel to allow users to operate the model without knowledge of FORTRAN. An optimization routine is available in the FORTRAN code that is not accessible through the Excel graphical user interface. Modification of the FORTRAN code requires experience in FORTRAN programming. It is recommended that users consult the authors before attempting to change the FORTRAN code. The model gives average temperature and composition profiles in the furnace, kiln, and cooler. The model may also be modified to include correlated equations that represent the cooler, or other unit operations.

2.9 Nomenclature

| | |
|---|-----------------------------------------------------|
| a | area per unit volume |
| A | cross sectional area |
| C | concentration |
| c | heat capacity |
| d | diameter |
| D | diffusivity |
| f | fraction or function |
| F | gas molar flow rate |
| G | free energy |
| H | enthalpy |
| h | local heat transfer coefficient |
| k | mass transfer coefficient or reaction rate constant |
| L | length (depth) |
| m | mass flow rate |
| M | molecular weight |
| P | gas pressure |
| q | heat transfer rate |
| R | ideal gas constant |

| | |
|---|-----------------------------------|
| r | pellet radius |
| T | temperature |
| U | overall heat transfer coefficient |
| u | velocity |
| V | volume |
| w | width |
| X | mass fraction |
| y | gas phase mole fraction |
| z | length coordinate |

Greek Symbols

| | |
|---------------|----------------------|
| ε | porosity |
| κ | thermal conductivity |
| λ | latent heat |
| μ | dynamic viscosity |
| ν | kinematic viscosity |
| ρ | density |
| τ | tortuosity |

Subscripts/Superscripts

| | |
|-----|---------------------------------|
| b | bed of solids or bulk gas phase |
| c | cooler zone or calcined flux |
| c | magnetite pellet core |
| Ca | calcium carbonate |
| e | effective |
| e | equilibrium |
| f | flux or flame |
| g | gas |
| h | hematite |
| i | in, inside, or inert |
| k | kiln |
| l | bed layer of solids |
| m | magnetite or mantle or measured |
| Mg | magnesium carbonate |
| o | out or outside |
| ox | oxidation |
| p | pellet |
| p | predicted |
| ' | per unit length |
| r | radiation |
| rcp | recoup |
| s | solids |
| sa | secondary air |
| v | vaporization |
| w | water or wall |

2.10 References

- Gaskell, D.R., *Introduction to Metallurgical Thermodynamics*, 2nd ed., Taylor & Francis, 1981.
- Mills, A.F., *Basic Heat and Mass Transfer*, 2nd ed., Prentice Hall, Upper Saddle River, NJ, p. 947 (1999).
- Papanastassiou, D. and G. Bitsianes, "Mechanisms and Kinetics Underlying the Oxidation of Magnetite in the Induration of Iron Ore Pellets," *Metallurgical Transactions*, v. 4, pp. 487-496 (1973).
- Press, W.H., B.P. Flannery, S.A. Teukolosky, and W.T. Vetterling, *Numerical Recipes: The Art of Scientific Computing*, Cambridge University Press (1987).
- Reid, R.C., J.M. Prausnitz, and B.E. Poling, *The Properties of Gases and Liquids*, 4th ed., McGraw-Hill, New York, 1987.
- Seader, J.D. and E.J. Henley, *Separation Process Principles*, Wiley, New York, p.814 (1998).
- TAPP: Thermal and Physical Properties*, ES Microware, Hamilton Ohio, 1991
- Thornton, G.J. and R.J. Batterham, "The Transfer of Heat in Kilns," *Chemeaca 82*, Tenth Australian Chemical Engineers Conference, The Institute of Engineers, Australia, National Publication no. 82/9, pp. 260-266 (1982).
- Thurlby, J.A., "A Dynamic Mathematical Model of the Complete Grate/Kiln Iron-Ore Pellet Induration Process," *Metallurgical Transactions B*, v. 19B, pp. 103-112 (1988).,
- Tscheng, S.H. and A.P. Watkinson, "Convective Heat Transfer in a Rotary Kiln," *Can. J. Chem Eng.*, v. 57. pp. 433-443 (1979).

Table 2.1. Unit Conversions for Medusa and CFD

| To Convert From: | To: | Multiply By: |
|----------------------|--------|-------------------------|
| in | m | 0.0240 |
| ft | m | 0.3048 |
| scfm | kmol/s | 2.1056×10^{-5} |
| LT/hr | kg/s | 0.28222 |
| Lb _m /min | kg/s | 7.56×10^{-3} |
| MBTU/hr | Kmol/s | 3.5×10^{-4} |

Table 2.2 Medusa Output File

```

*****
MEDUSA: TACONITE PELLETT INDURATION MODELER
        FOR STRAIGHT-GRATE & GRATE-KILN SYSTEMS

BY: RICHARD DAVIS, UMD CHEMICAL ENGINEERING DEPARTMENT
   COPYRIGHT 2000. RICHARD DAVIS.
        ALL RIGHTS RESERVED.

DISCLAIMER: USE THIS PROGRAM AT YOUR OWN RISK!
            NO WARRANTIES ARE EXPRESSED OR IMPLIED,
            THAT THIS PROGRAM IS FREE OF ERROR, OR
            WILL MEET YOUR REQUIREMENTS FOR ANY
            PARTICULAR APPLICATION. THE AUTHOR
            DISCLAIMS ALL LIABILITY FOR DIRECT OR
            CONSEQUENTIAL DAMAGES RESULTING FROM YOUR
            USE OF THIS PROGRAM.

*****
GRATE-KILN MODEL RESULTS
FIELD UNITS

TITLE: test
RUN DATE: 5/18/00
RESULTS FILE NAME: test.fld
WHAT-IF VARIABLE: FUEL RATE
Restart? False
Minimum what-if %:      100.0
Maximum what-if %:      100.0
Number of what-if:      1

*** RUN FILE DATA ***

SOLIDS FEED RATE (LT/hr):
  Green ball   =    472.00
  Hearth layer =     .00000

Pellet diameter (in) =    .43700

SOLIDS FEED TEMPERATURE (deg F):

```

Green ball = 62.300
Hearth layer = 62.300

FEED MASS FRACTION:

Magnetite = .75800
Hematite = .41000E-01
Inert = .44000E-01
Flux = .69000E-01
Water = .88000E-01

Pellet porosity = .25000

Heat conduction resistance factor = .00000

Solids emmissity = .60000

AIR TEMPERATURES (deg F):

Outside air = 37.000
Leakage air = 62.300

Number of zones = 4

Machine type (1 = SG; 2 = GK) = 2

Kiln zone = 4

Fire zone = 4

ZONE NAMES:

1 DD1
2 DD2
3 PH
4 KILN

FLOW DIRECTIONS (1 = DOWN-DRAFT; -1 = UP-DRAFT):

1 1
2 1
3 1
4 1

AIR FLOW RATE TO ZONE (SCFM):

1 .00000
2 70099.
3 .00000
4 85486.

TEMPERATURE OF AIR TO ZONE (deg F):

1 62.300
2 1686.0
3 62.300
4 2316.0

LEAKAGE INTO BED-GAS FEED SIDE (SCFM):

1 66428.
2 35536.
3 59171.
4 .00000

LEAKAGE INTO BED-GAS EXIT SIDE (SCFM):

1 .00000
2 .00000
3 10923.
4 .00000

FUEL TO ZONE (SCFM):

1 .00000
2 .00000
3 1083.0
4 2850.0

PRIMARY AIR TO ZONE (SCFM):

1 .00000
2 .00000
3 1168.0
4 3078.0

ZONE LENGTH (ft):

1 49.200
2 23.000
3 55.800
4 131.00

ZONE WIDTH (ft):

1 15.700
2 15.700
3 15.700
4 19.700

ZONE HIGHT (ft):

1 10.800
2 10.800
3 10.800
4 10.800

ZONE REFRACTORY THICKNESS (in):

1 5.5000
2 5.5000
3 5.5000
4 5.5000

ZONE BED DEPTH (in):

1 5.1000
2 5.1000
3 5.1000
4 5.1000

ZONE HEARTH LAYER DEPTH (in):

1 .00000
2 .00000
3 .00000
4 .00000

ZONE BED POROSITY:

1 .30000
2 .30000
3 .30000

```

4      .35000

ZONE BED SPEED (in/min)
1      270.73
2      270.73
3      270.73
4      232.36

KILN PARAMETERS:
Length (ft)      =      131.00
Inside diameter (ft) =      20.000
Outside diameter (ft) =      21.300
Rotation speed (rpm) =      1.1400
Pitch angle (deg) =      3.0000

UP-STREAM LEAKAGE-GAS FEED SIDE (SCFM):
1      .00000
2      .00000
3      .00000
4      .00000

DOWN-STREAM LEAKAGE-GAS FEED SIDE (SCFM):
1      .00000
2      .00000
3      .00000
4      .00000

UP-STREAM LEAKAGE-GAS EXIT SIDE (SCFM):
1      .00000
2      .00000
3      .00000
4      .00000

DOWN-STREAM LEAKAGE-GAS EXIT SIDE (SCFM):
1      .00000
2      .00000
3      .00000
4      .00000

TO VENT (SCFM):
1      47492.
2      47492.
3      .00000
4      .00000

FRACTION OF GAS FLOW FROM ZONE J TO ZONE I:
1  1      .00000
2  1      .00000
3  1      1.00000
4  1      .00000

1  2      .00000
2  2      .00000
3  2      .00000
4  2      .00000

1  3      .00000

```

2 3 .00000
 3 3 .00000
 4 3 1.0000

1 4 .00000
 2 4 .00000
 3 4 .00000
 4 4 .00000

Percent Humidity = 50.0

*** END RUN FILE DATA ***

What-if % = 100.00

*** MACHINE-LENGTH PROFILES ***

ZONE: DD1

SOLIDS LINEAR VELOCITY/ (in/min) = 270.73

| Z/ ft | t/ min | T-Bed/ F (Ave) | T-Layer/ F (Out) | T-Air/ F (Out) | X-Flux (Ave) | X-Fe3O4 (Ave) | X-H2O (Ave) | Solids/ LT/hr | C-Fe3O4 % cnvrsl |
|----------|-----------|-------------------|---------------------|-------------------|-----------------|------------------|----------------|------------------|---------------------|
| .0 | .00 | 62.3 | 62.3 | 62.3 | .0690 | .7580 | .0880 | 472.00 | .00 |
| 1.0 | .04 | 74.7 | 63.4 | 72.8 | .0690 | .7580 | .0882 | 472.11 | .00 |
| 2.0 | .09 | 87.7 | 65.6 | 78.4 | .0690 | .7580 | .0884 | 472.21 | .00 |
| 3.0 | .13 | 100.6 | 70.0 | 87.4 | .0690 | .7580 | .0885 | 472.25 | .00 |
| 3.9 | .17 | 113.0 | 77.9 | 100.3 | .0690 | .7580 | .0884 | 472.20 | .00 |
| 4.9 | .22 | 124.1 | 89.6 | 116.0 | .0690 | .7580 | .0880 | 471.99 | .00 |
| 5.9 | .26 | 133.2 | 105.5 | 131.4 | .0690 | .7580 | .0870 | 471.53 | .00 |
| 6.9 | .31 | 140.0 | 121.1 | 143.0 | .0690 | .7580 | .0854 | 470.78 | .00 |
| 7.9 | .35 | 144.2 | 133.3 | 151.5 | .0690 | .7580 | .0832 | 469.73 | .00 |
| 8.9 | .39 | 146.7 | 140.5 | 154.4 | .0690 | .7580 | .0805 | 468.48 | .00 |
| 9.8 | .44 | 148.7 | 142.7 | 154.7 | .0690 | .7580 | .0777 | 467.16 | .00 |
| 10.8 | .48 | 151.2 | 143.2 | 154.5 | .0690 | .7580 | .0750 | 465.86 | .00 |
| 11.8 | .52 | 154.3 | 142.3 | 153.3 | .0690 | .7580 | .0724 | 464.63 | .00 |
| 12.8 | .57 | 158.2 | 141.2 | 152.8 | .0690 | .7580 | .0699 | 463.45 | .00 |
| 13.8 | .61 | 162.8 | 140.1 | 151.9 | .0690 | .7580 | .0675 | 462.32 | .00 |
| 14.8 | .65 | 168.3 | 138.8 | 151.3 | .0690 | .7580 | .0652 | 461.25 | .00 |
| 15.7 | .70 | 174.2 | 138.1 | 151.3 | .0690 | .7580 | .0630 | 460.21 | .00 |
| 16.7 | .74 | 180.7 | 137.1 | 150.9 | .0690 | .7580 | .0609 | 459.21 | .00 |
| 17.7 | .79 | 187.8 | 136.4 | 151.2 | .0690 | .7580 | .0589 | 458.24 | .00 |
| 18.7 | .83 | 195.1 | 136.0 | 151.4 | .0690 | .7579 | .0568 | 457.29 | .01 |
| 19.7 | .87 | 203.0 | 135.1 | 151.5 | .0689 | .7578 | .0549 | 456.37 | .02 |
| 20.7 | .92 | 211.3 | 134.7 | 152.6 | .0689 | .7577 | .0530 | 455.47 | .04 |
| 21.6 | .96 | 219.9 | 134.4 | 152.9 | .0688 | .7574 | .0511 | 454.57 | .08 |
| 22.6 | 1.00 | 229.0 | 133.8 | 153.6 | .0688 | .7570 | .0493 | 453.70 | .14 |
| 23.6 | 1.05 | 238.6 | 133.7 | 155.0 | .0687 | .7563 | .0475 | 452.84 | .23 |
| 24.6 | 1.09 | 248.7 | 133.4 | 155.6 | .0685 | .7552 | .0457 | 451.98 | .37 |
| 25.6 | 1.13 | 259.3 | 132.9 | 157.0 | .0683 | .7538 | .0440 | 451.15 | .55 |
| 26.6 | 1.18 | 270.1 | 133.1 | 159.1 | .0681 | .7522 | .0422 | 450.30 | .77 |
| 27.6 | 1.22 | 281.1 | 132.7 | 159.6 | .0678 | .7504 | .0405 | 449.46 | 1.01 |
| 28.5 | 1.26 | 293.0 | 132.4 | 161.0 | .0676 | .7483 | .0389 | 448.66 | 1.28 |
| 29.5 | 1.31 | 305.1 | 132.7 | 163.3 | .0674 | .7459 | .0372 | 447.84 | 1.59 |
| 30.5 | 1.35 | 317.5 | 132.3 | 164.9 | .0671 | .7434 | .0356 | 447.06 | 1.92 |
| 31.5 | 1.40 | 330.2 | 132.0 | 167.0 | .0668 | .7407 | .0340 | 446.28 | 2.28 |
| 32.5 | 1.44 | 343.5 | 132.5 | 169.6 | .0666 | .7378 | .0323 | 445.51 | 2.67 |
| 33.5 | 1.48 | 357.2 | 132.0 | 171.7 | .0664 | .7346 | .0307 | 444.76 | 3.08 |
| 34.4 | 1.53 | 370.9 | 132.1 | 175.4 | .0661 | .7313 | .0292 | 444.02 | 3.52 |
| 35.4 | 1.57 | 384.7 | 132.4 | 177.6 | .0658 | .7278 | .0276 | 443.26 | 3.98 |
| 36.4 | 1.61 | 399.4 | 131.9 | 180.6 | .0656 | .7241 | .0261 | 442.56 | 4.47 |
| 37.4 | 1.66 | 414.0 | 132.2 | 185.1 | .0653 | .7202 | .0246 | 441.85 | 4.99 |
| 38.4 | 1.70 | 428.5 | 132.3 | 188.1 | .0649 | .7161 | .0231 | 441.12 | 5.53 |
| 39.4 | 1.74 | 443.7 | 131.9 | 192.2 | .0647 | .7118 | .0216 | 440.45 | 6.10 |
| 40.3 | 1.79 | 458.9 | 132.4 | 197.5 | .0644 | .7073 | .0202 | 439.77 | 6.68 |
| 41.3 | 1.83 | 474.1 | 132.3 | 200.8 | .0640 | .7027 | .0187 | 439.09 | 7.30 |
| 42.3 | 1.88 | 489.5 | 132.0 | 206.6 | .0637 | .6979 | .0174 | 438.44 | 7.93 |
| 43.3 | 1.92 | 505.1 | 132.8 | 213.2 | .0633 | .6929 | .0160 | 437.79 | 8.59 |
| 44.3 | 1.96 | 520.7 | 132.3 | 217.4 | .0630 | .6877 | .0146 | 437.16 | 9.27 |
| 45.3 | 2.01 | 537.0 | 132.2 | 225.1 | .0627 | .6824 | .0134 | 436.59 | 9.97 |
| 46.2 | 2.05 | 552.9 | 133.3 | 232.7 | .0624 | .6769 | .0120 | 435.97 | 10.69 |
| 47.2 | 2.09 | 568.8 | 132.4 | 239.0 | .0620 | .6713 | .0108 | 435.41 | 11.44 |
| 48.2 | 2.14 | 585.2 | 132.6 | 247.9 | .0617 | .6655 | .0097 | 434.89 | 12.20 |
| 49.2 | 2.18 | 601.1 | 133.9 | 256.5 | .0613 | .6596 | .0084 | 434.32 | 12.99 |

ZONE: DD2
SOLIDS LINEAR VELOCITY/ (in/min) = 270.73

| Z/ ft | t/ min | T-Bed/ F (Ave) | T-Layer/ F (Out) | T-Air/ F (Out) | X-Flux (Ave) | X-Fe3O4 (Ave) | X-H2O (Ave) | Solids/ LT/hr | C-Fe3O4 % cnvrsl |
|----------|-----------|-------------------|---------------------|-------------------|-----------------|------------------|----------------|------------------|---------------------|
| 49.7 | 2.20 | 613.2 | 130.9 | 263.0 | .0612 | .6557 | .0078 | 434.05 | 13.49 |
| 50.1 | 2.22 | 625.5 | 129.0 | 267.4 | .0610 | .6519 | .0072 | 433.80 | 14.00 |
| 50.6 | 2.24 | 637.9 | 127.9 | 272.7 | .0609 | .6480 | .0066 | 433.56 | 14.51 |
| 51.0 | 2.26 | 650.3 | 127.7 | 279.1 | .0607 | .6441 | .0061 | 433.32 | 15.03 |
| 51.5 | 2.28 | 662.5 | 127.9 | 285.4 | .0604 | .6400 | .0055 | 433.06 | 15.56 |
| 52.0 | 2.30 | 674.9 | 126.7 | 290.0 | .0602 | .6360 | .0050 | 432.85 | 16.10 |
| 52.4 | 2.32 | 687.3 | 125.9 | 297.6 | .0601 | .6319 | .0046 | 432.68 | 16.64 |
| 52.9 | 2.34 | 699.7 | 125.9 | 306.2 | .0599 | .6278 | .0042 | 432.49 | 17.18 |
| 53.3 | 2.36 | 711.9 | 126.4 | 314.6 | .0597 | .6236 | .0037 | 432.30 | 17.73 |
| 53.8 | 2.38 | 724.1 | 127.3 | 322.4 | .0594 | .6193 | .0032 | 432.10 | 18.29 |
| 54.3 | 2.41 | 736.4 | 127.4 | 329.4 | .0592 | .6150 | .0028 | 431.92 | 18.86 |
| 54.7 | 2.43 | 748.4 | 126.1 | 340.0 | .0591 | .6108 | .0025 | 431.79 | 19.42 |
| 55.2 | 2.45 | 760.4 | 126.0 | 350.7 | .0588 | .6064 | .0021 | 431.65 | 20.00 |
| 55.6 | 2.47 | 772.2 | 126.8 | 361.9 | .0586 | .6020 | .0018 | 431.50 | 20.58 |
| 56.1 | 2.49 | 784.0 | 127.8 | 371.9 | .0583 | .5976 | .0014 | 431.36 | 21.16 |
| 56.6 | 2.51 | 795.9 | 129.1 | 382.7 | .0581 | .5931 | .0011 | 431.21 | 21.75 |
| 57.0 | 2.53 | 807.2 | 126.9 | 395.3 | .0579 | .5887 | .0009 | 431.14 | 22.34 |
| 57.5 | 2.55 | 818.4 | 126.7 | 409.7 | .0576 | .5841 | .0007 | 431.06 | 22.94 |
| 57.9 | 2.57 | 829.6 | 127.6 | 423.5 | .0574 | .5795 | .0005 | 430.99 | 23.55 |
| 58.4 | 2.59 | 839.3 | 128.8 | 438.8 | .0571 | .5749 | .0003 | 430.90 | 24.16 |
| 58.9 | 2.61 | 850.2 | 130.3 | 451.5 | .0568 | .5703 | .0001 | 430.81 | 24.76 |
| 59.3 | 2.63 | 859.5 | 149.9 | 469.2 | .0565 | .5656 | .0000 | 430.79 | 25.38 |
| 59.8 | 2.65 | 868.5 | 178.5 | 489.1 | .0562 | .5609 | .0000 | 430.79 | 26.00 |
| 60.2 | 2.67 | 877.7 | 205.9 | 507.4 | .0559 | .5562 | .0000 | 430.80 | 26.63 |
| 60.7 | 2.69 | 886.9 | 232.4 | 526.5 | .0556 | .5514 | .0000 | 430.82 | 27.26 |
| 61.2 | 2.71 | 895.9 | 258.0 | 545.0 | .0553 | .5466 | .0000 | 430.83 | 27.88 |
| 61.6 | 2.73 | 905.7 | 283.0 | 563.2 | .0550 | .5418 | .0000 | 430.83 | 28.52 |
| 62.1 | 2.75 | 914.5 | 307.2 | 580.5 | .0547 | .5369 | .0000 | 430.84 | 29.16 |
| 62.5 | 2.77 | 923.1 | 330.9 | 599.7 | .0543 | .5320 | .0000 | 430.84 | 29.81 |
| 63.0 | 2.79 | 932.2 | 354.1 | 615.6 | .0538 | .5271 | .0000 | 430.82 | 30.46 |
| 63.5 | 2.81 | 940.5 | 376.7 | 633.1 | .0535 | .5223 | .0000 | 430.82 | 31.10 |
| 63.9 | 2.83 | 949.5 | 398.9 | 650.1 | .0531 | .5173 | .0000 | 430.81 | 31.76 |
| 64.4 | 2.85 | 958.4 | 420.5 | 666.3 | .0527 | .5122 | .0000 | 430.81 | 32.42 |
| 64.8 | 2.87 | 966.5 | 441.7 | 683.6 | .0524 | .5072 | .0000 | 430.81 | 33.09 |
| 65.3 | 2.89 | 975.1 | 462.5 | 700.1 | .0520 | .5022 | .0000 | 430.81 | 33.75 |
| 65.8 | 2.91 | 983.2 | 482.9 | 716.3 | .0516 | .4972 | .0000 | 430.79 | 34.41 |
| 66.2 | 2.94 | 990.6 | 502.9 | 732.4 | .0511 | .4920 | .0000 | 430.77 | 35.09 |
| 66.7 | 2.96 | 998.6 | 522.5 | 747.8 | .0506 | .4869 | .0000 | 430.75 | 35.77 |
| 67.1 | 2.98 | 1006.4 | 541.8 | 764.3 | .0502 | .4817 | .0000 | 430.75 | 36.45 |
| 67.6 | 3.00 | 1013.6 | 560.7 | 779.9 | .0498 | .4766 | .0000 | 430.73 | 37.12 |
| 68.1 | 3.02 | 1020.8 | 579.3 | 795.2 | .0493 | .4714 | .0000 | 430.70 | 37.81 |
| 68.5 | 3.04 | 1028.1 | 597.5 | 810.1 | .0488 | .4661 | .0000 | 430.69 | 38.51 |
| 69.0 | 3.06 | 1035.0 | 615.6 | 827.4 | .0483 | .4608 | .0000 | 430.65 | 39.20 |
| 69.4 | 3.08 | 1041.3 | 633.5 | 840.3 | .0477 | .4556 | .0000 | 430.60 | 39.90 |
| 69.9 | 3.10 | 1048.0 | 651.3 | 855.3 | .0472 | .4503 | .0000 | 430.57 | 40.59 |
| 70.4 | 3.12 | 1054.4 | 669.3 | 870.2 | .0466 | .4450 | .0000 | 430.53 | 41.29 |
| 70.8 | 3.14 | 1060.8 | 688.0 | 884.6 | .0461 | .4396 | .0000 | 430.51 | 42.01 |
| 71.3 | 3.16 | 1067.2 | 707.9 | 901.1 | .0456 | .4342 | .0000 | 430.49 | 42.72 |
| 71.7 | 3.18 | 1073.3 | 729.9 | 915.8 | .0451 | .4288 | .0000 | 430.46 | 43.43 |
| 72.2 | 3.20 | 1079.1 | 754.7 | 930.1 | .0445 | .4234 | .0000 | 430.42 | 44.14 |

ZONE: PH
SOLIDS LINEAR VELOCITY/ (in/min) = 270.73

| Z/ ft | t/ min | T-Bed/ F (Ave) | T-Layer/ F (Out) | T-Air/ F (Out) | X-Flux (Ave) | X-Fe3O4 (Ave) | X-H2O (Ave) | Solids/ LT/hr | C-Fe3O4 % cnvrnsn |
|----------|-----------|-------------------|---------------------|-------------------|-----------------|------------------|----------------|------------------|----------------------|
| 73.3 | 3.25 | 1090.7 | 790.9 | 924.9 | .0432 | .4145 | .0000 | 430.26 | 45.32 |
| 74.4 | 3.30 | 1102.0 | 819.3 | 949.6 | .0419 | .4059 | .0000 | 430.11 | 46.45 |
| 75.5 | 3.35 | 1113.3 | 850.5 | 966.9 | .0407 | .3979 | .0000 | 429.96 | 47.51 |
| 76.7 | 3.40 | 1123.8 | 882.6 | 989.7 | .0395 | .3902 | .0000 | 429.81 | 48.52 |
| 77.8 | 3.45 | 1133.9 | 914.1 | 1010.5 | .0382 | .3830 | .0000 | 429.65 | 49.48 |
| 78.9 | 3.50 | 1143.9 | 941.6 | 1027.8 | .0369 | .3760 | .0000 | 429.47 | 50.40 |
| 80.0 | 3.55 | 1153.0 | 966.0 | 1043.8 | .0356 | .3693 | .0000 | 429.27 | 51.28 |
| 81.1 | 3.60 | 1161.8 | 988.0 | 1058.2 | .0341 | .3628 | .0000 | 429.06 | 52.14 |
| 82.2 | 3.65 | 1170.8 | 1007.7 | 1071.4 | .0327 | .3565 | .0000 | 428.84 | 52.97 |
| 83.4 | 3.69 | 1179.0 | 1025.6 | 1083.8 | .0313 | .3504 | .0000 | 428.61 | 53.77 |
| 84.5 | 3.74 | 1187.9 | 1041.8 | 1094.9 | .0298 | .3445 | .0000 | 428.38 | 54.56 |
| 85.6 | 3.79 | 1195.8 | 1056.6 | 1105.8 | .0283 | .3387 | .0000 | 428.14 | 55.32 |
| 86.7 | 3.84 | 1204.6 | 1071.2 | 1115.5 | .0269 | .3330 | .0000 | 427.91 | 56.06 |
| 87.8 | 3.89 | 1212.3 | 1085.4 | 1124.8 | .0255 | .3275 | .0000 | 427.68 | 56.79 |
| 88.9 | 3.94 | 1219.9 | 1098.1 | 1133.5 | .0241 | .3221 | .0000 | 427.45 | 57.50 |
| 90.1 | 3.99 | 1227.5 | 1109.5 | 1141.4 | .0227 | .3168 | .0000 | 427.23 | 58.20 |
| 91.2 | 4.04 | 1235.0 | 1119.7 | 1148.6 | .0214 | .3117 | .0000 | 427.01 | 58.88 |
| 92.3 | 4.09 | 1242.5 | 1128.9 | 1155.3 | .0201 | .3066 | .0000 | 426.81 | 59.55 |
| 93.4 | 4.14 | 1250.0 | 1137.1 | 1161.5 | .0188 | .3016 | .0000 | 426.61 | 60.21 |
| 94.5 | 4.19 | 1257.6 | 1144.5 | 1167.2 | .0176 | .2967 | .0000 | 426.42 | 60.85 |
| 95.6 | 4.24 | 1265.1 | 1151.2 | 1172.7 | .0165 | .2919 | .0000 | 426.24 | 61.49 |
| 96.8 | 4.29 | 1272.7 | 1157.3 | 1177.8 | .0154 | .2872 | .0000 | 426.06 | 62.11 |
| 97.9 | 4.34 | 1280.3 | 1162.9 | 1182.7 | .0143 | .2826 | .0000 | 425.90 | 62.72 |
| 99.0 | 4.39 | 1288.0 | 1168.1 | 1187.5 | .0133 | .2780 | .0000 | 425.74 | 63.32 |
| 100.1 | 4.44 | 1295.7 | 1173.0 | 1192.2 | .0123 | .2736 | .0000 | 425.59 | 63.91 |
| 101.2 | 4.49 | 1303.5 | 1177.6 | 1196.8 | .0113 | .2691 | .0000 | 425.45 | 64.49 |
| 102.3 | 4.54 | 1311.3 | 1182.0 | 1201.5 | .0105 | .2648 | .0000 | 425.32 | 65.07 |
| 103.4 | 4.59 | 1319.2 | 1186.3 | 1206.1 | .0096 | .2605 | .0000 | 425.20 | 65.63 |
| 104.6 | 4.63 | 1327.2 | 1190.5 | 1210.8 | .0088 | .2563 | .0000 | 425.08 | 66.18 |
| 105.7 | 4.68 | 1335.2 | 1194.7 | 1215.6 | .0080 | .2522 | .0000 | 424.98 | 66.73 |
| 106.8 | 4.73 | 1343.2 | 1198.9 | 1220.6 | .0073 | .2481 | .0000 | 424.88 | 67.27 |
| 107.9 | 4.78 | 1351.3 | 1203.1 | 1225.6 | .0066 | .2441 | .0000 | 424.79 | 67.80 |
| 109.0 | 4.83 | 1359.5 | 1207.5 | 1230.9 | .0060 | .2401 | .0000 | 424.71 | 68.32 |
| 110.1 | 4.88 | 1367.6 | 1211.9 | 1236.3 | .0054 | .2362 | .0000 | 424.64 | 68.84 |
| 111.3 | 4.93 | 1375.9 | 1216.5 | 1242.0 | .0048 | .2324 | .0000 | 424.58 | 69.35 |
| 112.4 | 4.98 | 1384.1 | 1221.2 | 1247.9 | .0043 | .2286 | .0000 | 424.52 | 69.85 |
| 113.5 | 5.03 | 1392.4 | 1226.2 | 1254.1 | .0038 | .2248 | .0000 | 424.47 | 70.34 |
| 114.6 | 5.08 | 1400.6 | 1231.3 | 1260.5 | .0033 | .2211 | .0000 | 424.43 | 70.83 |
| 115.7 | 5.13 | 1409.0 | 1236.7 | 1267.2 | .0029 | .2175 | .0000 | 424.39 | 71.31 |
| 116.8 | 5.18 | 1417.2 | 1242.4 | 1274.2 | .0025 | .2139 | .0000 | 424.37 | 71.79 |
| 118.0 | 5.23 | 1425.6 | 1248.3 | 1281.6 | .0022 | .2103 | .0000 | 424.35 | 72.25 |
| 119.1 | 5.28 | 1433.8 | 1254.6 | 1289.2 | .0019 | .2068 | .0000 | 424.33 | 72.72 |
| 120.2 | 5.33 | 1442.1 | 1261.2 | 1297.2 | .0016 | .2034 | .0000 | 424.33 | 73.17 |
| 121.3 | 5.38 | 1450.3 | 1268.2 | 1305.5 | .0013 | .2000 | .0000 | 424.32 | 73.62 |
| 122.4 | 5.43 | 1458.4 | 1275.6 | 1314.2 | .0011 | .1966 | .0000 | 424.33 | 74.06 |
| 123.5 | 5.48 | 1466.4 | 1283.4 | 1323.1 | .0009 | .1933 | .0000 | 424.34 | 74.50 |
| 124.7 | 5.53 | 1474.3 | 1291.6 | 1332.5 | .0007 | .1900 | .0000 | 424.35 | 74.94 |
| 125.8 | 5.57 | 1482.0 | 1300.2 | 1342.0 | .0006 | .1868 | .0000 | 424.37 | 75.36 |
| 126.9 | 5.62 | 1489.7 | 1309.2 | 1352.0 | .0005 | .1836 | .0000 | 424.39 | 75.78 |
| 128.0 | 5.67 | 1497.2 | 1318.6 | 1362.0 | .0004 | .1804 | .0000 | 424.42 | 76.20 |

ZONE: KILN

SOLIDS LINEAR VELOCITY/ (in/min) = 70.154

| Z/ ft | t/ min | T-Bed/ F (Ave) | T-Layer/ F (Core) | T-Air/ F (Free) | X-Flux (Ave) | X-Fe3O4 (Ave) | X-H2O (Ave) | Solids/ LT/hr | C-Fe3O4 % cnvrnsn |
|----------|-----------|-------------------|----------------------|--------------------|-----------------|------------------|----------------|------------------|----------------------|
| 130.6 | 6.12 | 1499.5 | 1496.1 | 2150.0 | .0000 | .1800 | .0000 | 424.35 | 76.25 |
| 133.2 | 6.57 | 1503.2 | 1496.3 | 2161.0 | .0000 | .1796 | .0000 | 424.36 | 76.31 |
| 135.9 | 7.02 | 1506.9 | 1496.7 | 2172.1 | .0000 | .1792 | .0000 | 424.36 | 76.36 |
| 138.5 | 7.47 | 1510.8 | 1497.3 | 2183.2 | .0000 | .1788 | .0000 | 424.37 | 76.42 |
| 141.1 | 7.91 | 1514.8 | 1498.0 | 2194.5 | .0000 | .1783 | .0000 | 424.38 | 76.47 |
| 143.7 | 8.36 | 1519.0 | 1498.9 | 2205.8 | .0000 | .1779 | .0000 | 424.38 | 76.53 |
| 146.3 | 8.81 | 1523.2 | 1499.9 | 2217.2 | .0000 | .1775 | .0000 | 424.39 | 76.58 |
| 149.0 | 9.26 | 1527.6 | 1501.1 | 2228.7 | .0000 | .1771 | .0000 | 424.40 | 76.64 |
| 151.6 | 9.71 | 1532.2 | 1502.4 | 2240.1 | .0000 | .1767 | .0000 | 424.41 | 76.69 |
| 154.2 | 10.16 | 1536.9 | 1503.9 | 2251.6 | .0000 | .1762 | .0000 | 424.41 | 76.75 |
| 156.8 | 10.60 | 1541.8 | 1505.5 | 2263.0 | .0000 | .1758 | .0000 | 424.42 | 76.81 |
| 159.4 | 11.05 | 1546.9 | 1507.2 | 2274.3 | .0000 | .1754 | .0000 | 424.43 | 76.86 |
| 162.1 | 11.50 | 1552.2 | 1509.1 | 2285.5 | .0000 | .1750 | .0000 | 424.43 | 76.92 |
| 164.7 | 11.95 | 1557.8 | 1511.2 | 2296.5 | .0000 | .1745 | .0000 | 424.44 | 76.98 |
| 167.3 | 12.40 | 1563.7 | 1513.4 | 2307.3 | .0000 | .1741 | .0000 | 424.45 | 77.03 |
| 169.9 | 12.84 | 1569.8 | 1515.9 | 2317.8 | .0000 | .1737 | .0000 | 424.45 | 77.09 |
| 172.5 | 13.29 | 1576.4 | 1518.4 | 2328.0 | .0000 | .1732 | .0000 | 424.46 | 77.15 |
| 175.2 | 13.74 | 1583.3 | 1521.2 | 2337.6 | .0000 | .1728 | .0000 | 424.47 | 77.21 |
| 177.8 | 14.19 | 1590.7 | 1524.2 | 2346.7 | .0000 | .1723 | .0000 | 424.48 | 77.27 |
| 180.4 | 14.64 | 1598.7 | 1527.3 | 2355.1 | .0000 | .1719 | .0000 | 424.48 | 77.33 |
| 183.0 | 15.08 | 1607.3 | 1530.8 | 2362.6 | .0000 | .1714 | .0000 | 424.49 | 77.39 |
| 185.6 | 15.53 | 1616.7 | 1534.4 | 2369.0 | .0000 | .1709 | .0000 | 424.50 | 77.45 |
| 188.3 | 15.98 | 1627.1 | 1538.4 | 2374.0 | .0000 | .1705 | .0000 | 424.51 | 77.51 |
| 190.9 | 16.43 | 1638.7 | 1542.6 | 2377.4 | .0000 | .1700 | .0000 | 424.51 | 77.57 |
| 193.5 | 16.88 | 1651.8 | 1547.3 | 2378.7 | .0000 | .1695 | .0000 | 424.52 | 77.64 |
| 196.1 | 17.33 | 1666.8 | 1552.4 | 2377.4 | .0000 | .1690 | .0000 | 424.53 | 77.70 |
| 198.7 | 17.77 | 1684.2 | 1557.9 | 2372.8 | .0000 | .1685 | .0000 | 424.54 | 77.76 |
| 201.4 | 18.22 | 1705.1 | 1564.1 | 2363.9 | .0000 | .1680 | .0000 | 424.55 | 77.83 |
| 204.0 | 18.67 | 1730.6 | 1571.1 | 2349.6 | .0000 | .1675 | .0000 | 424.55 | 77.90 |
| 206.6 | 19.12 | 1763.0 | 1579.1 | 2327.9 | .0000 | .1670 | .0000 | 424.56 | 77.96 |
| 209.2 | 19.57 | 1802.8 | 1588.5 | 2296.2 | .0000 | .1665 | .0000 | 424.57 | 78.03 |
| 211.8 | 20.01 | 1841.8 | 1599.1 | 2297.2 | .0000 | .1660 | .0000 | 424.58 | 78.10 |
| 214.5 | 20.46 | 1879.8 | 1610.9 | 2298.0 | .0000 | .1655 | .0000 | 424.59 | 78.17 |
| 217.1 | 20.91 | 1916.5 | 1623.8 | 2298.6 | .0000 | .1650 | .0000 | 424.60 | 78.23 |
| 219.7 | 21.36 | 1952.1 | 1637.6 | 2299.1 | .0000 | .1645 | .0000 | 424.60 | 78.29 |
| 222.3 | 21.81 | 1986.3 | 1652.3 | 2299.4 | .0000 | .1641 | .0000 | 424.61 | 78.36 |
| 224.9 | 22.26 | 2019.3 | 1667.8 | 2299.6 | .0000 | .1636 | .0000 | 424.62 | 78.42 |
| 227.6 | 22.70 | 2050.8 | 1684.0 | 2299.6 | .0000 | .1632 | .0000 | 424.63 | 78.48 |
| 230.2 | 23.15 | 2080.8 | 1700.8 | 2299.6 | .0000 | .1627 | .0000 | 424.63 | 78.53 |
| 232.8 | 23.60 | 2109.3 | 1718.1 | 2299.4 | .0000 | .1623 | .0000 | 424.64 | 78.59 |
| 235.4 | 24.05 | 2136.1 | 1735.8 | 2299.2 | .0000 | .1619 | .0000 | 424.65 | 78.64 |
| 238.0 | 24.50 | 2161.0 | 1753.8 | 2298.9 | .0000 | .1615 | .0000 | 424.65 | 78.69 |
| 240.7 | 24.94 | 2183.6 | 1772.1 | 2298.5 | .0000 | .1612 | .0000 | 424.66 | 78.74 |
| 243.3 | 25.39 | 2203.5 | 1790.5 | 2298.1 | .0000 | .1608 | .0000 | 424.66 | 78.78 |
| 245.9 | 25.84 | 2219.9 | 1808.8 | 2297.7 | .0000 | .1605 | .0000 | 424.67 | 78.82 |
| 248.5 | 26.29 | 2232.2 | 1826.9 | 2297.3 | .0000 | .1602 | .0000 | 424.67 | 78.86 |
| 251.1 | 26.74 | 2239.4 | 1844.6 | 2296.8 | .0000 | .1599 | .0000 | 424.68 | 78.90 |
| 253.8 | 27.19 | 2241.3 | 1861.7 | 2296.5 | .0000 | .1597 | .0000 | 424.68 | 78.94 |
| 256.4 | 27.63 | 2238.3 | 1878.0 | 2296.2 | .0000 | .1593 | .0000 | 424.69 | 78.98 |
| 259.0 | 28.08 | 2231.8 | 1893.3 | 2296.0 | .0000 | .1590 | .0000 | 424.69 | 79.02 |

*** KILN TEMPERATURE PROFILES ***

| Z/ ft | Time/ min | T-Flame/ F | T-Air/ F | T-Bed/ F (Ave) | T-Mantle/ F | T-Core/ F | T-Wall/ F |
|----------|--------------|---------------|-------------|-------------------|----------------|--------------|--------------|
| 2.6 | .45 | 1865.3 | 2150.0 | 1499.5 | 1501.2 | 1496.1 | 1619.8 |
| 5.2 | .90 | 1874.4 | 2161.0 | 1503.2 | 1506.6 | 1496.3 | 1628.3 |
| 7.9 | 1.34 | 1883.9 | 2172.1 | 1506.9 | 1512.1 | 1496.7 | 1637.0 |
| 10.5 | 1.79 | 1893.7 | 2183.2 | 1510.8 | 1517.6 | 1497.3 | 1646.1 |
| 13.1 | 2.24 | 1904.1 | 2194.5 | 1514.8 | 1523.3 | 1498.0 | 1655.6 |
| 15.7 | 2.69 | 1914.9 | 2205.8 | 1519.0 | 1529.1 | 1498.9 | 1665.5 |
| 18.3 | 3.14 | 1926.3 | 2217.2 | 1523.2 | 1535.0 | 1499.9 | 1675.9 |
| 21.0 | 3.59 | 1938.3 | 2228.7 | 1527.6 | 1541.0 | 1501.1 | 1686.8 |
| 23.6 | 4.03 | 1951.1 | 2240.1 | 1532.2 | 1547.2 | 1502.4 | 1698.3 |
| 26.2 | 4.48 | 1964.6 | 2251.6 | 1536.9 | 1553.6 | 1503.9 | 1710.5 |
| 28.8 | 4.93 | 1979.1 | 2263.0 | 1541.8 | 1560.2 | 1505.5 | 1723.5 |
| 31.4 | 5.38 | 1994.6 | 2274.3 | 1546.9 | 1567.0 | 1507.2 | 1737.4 |
| 34.1 | 5.83 | 2011.3 | 2285.5 | 1552.2 | 1574.1 | 1509.1 | 1752.4 |
| 36.7 | 6.27 | 2029.4 | 2296.5 | 1557.8 | 1581.4 | 1511.2 | 1768.5 |
| 39.3 | 6.72 | 2049.1 | 2307.3 | 1563.7 | 1589.1 | 1513.4 | 1786.1 |
| 41.9 | 7.17 | 2070.7 | 2317.8 | 1569.8 | 1597.2 | 1515.9 | 1805.3 |
| 44.5 | 7.62 | 2094.4 | 2328.0 | 1576.4 | 1605.8 | 1518.4 | 1826.4 |
| 47.2 | 8.07 | 2120.7 | 2337.6 | 1583.3 | 1614.8 | 1521.2 | 1849.9 |
| 49.8 | 8.51 | 2150.0 | 2346.7 | 1590.7 | 1624.5 | 1524.2 | 1876.1 |
| 52.4 | 8.96 | 2182.9 | 2355.1 | 1598.7 | 1634.9 | 1527.3 | 1905.7 |
| 55.0 | 9.41 | 2220.0 | 2362.6 | 1607.3 | 1646.2 | 1530.8 | 1939.3 |
| 57.6 | 9.86 | 2262.4 | 2369.0 | 1616.7 | 1658.5 | 1534.4 | 1977.7 |
| 60.3 | 10.31 | 2310.7 | 2374.0 | 1627.1 | 1672.2 | 1538.4 | 2022.0 |
| 62.9 | 10.76 | 2366.3 | 2377.4 | 1638.7 | 1687.5 | 1542.6 | 2073.4 |
| 65.5 | 11.20 | 2430.9 | 2378.7 | 1651.8 | 1704.8 | 1547.3 | 2133.9 |
| 68.1 | 11.65 | 2506.7 | 2377.4 | 1666.8 | 1724.8 | 1552.4 | 2205.9 |
| 70.7 | 12.10 | 2596.6 | 2372.8 | 1684.2 | 1748.2 | 1557.9 | 2292.7 |
| 73.4 | 12.55 | 2704.9 | 2363.9 | 1705.1 | 1776.3 | 1564.1 | 2399.3 |
| 76.0 | 13.00 | 2837.5 | 2349.6 | 1730.6 | 1811.0 | 1571.1 | 2532.7 |
| 78.6 | 13.44 | 3003.9 | 2327.9 | 1763.0 | 1855.4 | 1579.1 | 2704.6 |
| 81.2 | 13.89 | 3219.5 | 2296.2 | 1802.8 | 1909.9 | 1588.5 | 2820.2 |
| 83.8 | 14.34 | 3229.9 | 2297.2 | 1841.8 | 1962.4 | 1599.1 | 2820.9 |
| 86.5 | 14.79 | 3229.6 | 2298.0 | 1879.8 | 2012.5 | 1610.9 | 2821.5 |
| 89.1 | 15.24 | 3229.1 | 2298.6 | 1916.5 | 2060.2 | 1623.8 | 2822.0 |
| 91.7 | 15.69 | 3228.2 | 2299.1 | 1952.1 | 2105.6 | 1637.6 | 2822.3 |
| 94.3 | 16.13 | 3226.8 | 2299.4 | 1986.3 | 2148.6 | 1652.3 | 2822.0 |
| 96.9 | 16.58 | 3224.7 | 2299.6 | 2019.3 | 2189.2 | 1667.8 | 2821.0 |
| 99.6 | 17.03 | 3221.4 | 2299.6 | 2050.8 | 2227.6 | 1684.0 | 2818.8 |
| 102.2 | 17.48 | 3216.6 | 2299.6 | 2080.8 | 2263.5 | 1700.8 | 2815.1 |
| 104.8 | 17.93 | 3209.5 | 2299.4 | 2109.3 | 2297.0 | 1718.1 | 2809.1 |
| 107.4 | 18.37 | 3198.7 | 2299.2 | 2136.1 | 2327.9 | 1735.8 | 2799.5 |
| 110.0 | 18.82 | 3182.4 | 2298.9 | 2161.0 | 2356.0 | 1753.8 | 2784.6 |
| 112.7 | 19.27 | 3157.3 | 2298.5 | 2183.6 | 2380.7 | 1772.1 | 2761.7 |
| 115.3 | 19.72 | 3118.0 | 2298.1 | 2203.5 | 2401.4 | 1790.5 | 2726.5 |
| 117.9 | 20.17 | 3056.3 | 2297.7 | 2219.9 | 2417.1 | 1808.8 | 2673.6 |
| 120.5 | 20.62 | 2959.9 | 2297.3 | 2232.2 | 2426.8 | 1826.9 | 2596.6 |
| 123.1 | 21.06 | 2813.0 | 2296.8 | 2239.4 | 2429.2 | 1844.6 | 2492.4 |
| 125.8 | 21.51 | 2600.1 | 2296.5 | 2241.3 | 2423.9 | 1861.7 | 2367.4 |
| 128.4 | 21.96 | 2313.5 | 2296.2 | 2238.3 | 2411.8 | 1878.0 | 2242.0 |
| 131.0 | 22.41 | 1958.2 | 2296.0 | 2231.8 | 2395.1 | 1893.3 | 2141.5 |

*** BED-LAYER PROFILES:
 TOP LAYER i=1 ; BOTTOM LAYER i=20 ***

END-ZONE: DD1

| i | T-Air/ F | T-Layer/ F | X-Flux/ lb/lb | X-Fe3O4/ lb/lb | X-H2O/ lb/lb |
|----|-------------|---------------|------------------|-------------------|-----------------|
| 1 | 840.1 | 884.1 | .0505 | .4186 | .0000 |
| 2 | 853.9 | 898.2 | .0512 | .4422 | .0000 |
| 3 | 867.3 | 909.6 | .0514 | .4680 | .0000 |
| 4 | 878.7 | 914.7 | .0510 | .4950 | .0000 |
| 5 | 886.1 | 909.7 | .0493 | .5245 | .0000 |
| 6 | 888.7 | 896.6 | .0515 | .5575 | .0000 |
| 7 | 882.7 | 864.1 | .0512 | .5971 | .0000 |
| 8 | 865.2 | 809.8 | .0529 | .6477 | .0000 |
| 9 | 837.6 | 750.1 | .0624 | .7126 | .0000 |
| 10 | 800.3 | 681.2 | .0666 | .7491 | .0000 |
| 11 | 757.9 | 621.6 | .0682 | .7567 | .0000 |
| 12 | 710.5 | 555.9 | .0688 | .7579 | .0000 |
| 13 | 656.6 | 478.6 | .0690 | .7580 | .0000 |
| 14 | 594.7 | 386.6 | .0690 | .7580 | .0000 |
| 15 | 522.8 | 276.7 | .0690 | .7580 | .0000 |
| 16 | 437.9 | 139.4 | .0690 | .7580 | .0000 |
| 17 | 372.7 | 135.3 | .0690 | .7580 | .0210 |
| 18 | 323.6 | 134.8 | .0690 | .7580 | .0373 |
| 19 | 285.9 | 134.3 | .0690 | .7580 | .0500 |
| 20 | 256.5 | 133.9 | .0690 | .7580 | .0600 |

END-ZONE: DD2

| i | T-Air/ F | T-Layer/ F | X-Flux/ lb/lb | X-Fe3O4/ lb/lb | X-H2O/ lb/lb |
|----|-------------|---------------|------------------|-------------------|-----------------|
| 1 | 1172.3 | 1164.3 | .0350 | .2623 | .0000 |
| 2 | 1169.5 | 1161.0 | .0366 | .2753 | .0000 |
| 3 | 1166.6 | 1157.8 | .0375 | .2886 | .0000 |
| 4 | 1163.8 | 1155.2 | .0379 | .3016 | .0000 |
| 5 | 1161.2 | 1153.3 | .0372 | .3145 | .0000 |
| 6 | 1158.6 | 1150.7 | .0395 | .3275 | .0000 |
| 7 | 1156.2 | 1148.7 | .0400 | .3408 | .0000 |
| 8 | 1153.8 | 1146.5 | .0406 | .3547 | .0000 |
| 9 | 1151.3 | 1143.5 | .0423 | .3689 | .0000 |
| 10 | 1148.4 | 1139.5 | .0435 | .3844 | .0000 |
| 11 | 1144.8 | 1133.7 | .0448 | .4015 | .0000 |
| 12 | 1139.9 | 1125.1 | .0450 | .4201 | .0000 |
| 13 | 1133.1 | 1112.0 | .0475 | .4406 | .0000 |
| 14 | 1123.2 | 1092.7 | .0461 | .4632 | .0000 |
| 15 | 1109.4 | 1067.1 | .0501 | .4885 | .0000 |
| 16 | 1090.8 | 1033.5 | .0494 | .5174 | .0000 |
| 17 | 1064.6 | 983.2 | .0471 | .5514 | .0000 |
| 18 | 1031.0 | 926.6 | .0509 | .5930 | .0000 |
| 19 | 986.3 | 845.7 | .0549 | .6491 | .0000 |
| 20 | 930.1 | 754.7 | .0651 | .7244 | .0000 |

| END-ZONE: PH | | | | | |
|--------------|-------------|---------------|------------------|-------------------|-----------------|
| i | T-Air/ F | T-Layer/ F | X-Flux/ lb/lb | X-Fe3O4/ lb/lb | X-H2O/ lb/lb |
| 1 | 1592.7 | 1602.5 | .0000 | .1060 | .0000 |
| 2 | 1596.6 | 1604.5 | .0000 | .1131 | .0000 |
| 3 | 1599.3 | 1604.8 | .0000 | .1204 | .0000 |
| 4 | 1600.5 | 1602.9 | .0000 | .1274 | .0000 |
| 5 | 1599.8 | 1598.4 | .0000 | .1345 | .0000 |
| 6 | 1596.9 | 1591.0 | .0000 | .1414 | .0000 |
| 7 | 1591.7 | 1580.9 | .0000 | .1486 | .0000 |
| 8 | 1584.0 | 1568.1 | .0000 | .1558 | .0000 |
| 9 | 1573.8 | 1552.7 | .0000 | .1631 | .0000 |
| 10 | 1561.1 | 1535.0 | .0000 | .1709 | .0000 |
| 11 | 1546.2 | 1515.4 | .0000 | .1791 | .0000 |
| 12 | 1529.4 | 1494.5 | .0000 | .1876 | .0000 |
| 13 | 1510.8 | 1472.3 | .0000 | .1966 | .0000 |
| 14 | 1490.9 | 1449.6 | .0000 | .2060 | .0000 |
| 15 | 1469.9 | 1425.9 | .0001 | .2157 | .0000 |
| 16 | 1448.2 | 1402.7 | .0002 | .2260 | .0000 |
| 17 | 1426.4 | 1380.4 | .0005 | .2367 | .0000 |
| 18 | 1404.1 | 1357.1 | .0011 | .2479 | .0000 |
| 19 | 1382.4 | 1336.2 | .0020 | .2598 | .0000 |
| 20 | 1362.0 | 1318.6 | .0031 | .2717 | .0000 |

END-ZONE: KILN * NOT APPLICABLE *

*** GAS FLOW AND TEMPERATURE SUMMARY ***

| TO BED | Volume Flow/ SCFM | Mass Flow/ lb/min | T/F |
|--------|----------------------|----------------------|--------|
| DD1 | 222133.9 | 17799.6 | 826.1 |
| DD2 | 110478.1 | 8865.3 | 1181.8 |
| PH | 143414.7 | 11369.4 | 1588.2 |
| KILN | 76041.2 | 6101.9 | 2295.9 |

| FROM ZONE | Volume Flow/ SCFM | Mass Flow/ lb/min | T/F |
|-----------|----------------------|----------------------|--------|
| DD1 | 249930.5 | 19206.1 | 164.1 |
| DD2 | 112973.7 | 9011.1 | 553.2 |
| PH | 155710.2 | 12469.6 | 1109.4 |
| KILN | 81992.8 | 6479.1 | 2038.0 |

*** OVERALL GAS PHASE MATERIAL BALANCE (SCFM) ***

| | |
|---------------------|----------|
| Secondary Air | .151E+06 |
| + Fuel/Prim Air | .818E+04 |
| + Net Leakage | .172E+06 |
| + CO2 (LOI) | .473E+04 |
| + H2O (Drying) | .309E+05 |
| - O2 (Oxidation) | .409E+04 |
| ----- | |
| TOTAL NET GAS IN = | .363E+06 |
| TOTAL NET GAS OUT = | .363E+06 |

*** GAS COMPOSITION (%) ***

| ZONE | | CO2 | H2O | O2 | N2 | CH4 |
|------|-------------|-----|------|------|------|-----|
| DD1 | (To Bed) | 3.1 | 3.9 | 16.1 | 76.8 | .0 |
| | (From Zone) | 3.0 | 14.6 | 14.1 | 68.3 | .0 |
| DD2 | (To Bed) | .0 | .4 | 20.9 | 78.7 | .0 |
| | (From Zone) | 1.0 | 3.0 | 19.0 | 77.0 | .0 |
| PH | (To Bed) | 2.8 | 5.8 | 14.9 | 76.5 | .0 |
| | (From Zone) | 4.5 | 5.4 | 14.1 | 76.0 | .0 |
| KILN | (To Bed) | .0 | .4 | 20.9 | 78.7 | .0 |
| | (From Zone) | 3.5 | 7.3 | 13.2 | 76.0 | .0 |




Figure 2.1. Block diagram of zone and gas distribution.




Figure 2.2. Diagram of solid layers in model of pellet bed.




Figure 2.3. Drying algorithm




Figure 2.4. Medusa model solution algorithm.




Figure 2.5. Graphical User Interface for Medusa: File Manager.




Figure 2.6. Graphical User Interface for Medusa: Pellet Bed.




Figure 2.7. Graphical User Interface: Furnace Zones I.




Figure 2.8. Graphical User Interface: Furnace Zones II.

| <i>Rotary Kiln Parameters</i> | | | |
|-------------------------------|--------------------------------------|------------------|---------------------------------------|
| Length = | <input type="text" value="131"/> ft | Rotation Speed = | <input type="text" value="1.14"/> rpm |
| Inside Diameter = | <input type="text" value="20"/> ft | Slope = | <input type="text" value="3"/> deg |
| Outside Diameter = | <input type="text" value="21.3"/> ft | | |

| <i>Ported Kiln Parameters</i> | <i>Ported Gas Composition (Volume %)</i> |
|-----------------------------------------------------------|------------------------------------------------------------------------------|
| Feed Gas Flow = <input type="text" value="0"/> scfm | CO ₂ mole = <input type="text" value="0"/> % |
| Feed Temperature = <input type="text" value="70"/> °F | H ₂ O Mole = <input type="text" value="0"/> % |
| Start Porting at Div. <input type="text" value="101"/> ▲▼ | O ₂ Mole = <input type="text" value="21"/> % |
| End Porting at Div. <input type="text" value="102"/> ▲▼ | N ₂ Mole = <input type="text" value="79"/> % |
| <i>Note:</i> <input type="button" value="OK"/> | CH ₄ Mole = <input type="text" value="0"/> % |
| Kiln has 100 divisions. | Total = <input type="text" value="100"/> % <input type="button" value="OK"/> |
| Requires End Div > Start Div. | <i>Note:</i> Must sum to 100% |

Figure 2.9. Graphical User Interface for Medusa: Rotary Kiln.




Figure 2.12. Graphical User Interface for Medusa: Gas Distribution.




Figure 2.13. Solids temperature-position profiles.




Figure 2.14. Solids temperature-residence time profiles.




Figure 2.15. Average pellet composition profiles.

3 Model Validation and Process Analysis

| <u>Page No</u> | <u>Text Headings</u> | <u>Tables</u> | <u>Figures</u> | <u>Appendix</u> |
|-----------------------|-------------------------------------------------------------|----------------------|-----------------------|------------------------|
| 3-7 | 3.1 Introduction | | | |
| | 3.1.1 Objectives | | | |
| 3-8 | 3.1.2 Model Description | | | |
| | 3.1.2.1 Simulation Units | | | I |
| | 3.1.2.2 MEDUSA | | | |
| | 3.1.2.3 CFD Cooler | | 1 | |
| | 3.1.2.3.1 Boundary Conditions | | | |
| 3-9 | 3.1.2.3.2 Bed Pressure Drop Resistance | | 2, 3 | |
| | 3.1.2.4 MEDUSA/CFD Hybrid | | | |
| | 3.1.2.5 Cooler Schematic | | | |
| 3-10 | 3.2 Model Validation | | | |
| | 3.2.1 Plant Tests | | 1 | I |
| | 3.2.1.1 Estimating Feed Rate | | 1 | |
| | 3.2.1.2 Thermocouples vs CFD Averages | | 2 | |
| | 3.2.1.3 Feed Variability | | | |
| 3-11 | 3.2.1.4 Simulation Tuning - Variable Description | | 3 | |
| | 3.2.1.4.1 Magnetite Entering Cooler | | | |
| | 3.2.1.4.2 Pellet Feed Rate to Cooler | | | |
| | 3.2.1.4.3 Kiln Solids Discharge Temperature | | | |
| | 3.2.1.4.4 Cooler Wind Box Leakage | | | |
| | 3.2.1.4.5 Wind Box Damper | | | |
| | 3.2.2 MEDUSA File Input/Output | | | |
| 3-12 | 3.2.3 Section Summary | | | |
| | 3.2.4 CFD Cooler Model Validation - Test by Test Comparison | | | |
| | 3.2.4.1 Cooler Feed Rate | | 4 | |
| | 3.2.4.2 Kiln Discharge Solids Temperature | | 5 | |
| 3-13 | 3.2.4.3 Primary Cooling Overbed Pressure | | 6, 7 | |
| | 3.2.4.4 Primary Cooling Wind Box Pressure | | 8 | |
| | 3.2.4.5 Kiln Secondary Air Temperature | 6 | 9, 10 | |
| | 3.2.4.6 Secondary Cooling Overbed Pressure | | 11 | |
| 3-14 | 3.2.4.7 Secondary Cooling Wind Box Pressure | | 12 | |

3 Model Validation and Process Analysis

| <u>Page No</u> | <u>Text Headings</u> | <u>Tables</u> | <u>Figures</u> | <u>Appendix</u> |
|-----------------------|-------------------------------------------------------------------------|----------------------|-----------------------|------------------------|
| | 3.2.4.8 Recoup Duct Temperatures | 2 | 13-18 | |
| | 3.2.4.8.1 Recoup A Duct Thermocouple Traverse | 7 | 17 | |
| | 3.2.4.8.2 Averaged Recoup Temperature vs DD2 Overbed | | 18 | |
| 3-15 | 3.2.4.9 Recoup Duct Flows | | 19, 20 | |
| | 3.2.4.10 Cooler Vent Stack Flow and Temperature | | 21, 22 | |
| | 3.2.5 CFD Cooler Model Validation - Common Test Trends | | | |
| | 3.2.5.1 Cooler Fan Inlet Flows | | 23, 24 | |
| | 3.2.5.2 Cooler Vent Stack Flow | | 25 | |
| 3-16 | 3.2.5.3 Kiln Secondary Air Temperature | | 26 | |
| | 3.2.5.4 Recoup Temperature vs Primary Cooling Fan Flow | | 27, 28 | |
| | 3.2.5.5 Recoup Temperature vs Secondary Cooling Fan Flow | | 29-31 | |
| | 3.2.5.6 Cooler Overbed Pressure vs Cooler Fan Flow | | 32, 33 | |
| | 3.2.5.7 Preheat Overbed Pressure vs Primary Cooling Overbed Pressure | | 34 | |
| 3-17 | 3.2.5.8 Kiln Flow vs Primary Cooling Fan Flow | | 35 | |
| | 3.2.5.9 Section Summary | | | |
| | 3.2.6 MEDUSA Validation | 4 | | |
| | 3.2.6.1 Convergence Criteria | 5 | | |
| 3-18 | 3.2.6.1.1 Target Temperatures | | 36-39 | |
| | 3.2.6.1.2 Feed Rate Comparison | | 40 | |
| | 3.2.6.2 Section Summary | | | |
| 3-19 | 3.3 CFD Cooler Model - Parametric Series | 8,9 | 41 | |
| | 3.3.1 Cooler Variables and Experimental Design | | | |
| | 3.3.2 Cooler Fan Flow Series | 10 | 42-48 | |
| 3-20 | 3.3.3 First Parametric Series - Mixed Cooler Physical Layouts | 10 | | |
| | 3.3.4 Second Parametric Series - Current Cooler Baseline | 11 | | |
| | 3.3.4.1 Linear Regression - Variable Abbreviations | | 49 | |

3 Model Validation and Process Analysis

| <u>Page No</u> | <u>Text Headings</u> | <u>Tables</u> | <u>Figures</u> | <u>Appendix</u> |
|-----------------------|--------------------------------------------------------------------------|----------------------|-----------------------|------------------------|
| 3-21 | 3.3.4.2 Linear Regression - Prediction Profiles | | 49,79 | |
| 3-22 | 3.3.4.3 Current Cooler Operating Window | | | |
| 3-23 | 3.3.4.3.1 Vent Stack Temperature vs Pellet Exit Temperature | | 50 | |
| | 3.3.4.3.2 Operating Variable Constraints | | 51 | |
| | 3.3.4.3.3 Effect of Feed Rate on Operating Window | | 52 | |
| 3-24 | 3.3.6 Third Parametric Series - Cooler with Overbed Dividing Wall | 12 | 53 | |
| | 3.3.6.1 Vent Stack Temperature vs Pellet Exit Temperature | | 54 | |
| | 3.3.6.2 Operating Variable Constraints | | 55 | |
| | 3.3.6.3 Effect of Feed Rate | | 56 | |
| | 3.3.7 Section Summary | | | |
| 3-25 | 3.4 MEDUSA/CFD Hybrid Simulations | | | |
| | 3.4.1 Target Constraints | | | |
| | 3.4.2 Flow Conditions | 13,14 | | |
| | 3.4.3 Target Temperature vs Simulation Results Temperature | | 57-59 | |
| | 3.4.4 Feed Rate and Fuel Consumption Response Surfaces | 13,14 | 60-63 | |
| 3-26 | 3.4.5 Current Cooler vs Cooler with Wall Comparison | | 60,61 | |
| | 3.4.5.1 Cooler Flow vs System Feed Rate and Fuel Consumption | | 60-63 | |
| | 3.4.5.2 Preheat and Recoup Flow vs System Feed Rate and Fuel Consumption | | 62,63 | |
| 3-27 | 3.4.5.3 Least Squares Model Fitting Analysis | | 64-69 | II |
| | 3.4.6 Section Summary | | | |
| 3-28 | 3.5 Plant Validation Tests | | | |
| | 3.5.1 Project Review - Test Criteria | | | |
| | 3.5.2 Test Data Manipulation | | 70-77 | |
| | 3.5.3 Plant Cooler Flow vs Operating Window | | 78-80 | |
| 3-29 | 3.5.4 Unedited Data Observations | | 81-86 | |
| | 3.5.4.1 Process Fan Damper Position | | 87-92 | |
| 3-30 | 3.5.4.2 Process Fan Power vs Fan Damper Position | | 93,94 | |

3 Model Validation and Process Analysis

| <u>Page No</u> | <u>Text Headings</u> | <u>Tables</u> | <u>Figures</u> | <u>Appendix</u> |
|----------------|------------------------------------------------------------------------------------|---------------|----------------|-----------------|
| | 3.5.4.3 Process Fan Power vs Recoup Flow | | 95-100 | |
| | 3.5.4.4 Recoup A Flow vs Average Recoup Temperature | | 101-106 | |
| 3-31 | 3.5.4.5 Cooler Outlet Stream Temperature Oscillations | | 107-112 | |
| | 3.5.5 Section Summary | | | |
| | 3.6 Edited Plant Data | | | |
| | 3.6.1 General Statistics | | | |
| | 3.6.1.1 Estimated Feed Rate | | 113 | |
| 3-32 | 3.6.1.2 DD1 and DD2 Overbed Temperatures | | 114 | |
| | 3.6.1.3 DD1 and DD2 Overbed Pressures | | 115 | |
| | 3.6.1.4 Preheat Fan - Damper Control Thermocouples | | 116 | |
| | 3.6.1.5 Recoup A Duct Flow and Temperature | | 117 | |
| | 3.6.1.6 Average Recoup Temperature | | 118 | |
| | 3.6.1.7 Waste Gas Fan and Primary Cooling Fan Flows | | 119 | |
| 3-33 | 3.6.1.8 Secondary Cooling Fan Correction Factor and Cooling Fan Inlet Temperatures | | 120 | |
| | 3.6.1.8.1 Secondary Cooling Fan - Indicated Flow and Corrected Flow | | 121 | |
| | 3.6.1.9 Process Fan Power | | 122-123 | |
| | 3.6.1.10 Cooler Vent Stack Flow and Temperature | | 124 | |
| | 3.6.2 Data Trends - XY Format | | | |
| 3-34 | 3.6.2.1 Waste Gas Fan Power vs Waste Gas Fan Damper | | 125,126 | |
| | 3.6.2.2 DD1 Wind Box Pressure vs Waste Gas Fan Damper | | 127 | |
| | 3.6.2.3 DD1 Overbed Temperature vs Preheat Fan Inlet Temperature | | 128 | |
| | 3.6.2.4 DD1 Overbed Pressure vs Waste Gas Fan Power | | 129,130 | |
| | 3.6.2.5 Recoup A Duct Flow vs Recoup A Duct Temperature | | 131 | |
| | Recoup A Duct Flow vs Average Preheat Fan Power | | | |

3 Model Validation and Process Analysis

| <u>Page No</u> | <u>Text Headings</u> | <u>Tables</u> | <u>Figures</u> | <u>Appendix</u> |
|-----------------------|-----------------------------|--------------------------------------------------------------------------------------------------------------------|-----------------------|------------------------|
| 3-35 | 3.6.2.6 | Average Preheat Fan Power vs Preheat Fan Damper Total Preheat Fan Flow vs Preheat Fan Power | | 132 |
| | 3.6.2.7 | Preheat Overbed Pressure vs Average Preheat Fan Damper Preheat Overbed Pressure vs Average Preheat Fan Power | | 133-135 |
| | 3.6.2.8 | Primary Cooling Fan Flow vs Average Preheat Fan Power Primary Cooling Fan Flow vs Firing Hood Pressure | | 136,137 |
| | 3.6.2.9 | Kiln Exit Gas Temperature vs Cooler Flow to Kiln Kiln Discharge Solids Temperature vs Calculated Flow to Cooler | | 138 |
| 3-36 | 3.6.2.10 | Primary Cooling Fan Flow vs Primary Cooling Fan Power Secondary Cooling Fan Flow vs Secondary Cooling Fan Power | | 139,140 |
| | 3.6.2.11 | Recoup A Duct Flow vs Total Cooler Inlet Flow Recoup A Duct Temperature vs Total Cooler Inlet Flow | | 141,142 |
| | 3.6.3 | Section Summary | | |
| 3-37 | 3.7 | Plant Data Models | | |
| | 3.7.1 | Description | | |
| | 3.7.2 | Linear Regression - CFD Model Criteria | | 143-146 |
| | 3.7.2.1 | Correlation Fit | | |
| | 3.7.2.2 | Operating Window | | 80,147,148 |
| | 3.7.3 | Linear Regression - MEDUSA/CFD Hybrid | | |
| 3-38 | 3.7.3.1 | Feed Rate and Fuel Consumption Response Surfaces | | 149 |
| | 3.8 | Comparison of Plant Data Model with CFD or MEDUSA/CFD Models | | |
| | 3.8.1 | Description | | |
| | 3.8.2 | Desirability Criteria | | |
| | 3.8.3 | Secondary Cooling Overbed Pressure Correlations | | 78 |
| 3-39 | 3.8.3.1 | Secondary Cooling Overbed Pressure - CFD Current Cooler Series | | 49,150 |
| | 3.8.3.2 | Secondary Cooling Overbed Pressure - CFD Cooler with Wall Series | | 151 |
| | 3.8.3.3 | Secondary Cooling Overbed Pressure - Plant Data | | 152-154 |

3 Model Validation and Process Analysis

| <u>Page No</u> | <u>Text Headings</u> | <u>Tables</u> | <u>Figures</u> | <u>Appendix</u> |
|-----------------------|-----------------------------|------------------------------------------------------------------|-----------------------|------------------------|
| | 3.8.4 | Statistics and Prediction Profiles - Plant Data | | 155,156 |
| 3-40 | 3.8.5 | Statistics and Prediction Profiles - CFD Current Cooler Series | | 157,158 |
| | 3.8.6 | Statistics and Prediction Profiles - CFD Cooler with Wall Series | | 159,160 |
| 3-41 | 3.8.7 | Waste Gas Fan Operating Issues | | |
| 3-42 | 3.8.8 | Comparison of Plant Model to CFD and Hybrid Models | | |
| | 3.8.8.1 | Comparison with CFD Models | | |
| | 3.8.8.1.1 | Primary Cooling Overbed Pressure vs Total Cooler Flow | 161 | |
| | 3.8.8.1.2 | Kiln Secondary Air Temperature vs Total Cooler Flow | 162 | |
| | 3.8.8.1.3 | Calculated Flow to Kiln vs Total Cooler Flow | 163 | |
| 3-43 | 3.8.8.1.4 | Total Recoup Flow vs Total Cooler Flow | 164 | |
| | 3.8.8.1.5 | Averaged Recoup Temperature vs Total Cooler Flow | 165 | |
| | 3.8.8.1.6 | Vent Stack Temperature vs Total Cooler Flow | 166 | |
| | 3.8.8.1.7 | Section Summary | | |
| 3-44 | 3.8.8.2 | Comparison with Hybrid Model | | |
| | 3.8.8.2.1 | Estimated Feed Rate vs Total Cooler Flow | 167 | |
| | 3.8.8.2.2 | Calculated Flow to Kiln vs Total Cooler Flow | 168 | |
| | 3.8.8.2.3 | Fuel Consumption vs Total Cooler Flow | 169 | |
| | 3.8.8.2.4 | Section Summary | | |
| 3-45 | 3.9 | Conclusions | | |
| | 3.9.1 | General | | |
| | 3.9.2 | Specific to Minntac Line 6 | | |
| 3-46 | 3.10 | Recommendations | | |
| | 3.10.1 | General | | |
| | 3.10.2 | Specific to Minntac Line 6 | | |

3.1 Introduction

3.1.1 Objectives: This report documents the work of a two-year collaborative effort between USX-Minntac, UMD-Chemical Engineering and NRRI-CMRL. The goals of this research were twofold:

1. Develop numerical models of existing taconite induration operations.
2. Demonstrate the use of these models for process analysis and optimization.

There were four main objectives to be accomplished in successfully completing this project:

1. Install mass flow meters on Minntac Line 6 and collect operating data to validate the models.
2. Develop and validate an overall material and energy balance model called MEDUSA.
3. Develop and validate a Computational Fluid Dynamics (CFD) model of the Line 6 cooler.
4. Perform an analysis of Line 6 using these models and, if possible, propose operating changes.

This section of the report documents:

1. Initial validation of the MEDUSA and CFD models.
2. The method of analysis using the models.
3. A comparison of model predictions with plant data.
4. Trends found in the plant data collected.
5. Conclusions from the analysis.
6. Recommendations for process improvements to Minntac Line 6.

The CFD model of the cooler provided air flow and temperature information for the MEDUSA model. Ultimately, the CFD results were quantified as linear equations capable of predicting cooler outflows to the kiln, recoup duct and vent stack, based on cooler fan inlet flows. These equations were subsequently inserted into MEDUSA, allowing the user to specify only cooler fan flows, thus avoiding the task of estimating air flow splits in the cooler.

3.1.2 Model Descriptions:

3.1.2.1 Simulation Units: The reader will find both SI and English units used in this report. CFD simulations are always carried out using SI units; appropriate conversions were made to English units for comparison with plant operating data. The earlier versions of MEDUSA required SI units for direct file input, and, as a result, the tables summarizing that work appear in original format.

3.1.2.2 MEDUSA: See section two for a description of this model.

3.1.2.3 CFD Cooler: AEA Technologies Tascflow software was used to construct the model. The model is illustrated in Figure 1. It includes the kiln secondary air duct, the double vent stack system and approximately one-third of the double recoup duct assembly. The model contains 358,000 cells and requires 11-14 hours to converge, using an SGI 320 workstation, with dual P-III 500 Mhz chips and 1 GB of memory. The simulations are performed serially, but this workstation is equipped to run one simulation on each processor. Tascflow allows attachment of grids at specified interfaces, eliminating the requirement of multi-block propagation across these interfaces. The main grid consists of the cooler assembly. The attached fan inlet ducts, recoup ducts, vent stacks and kiln secondary air duct, also referred to as the parallel flow duct, are then attached to this grid. One advantage of Tascflow software is the relative ease with which grid attachments can be detached, moved and reattached. This allows ducts to be moved and evaluated, without having to re-block the grid.

3.1.2.3.1 Boundary Conditions: The boundary conditions specified for the cooler model consisted of:

| | |
|-----------------------------------------------|------------------------------------------|
| 3A fan mass flow | 10,000 - 17,000 lbs/min |
| 3B fan mass flow | 10,000 - 17,000 lbs/min |
| Cooler fan inlet temperature | 5 - 40°F |
| Cooler bed depth | 28 inches |
| Cooler bed porosity | 35% voids |
| Cooler bed bulk density | 125.3 lbs/ft ³ |
| Incoming magnetite in pellets | 16-28%wt (Fe ⁺⁺ = 4.6 - 6.9%) |
| Incoming pellet temperature | 2268°F |
| Incoming pellet rate (based on feed to grate) | 450 - 520 WLTPH grate feed |
| A total green ball magnetite content | 87%wt |

Pressures were specified at cooler outlets based on plant measurements. They were:

| | |
|-----------------------------------|------------------------------------------|
| Kiln firing hood opening | -0.73 in.H ₂ O (not measured) |
| Kiln secondary air outlet to kiln | -0.40 in.H ₂ O (not measured) |

| | |
|---------------|----------------------------------|
| Recoup A Duct | -0.9 to -1.1 in.H ₂ O |
| Recoup B Duct | -1.0 to -1.3 in.H ₂ O |

This model incorporates heat transfer and magnetite oxidation routines similar to those in the MEDUSA model to simulate heat transfer and oxidation in the cooler, based on actual fired pellet properties. Cooler speed is determined based on volumetric flow and density, and incorporated into the heat transfer equations, to simulate the effect of changes in production rate that occur in the plant. The CFD model was intended to function in a way similar to the plant cooler.

3.1.2.3.2 Bed Pressure Drop Resistance: A resistance term was determined empirically in the model to match bed pressure drop in the model with values measured in the plant during the initial validation tests. This method compared primary and secondary cooling pressures above and below the bed with CFD simulation values at corresponding locations in the grid. The factor value used was 545. Constant values as low as 480 or as high as 575 yielded pressures within the plant operating range. Once established, this factor was not changed. It represents a best fit between actual flow and estimated system leakages, production rate and bed permeability. Figure 2 shows the furnace-kiln-cooler layout, with flow and pressure sensor locations; Figure 3 provides additional cooler layout information.

It is recognized that pressures at cooler outlets vary depending on flow conditions in the process. For our purposes these pressures were maintained constant throughout the simulations, once acceptable values were established. The underlying assumption is that process fans (preheat and waste gas) will maintain these pressures. The study of outlet pressure as a variable is left as a subject for future research. The approach was to accept the mass flow measurements in the plant data as accurate and to base validation simulations on these values. Wind box leakage was determined by attempts to match the overall cooler outlet flows and temperatures. For this cooler, these leakages ranged 10 to 13% of the total input to the cooler; they were attributed to poor wind box seals. Location of the leakage was across the width of the cooler at the beginning of the primary cooling zone. In reality, this leakage occurs throughout the cooler. In an effort to keep the model analysis manageable, we did not want to test a large number of leakage variations, although this could be done at a later time.

3.1.2.4 MEDUSA/CFD Hybrid: In time, it became apparent that we could describe the CFD model results as linear equations derived from a parametric series of runs. These equations could predict the cooler outlet flows based on cooler boundary conditions. These equations were embedded into MEDUSA, so that cooler responses reflected the effects of magnetite content and feed rate, as they were optimized during the simulation. This procedure is described in detail in the MEDUSA report.

3.1.2.5 Cooler Schematic: Figure 41 shows the cooler grid with wind box numbers. Note that in the plant, numbering begins at location “A” in the figure, which is the kiln discharge point. Since this zone was not part of the model grid, numbering began at the first wind box in the model. Ducts, thermocouples and pressure sensors are also labeled. Figure 2 shows the overall furnace, kiln and cooler system, with flow sensor locations, and Figure 3 provides some additional information on the cooler layout.

3.2 Model Validation:

3.2.1 Plant Tests: Plant tests were performed on November 19, 1998; February 11, 1999; February 17, 1999; and April 19, 1999. These tests were of relatively short duration, ranging from 1 to 6 hours in length. The primary goal was to generate varied cooler operating conditions by changing 3A and 3B fan flows. Minntac personnel developed a computer program to log 91 control room readouts throughout the furnace, kiln and cooler. A list of these parameters is given in Appendix I. Table 1 briefly summarizes the dates, test times, production rates and fan settings. The data was collected and tabulated in spreadsheet form, from which averaged test conditions were generated. The actual plant data has not been provided in this report. Table 2 serves as a summary of the plant conditions and CFD simulations. It is organized chronologically.

Ideally, the plant tests should have spanned longer periods. We were continually plagued by daily upsets. These tests represent stable but short periods of operation. The long-term impact on furnace operation is clouded by the changes made to the cooler fans over these relatively short test periods. Since the first goal was to validate the cooler model, we opted to make changes in the fan flow and record the immediate results, hence the sequential times for the tests. Additional tests were conducted in February and March 2000 that spanned 24-48 hour periods of time. If feed rate remained relatively constant, we felt this approach was acceptable, since the changes in cooler airflow and temperature were essentially immediate.

3.2.1.1 Estimating Feed Rate: Estimating feed rate to the grate and ultimately the cooler is perhaps the largest single source of error. Feed rate continually cycles, and there are fluctuations in green ball moisture and pellet flux addition as well. Table 1 describes two methods used to fix feed rate for the simulations. Method one simply multiplies green ball production rate by a plant factor (0.77) to estimate production rate or feed to the cooler. Method two calculates a modified production factor by making the assumption that moisture, flux addition, and magnetite content are relatively constant and that fines removed at the grate roller feeder are variable. Method two produced plant production factor variations from 0.72 to 0.79, which appeared to yield a better fit in the simulation results than did method one.

3.2.1.2 Thermocouples vs CFD Averages: Another source for error between plant and simulation results from thermocouple readouts. The plant values given in Table 2 represent temperature at the thermocouple location. While CFD simulations can provide a corresponding point source value, averaged values at the duct outlets are reported, since these are needed in the MEDUSA runs. In Table 2, plant temperatures are provided on one row and CFD averages on the row below it in the simulation result column. For the November 19 simulations, a range of temperatures at the thermocouple location in the grid was also reported, as a check. This number was dropped from later simulations, as we found good correlation between the CFD averaged value and the plant thermocouple value.

3.2.1.3 Feed Variability: Finally, there are the fluctuations in pellet moisture, flux addition and pellet size distribution that are not recorded on-line. Our approach with these variables was to work with constant values for moisture (9.5%wt) and flux addition (8.0%wt)

and let the deviations fall where they would. Bed permeability also remained constant, although if we had the means to estimate it from plant operation, we could have varied it as well.

3.2.1.4 Simulation Tuning - Variable Description: Table 3 provides a link between the results given in Table 2 and plotted in Figures 4-35. It provides the reader with an index of exploratory boundary conditions that were varied as we tuned the CFD model. The CFD boundary conditions given in Table 2 evolved with time. Some conditions were only used once, while others were repeated for several tests. We were faced with a large number of variable combinations that could be used to alter the CFD results. Because there were limitations in the plant data collected, changing these parameters became somewhat subjective. The goal was to introduce as few variations as possible before evaluating the fit with plant tests. The conditions that were varied included:

3.2.1.4.1 Magnetite Entering Cooler: The pellet ferrous iron content was not measured for the plant tests. The range in ferrous iron was provided by Minntac, from plant sampling performed by Svedala in December, 1998. Ferrous iron ranged from 4.56 to 6.94%wt (18.9 to 28.8% wt magnetite). The CFD series ranged from 16 to 28% wt magnetite.

3.2.1.4.2 Pellet Feed Rate to Cooler: As previously mentioned, two methods of calculating feed rate to the cooler were evaluated. The first multiplied green ball production by a constant plant factor. The second modified this factor for variable plant recycle. Method two provided a better fit between the CFD simulations and the plant conditions.

3.2.1.4.3 Kiln Solids Discharge Temperature: Plant instrumentation provided a pellet surface temperature on the bed, about 15 feet upstream from the discharge point. This temperature ranged from 2252 to 2284°F. Two temperatures (2200 and 2250°F) were evaluated in the simulations; 2250°F was chosen as it was closer to the plant value.

3.2.1.4.4 Cooler Wind Box Leakage: A one-inch gap across the width of the cooler was initially used to allow wind box leakage out of the cooler in the primary cooling zone. As the simulations progressed, it was clear that down stream outlet temperatures were cold relative to the plant data, and that the primary cooling wind box pressure was too high in the simulations. This gap was ultimately increased to 3.6 inches. This leakage was taken as a point source in these simulations, however, it is more likely that it accumulates throughout the cooler.

3.2.1.4.5 Wind Box Damper: Line 6 has a movable damper installed in the wind box separating primary cooling flow from secondary cooling flow. Only one plant test was performed with the damper open, after which Minntac personnel decided to keep it closed. In the CFD model we also simulated leakage around the damper. Initially we used a 4.7-inch effective gap (across the wind box width), which was subsequently decreased to 1.7 inches. The criteria for estimating this gap was a comparison of both wind box pressures with the CFD results. The magnitude of this dimension is also influenced by bed pressure drop, and wind box leakage. It was meant to be a relative number and not absolute.

3.2.2 MEDUSA File Input/Output: Table 4 is organized in MEDUSA direct data input format; all units are SI. This table presents the base data conditions for each of the simulations.

The range in feed rate based on both methods of calculation is shown at the top. The bottom half of the table splits into two columns for each test by relative wind box leakage (low or high), which refers to the wind box gap given in Table 3 (1" or 3.6"). Target temperatures refer to the plant data for each test. Cooler inlet flows are taken from CFD simulations. Plant pressures are also presented for the furnace zones; leakages in MEDUSA were initially calculated using these pressures. Using the data as presented in Table 4, we continually adjusted leakages to hit target temperatures at the given feed rates, varying leakages from run to run. We eventually opted to follow a constant leakage basis, letting MEDUSA find the feed rate that balanced the target temperatures. Simulation results are not presented from Table 4.

Table 5 presents the final form for MEDUSA simulations. The basic inputs and target temperatures remain unchanged from Table 4. The production rates given on the last line of Table 5 are the end result of several attempts to hit target temperatures at each set of conditions. Furnace leakages remain constant for the runs given in Table 5. The reader is referred to the MEDUSA report for a detailed explanation of their calculation.

3.2.3 Validation Criteria Summary: We standardized boundary conditions when possible to keep the number of simulations manageable, without compromising simulation sensitivity or accuracy. The above parameters were used to develop a feel for the model in this phase. Leakages can be incorporated wherever they occur, but are variable, changing with maintenance policies and machine wear. The leakages remained constant in location and opening area once established. Magnetite content and feed rate were varied throughout the anticipated range to quantify their effects. In the April 1999 tests, pitot tube sampling of the recoup ducts indicated a difference in static pressure of 0.2 in.H₂O at the thermocouple locations between the two ducts. The recoup B duct averaged about 0.2 in.H₂O more negative than the recoup A duct. The April CFD simulations and the adjusted feed rate simulations take this difference into account, as do all the subsequent runs.

3.2.4 CFD Cooler Model Validation - Test by Test Comparison: The previous section provided general background regarding our validation phase and the criteria used to achieve it. We were faced with the task of limiting the number of possible variable combinations existing in the plant data. The discussion that follows will refer to plots generated from the data in Table 2. The reader is referred to Table 3 for a complete description of the variable levels used for each plotting symbol.

3.2.4.1 Cooler Feed Rate: Figure 4 compares feed rate calculation methods one and two. It can be seen that method two yields wider fluctuations in the cooler feed rate, and also shows more deviation in the April test series. If the plant scales are good indicators, then method two is more likely a better reflection of the feed entering the cooler. This method was used exclusively once the initial validation was completed.

3.2.4.2 Kiln Discharge Solids Temperature: Figure 5 shows the variation in temperature measured at the pellet surface approximately 15 feet from the kiln discharge. Two temperatures were tested in the simulations, 2200 and 2250°F. It was initially thought that the average pellet temperature within the bed would be lower, cooling as it neared the end of the kiln (basis for 2200). As the testing progressed, and down stream cooler temperatures appeared too

cold, this temperature was raised to 2250°F. If we had not been faced with so many runs in our parametric series, we would have made this another boundary condition variable and evaluated a range of three temperatures: 2215, 2250, and 2285°F.

3.2.4.3 Primary Cooling Overbed Pressure: Figures 6 and 7 compare plant overbed pressures. In Figure 6 overbed pressures tended to compare slightly better for the simulations with lower wind box out leakage, although the simulations as a whole followed the pressure trends reasonably well. The feed rate, kiln discharge pellet temperature, magnetite content and wind box leakage all affected pressure, raising the pressure as solids temperature in the bed increased.

Figure 7 plots plant primary cooling overbed pressure vs itself on the y axis, and the CFD predicted value on the y axis vs the actual plant value on the x-axis. The comparison shows that the CFD predictions are approximately 0.07 in.H₂O more negative than the plant measurement. This is mentioned now for reference and is discussed again in section 3.3.4.3. The implication is that the pressure offset must be taken into account so that plant operation under predicted CFD conditions is possible.

3.2.4.4 Primary Cooling Wind Box Pressure: Figure 8 plots wind box pressure. The fit was adjusted by varying the cross zone leakage at the wind box damper and changing the effective size of the opening for out leakage. The subtle effects of temperature variation show up as increased pressures. For the April tests there is some deviation, which may be due to an increase in bed permeability. The CFD wind box pressures were higher and the overbed pressures lower for these tests, which may be an indication that permeability in the plant bed improved, generating a smaller pressure drop relative to the previous tests.

3.2.4.5 Kiln Secondary Air Temperature: Figure 9 compares plant secondary air temperature with simulated results. The CFD values were consistently hotter and showed significantly more variation with test conditions. This comparison is perhaps the worst of all parameters compared. However, this temperature is measured by a single thermocouple extending approximately 18 inches beyond refractory in a duct location that is approximately fifteen feet across. The CFD simulations showed significant temperature variation across this duct. The simulated value reported is a mass weighted average temperature in the duct outlet; the plant value is based on the thermocouple. Initially we considered point to point comparisons of temperature, but decided to compare the CFD cross section average with the plant data. The average duct outlet temperature was considered more reliable than a localized point value. Figure 10 illustrates the temperature variation in duct cross-section at this location; the thermocouple is shown at relative scale. Table 6 shows the results of a plant test of the Line 7 parallel flow duct, which is identical to Line 6. The maximum deviation was 36°F at 38 inches from the refractory wall. This temperature range is comparable to the variation near the thermocouple location shown in Figure 10.

3.2.4.6 Secondary Cooling Overbed Pressure: This data is plotted in Figure 11. All of the variations in simulation conditions gave good correlation with the plant data for this sensor, although the simulations using the adjusted feed rate were the best. Overall, the trends in the plant data were reflected in the simulations.

3.2.4.7 Secondary Cooling Wind Box Pressure: For this sensor, the simulations matched the overall trends, see Figure 12. The fit, however, was affected by the wind box leakage and damper cross zone leakage conditions. The primary cooling wind box pressure was usually greater than secondary cooling, thus the direction of leakage across the damper was usually into secondary cooling, which contributed to the secondary cooling zone pressure variations.

3.2.4.8 Recoup Duct Temperatures: Figures 13-18 compare averaged simulated recoup duct temperatures with plant thermocouple values. The reason for increased wind box out leakage and higher kiln solids discharge temperatures can be seen in Figures 13 and 14. At low wind box leakage levels, too much air appeared to be moving through the bed, resulting in low recoup temperatures. Temperatures were raised by increasing the amount of air leaking out of the primary cooling wind box. However, in the April tests, the simulated values greatly exceeded the plant values. When the feed rates were adjusted by method two, the recoup temperatures more closely matched the plant values.

Figures 15 and 16 illustrate the variation in temperature at the thermocouple location for CFD run 1_20_0800 (Nov. 1998 Run 1). The variation near the thermocouple (box region) is compared with the plant value in Table 2. In the A duct, this range is 1290 to 1390°F, vs 1348°F plant. In the B duct, the range is 1600 to 1625°F vs 1607°F plant. When the range in temperature near the thermocouple (box area) is compared to the duct cross section average, the A duct local thermocouple region was 10 to 110°F hotter (1290-1390 vs 1280 avg), while in the B duct, the local value was 20 to 50°F colder (1600-1625 vs 1650 avg). This implies that the A duct plant thermocouple reads a temperature hotter than the true average, while the B duct thermocouple reads a temperature actually colder than the true average.

3.2.4.8.1 Recoup A Duct Thermocouple Traverse: On February 5, Minntac personnel conducted a thermocouple traverse of the Recoup A duct; they were unable to get the probe into the B duct. The results of this traverse are found in Table 7. The temperatures range from 1195°F to 1285°F, the hottest region occurring near the middle of the duct. Figure 17 is from a simulation performed as part of the parametric series. Velocity vectors show the movement of gas in the plane of the traverse, and the hot spot in this run has rotated from a 2 o'clock position in Figure 15 to a 1 o'clock position in Figure 17. It is likely that the hot spot moves with operating conditions, given the rotation in the gas stream. Experience has shown that small changes in turbulence can affect the location at which the hot spot will occur. Thus, simulations and the plant correlate on the magnitude of the temperature gradient, but the exact locations can appear slightly different.

3.2.4.8.2 Averaged Recoup Temperature vs DD2 Overbed Temperature: Figure 18 plots the average recoup temperature vs the furnace DD2 overbed temperature. For the plant data, average recoup temperature is the numerical average of the two ducts, while the CFD average is a mass weighted average of the individual duct averages. There is a clear correlation between the plant recoup average and the plant DD2 zone value, although there is an approximate drop of 300°F in these tests. The CFD averages track very closely with the plant recoup average and follow the same trend with the DD2 zone value. The intent was to

make sure that recoup temperatures tracked with furnace temperatures, which would be important when running MEDUSA.

3.2.4.9 Recoup Duct Flows: The recoup duct flow sensors were the last to be installed, and became operational for the April plant tests. The simulations indicated flow rates approximately 10 to 20% higher than reported by the instrumentation as shown in Figures 19 and 20. Several attempts were made to solicit information regarding the accuracy of these meters given the temperature gradients across them (100 - 300°F). This information was never attained. However, the simulations did seem to pick up the trends in the tests. The accuracy and reliability of these sensors further degraded with time. The reader is referred to the Minntac report section for details.

3.2.4.10 Cooler Vent Stack Flow and Temperature: Figure 21 compares plant flow with the CFD simulations. The simulations tended to be more erratic than the plant sensor. Minntac personnel monitored this meter from time to time with pitot tube traverses; they consistently reported flows 20 to 30% lower than the sensor was indicating. Their flows were comparable to the simulated data. Figure 22 plots vent stack temperature vs averaged simulated temperature. While the sensitivity seems to vary in the simulations, they appear to track with the plant trends. Changing bed permeability may be a factor in some of these variations.

3.2.5 CFD Cooler Model Validation - Common Test Trends: In the last section, simulations and plant conditions were compared by test date. The following figures and comparisons use the same data (Table 2), but present the results in relation to another process variable. In these plots, the first test (Nov. 1998 Run 1 Open Damper) was excluded, since it represents a completely different operating condition. The CFD results are classified by the damper gap (cross zone leakage 4.7" [BC-3 & 4] vs 1.7"[BC-5]), and the simulations adjusted for roll feed recycle using method 2 [BC-6] are shown separately. A linear fit was applied to the adjusted feed points, since they represent the closest fit to the plant results.

3.2.5.1 Cooler Fan Inlet Flows: Figures 23 and 24 plot wind box pressure as a function of fan flow for the two cooling zones. The simulations and the plant measurements compare favorably. In Figure 23 (3A - Primary Cooling), the CFD results appear biased, indicating slightly higher pressures at the same flow. This can be attributed to the combination of empirically determined leakage and bed resistance. In Figure 24 (3B - Secondary Cooling) the comparison is also close, however, the CFD pressures are slightly higher at lower flows, and then starting at 13,000 lbs/min, become slightly lower relative to the plant values.

3.2.5.2 Cooler Vent Stack Flow: The cooler vent stack is located near the end of the secondary cooling zone. At this stage of the investigation, it was thought that the 3B fan should have a strong influence on stack flow. Figure 25 shows an erratic relation between stack and fan in the plant data, while the CFD simulations show an increasing stack flow with increasing 3B fan flow. It will be shown in sections 3.8.3.1 and 3.8.3.3 that both fans exert an influence on stack flow in this cooler, because there is no overbed dividing wall to isolate fan flow above the pellet bed.

3.2.5.3 Kiln Secondary Air Temperature: Plant personnel indicated they typically saw an increase in kiln secondary air temperature as 3A fan flow increased. The plant data in Figure 26 does show a slight increase of 20°F over the flow range. However the CFD data indicates a significant drop in temperature, approximately 170°F over the same range. It is believed that the plant measurement is not representative of the true average temperature in the duct, and that the simulated average indicates a truer response with increasing flow. There was some discussion with Minntac to install additional thermocouples in this duct, to verify the simulations, but at this time there are no plans to do so.

3.2.5.4 Recoup Temperature vs Primary Cooling Fan Flow: Recoup A duct temperature is plotted as a function of 3A fan flow in Figure 27, while Recoup B duct temperature is plotted in Figure 28. Both figures show a decrease in temperature as 3A fan flow increases; this was expected, since more cooling is taking place upstream from the recoup outlets. In both figures, the CFD simulations demonstrated a stronger relationship (steeper slope) with flow, but the trends are similar to the plant data. The statements made earlier indicated the A duct thermocouple should read hotter than the true gas average. If the CFD value is taken as true average, then this statement is true with 3A flows greater than 13,500 lbs/min. At flows less than 13,500, the thermocouple appears to read colder than the true average. The Recoup B duct thermocouple was stated to read colder than the true gas average. Again comparing to the CFD average this statement appears to be accurate at flows up to 15,000 lbs/min on the 3A fan.

3.2.5.5 Recoup Temperature vs Secondary Cooling Fan Flow: Figures 29 and 30 are analogous to 27 and 28, showing recoup temperature as a function of 3B flow. In both ducts, plant data trends upward (increasing temperature) with increasing flow. This effect is more pronounced in the B duct (Figure 30) than in the A duct (Figure 29). The CFD simulations yield the same trends but with steeper slopes. The reader is cautioned at this point. Because of the interdependence in the cooler fans, the effects shown in these plots are not independent of each other. As the 3B fan flow increases, there is usually a corresponding decrease in 3A fan flow, because the 3A fan is controlled by pressure, and the 3B is operated in manual, and will raise pressure at the 3A control point causing the 3A to cut back. Thus, as 3B flow increases, 3A cooling has diminished, shifting more heat toward secondary cooling. Figure 31 illustrates this relation between the 3A and 3B fan flow in the plant data.

3.2.5.6 Cooler Overbed Pressure vs Cooler Fan Flow: Figure 32 plots primary cooling overbed pressure vs 3A fan flow, and Figure 33 plots secondary cooling overbed pressure vs 3B fan flow. While both fans have a combined impact, these two figures illustrate that plant data and CFD simulations follow the same trends.

3.2.5.7 Preheat Overbed Pressure vs Primary Cooling Overbed Pressure: The preheat overbed and primary cooling overbed zones are linked by the kiln and firing hood. Since the 3A fan is set to maintain a kiln firing hood pressure, Figure 34 plots the relation between preheat and primary cooling overbed pressure sensors. The plant data shows a slight trend for primary cooling overbed pressure to decrease with increasing (more positive) pressure in the preheat zone. Plotting the CFD data against the plant preheat pressure yielded the same relation. The trend is marginal, but is consistent between the CFD and plant data.

3.2.5.8 Kiln Flow vs Primary Cooling Fan Flow: Preheat fan flow was plotted as a function of 3A fan flow for the plant data in Figure 35. For the CFD simulations, the total kiln flow is plotted against the secondary y-axis (on left) as CFD Kiln Flow. This total consists of the parallel duct flow (kiln secondary air) and firing hood flow. Both data sets show close correlation, although in this case the plant slope appears slightly steeper.

3.2.5.9 Section Summary: At this point we felt confident that the CFD cooler model was tracking with the plant validation tests. The model probably could have been tuned further with regard to bed pressure drop (resistance factor) and cooler wind box leakages, but we lacked credible data on which to base further modifications. The decision was made to move on to validating MEDUSA using the information we gained from the cooler simulations.

3.2.6 MEDUSA Validation: Table 4 summarizes the data file inputs for the thirteen plant validation tests. The table is organized for direct input into MEDUSA FORTRAN files. The units are SI. Feed rates based on both methods of calculation are included. Although we favored the higher level of primary cooling wind box leakage, we also tested the lower level for the first seven plant tests. The reader will thus find two sets of air flow inputs to the cooler. These values were computed from the appropriate CFD simulations given in Table 2; the data file heading is provided in Table 4 as well.

The target variables were our criteria for evaluating the MEDUSA runs. Plant overbed pressures are tabulated for comparison purposes, because they were used to establish leakages in the system. Given below the pressures are the plant fuel rates for these tests. Fuel is shown for the kiln burner and the preheat burners. Line 6 also has a burner in the DD2 zone; we chose to ignore the burner because the fuel input was less than 7% of the total. In hindsight it is not recommended that this burner be ignored, although its impact is small. Feed composition was kept constant, as was green ball moisture. There was a lack of reliable information to justify changing composition from run to run.

We found ourselves continually adjusting the combination of furnace leakages, green ball moisture and flux addition to hit target temperatures. With this many variables, the number of combinations became unmanageable, and as a result, the fit of MEDUSA with plant conditions became subject to the user's experience. This approach has always presented a dilemma for the user, because even relatively small errors in measurement of moisture, composition, feed rate and leakage assessment can affect the mass and energy balance simulations. For this reason the results of the runs performed using the data of Table 4 have not been included..

3.2.6.1 Convergence Criteria: A constant set of leakages was determined, based on zone area and pressure. The reader is referred to the MEDUSA report for the details. Feed moisture and composition were held constant. MEDUSA was given a set of target temperatures such as preheat fan inlet and kiln solids discharge, a constant fuel flow (SMCFH), and the specified cooler outlet flows and temperatures. MEDUSA, using an optimization routine, found the feed rate that balanced the target temperatures and cooler flows. The focus was on attaining a good overall match between the simulations and a range of plant operating conditions. The specific effects of moisture, composition, and feed rate fluctuations could then be studied individually or in combination by the user, under steady feed rate or fuel input conditions.

This method was tested manually, making several runs at each set of plant conditions, adjusting the feed rate up or down according to the desired change to match target temperatures. Table 5 presents the results of this method. The data input information is copied from Table 4 for convenience. Since the plant was now operating with the wind box damper closed, the first test was dropped from this series. For the results given in Table 5, we used DD1, DD2, and preheat fan inlet temperatures as targets. The optimized production rate is given on the last line of Table 5.

3.2.6.1.1 Target Temperatures: Figures 36-39 illustrate the results of manually adjusting feed rates to hit each test target temperature. The criteria were arbitrarily chosen as simulation temperatures falling within approximately 10°K of the specific target. This strategy worked well for DD1 overbed and preheat fan inlet temperatures shown in Figures 36 and 38. It did not yield similar fits with DD2 overbed and kiln solids exit temperatures, see Figures 37 and 39.

Discussion with Minntac personnel helped resolve the target choices. Since DD1 and preheat fan temps were closely related in the plant, usually within 25-50°F of each other, DD1 was eliminated as a target, in favor of the preheat fan temperature. The DD2 overbed temperature is not considered an accurate measurement because of the thermocouple location and turbulence in this zone. Thus the DD2 temperature was also eliminated as a target, with a relatively accurate estimate of the recoup temperature from the CFD model. The plant controls kiln firing based on the kiln solids discharge temperature, so this became the second target. MEDUSA now optimized feed rate under constant moisture, composition, and leakage conditions, using preheat fan inlet temperature and kiln solids discharge temperature as the operating constraints.

3.2.6.1.2 Feed Rate Comparison: Plant measured feed rate is compared with the optimized feed rates for the tests presented in Table 5 in Figure 40. These are the manually adjusted results by the user to hit the target temperatures discussed in the section above. We considered the fit to be very good, as the deviation between the plant indicated rate, and the optimized rate was less than 4% for all runs, and under 3% for 9 of the 12 tests.

3.2.6.2 Section Summary: Summarizing the MEDUSA validation, we matched the simulations over a range of plant conditions. We did so by eliminating the moisture, composition and leakage variations from the data input, fixing preheat fan and kiln solids discharge temperatures, and letting the model find the feed rate that yielded these targets. Fuel flow changed in each of these runs as reported by plant data. Fuel flow could be fixed or kept as a variable, depending on the investigation objective. The traditional approach has been to calibrate the model to one set of data at a time, which then leads to a continual tweaking as the model is calibrated against each new set of data. It is felt that the method outlined will lead to more consistent results, so long as the user does not expect an exact numerical match between simulated results and plant data.

3.3 CFD Cooler Model - Parametric Series:

3.3.1 Cooler Variables and Experimental Design: We were now ready to begin developing a predictive model of the cooler. In total, four experimental series were performed. Table 8 describes the control variables and levels tested for these series. Magnetite, feed rate, and fan flow levels were determined by anticipated minimum, mean, and maximum plant levels. In the case of the First Parametric Series, we initially tried to structure the 3A flow to meet firing hood pressure constraints as well as making physical changes to the cooler. This method required an additional 5 tests (varied 3A flows) to complete the series. Experimental designs for these series are given in Table 9.

A fan flow series was performed to determine basic cooler behavior under constant feed conditions. This information was used to determine the 3A fan flows in the first parametric series of Table 8. Figure 41 shows the cooler layout and wind box numbers as used in this report. In the plant, there is an additional wind box where pellets are discharged from the kiln; this zone is considered “dead” in terms of air flow, and, because the bed is not uniform (upstream of the screed wall), it is not included in the CFD model.

Upon completion of the first series, we revised our method because mixing the physical modifications (walls, duct moves) tended to produce a set of linear equations that averaged all effects. Thus wall effects were mixed with no wall effects, yielding a relation that was not true to either of the physical conditions simulated.

Once we realized this, the series was repeated dropping out one wall location, and the recoup B duct move. The two-position evaluation of recoup B duct was to provide some insight for comparison to Minntac Line 7, which has the B recoup duct attached to the cooler in wind box 5. The second series modeled the Line 6 cooler as it existed at the time of this study. The third series in design was the same as the second, but now a wall was installed between wind boxes 6 and 7. The second and third series are partial factorial designs, 27 combinations out of 81 total were simulated.

Tables 10-12: These tables summarize the CFD simulations for the four experimental series. The fan flow series and the first parametric series are given in Table 10. Individually the results in Table 10 are acceptable, statistically they cannot be combined into a predictive model. Table 11 summarizes the second parametric series and Table 12 the third.

3.3.2 Cooler Fan Flow Series: This series of simulations investigated the response of the cooler under constant production, constant ferrous iron conditions for a series of fan flows. Fan flows consisted of a minimum flow (10,000 lbs/min) a mean flow (13,500 lbs/min) and a maximum flow (17,000 lbs/min) for both the 3A and 3B fans. The results demonstrated that cooler response was linear, in most cases, and for those responses where it was non-linear, a linear regression yielded a reasonable approximation.

Figure 42 shows effect of flow on primary overbed pressure and pellet exit temperature for each level of 3A fan flow. Pressure response is linear, pellet exit temperature displays some non-linearity. Pellet exit temperature is defined at a point location (single cell) about 2 inches

down from the top of the bed, centered on grate width, in the last cell of the cooler. Figure 43 shows pellet exit temperature as a function of total cooler flow. Figure 44 shows primary overbed pressure as a function of total flow. Figure 45 plots average recoup gas temperature for each 3A series as a function of the 3B fan flow; the data is plotted vs total flow in Figure 46. Recoup flow is plotted in Figure 47 for each 3A fan series as a function of the 3B flow and in Figure 48 as a function of total flow. We concluded on the basis of this series that a linear regression model of cooler behavior should give a good approximation of the cooler behavior.

3.3.3 First Parametric Series - Mixed Cooler Physical Layouts: This series consisted of a number of physical modifications as well as operating variations. The full factorial design required 162 simulations; a partial design consisting of 18 simulations was carried out (see Tables 9 and 10). As mentioned, no regression analysis was utilized from this series because of the mixed physical changes to the cooler. However, the individual tests may be of interest to the reader.

In this series, we intended to compare Minntac Lines 6 and 7 recoup duct arrangements. Line 7 is identical to Line 6 except that the recoup B duct is attached to the cooler in wind box 5 on the roof. On Line 6, this duct is attached to the outside wall in wind box 9. A third recoup duct arrangement was also to be evaluated (wind boxes 5, 9, 10), as well as two overbed dividing wall locations, between wind boxes 5 and 6, and between wind boxes 7 and 8.

Budget constraints restricted the subsequent series to the current cooler, and the cooler with a wall installed at one location. The recoup B duct relocation and addition of third recoup duct were dropped from the investigation. The results of this series were useful in determining the wall location for the third series. It was apparent from the simulations of a wall in the original location (wind box 7/8) that 3A fan flow was severely limited, and with the two wind box offset (wind box 5/6) that the 3A fan would run at maximum flow, because of plant control attempting to maintain a neutral firing hood pressure. The third series evaluated the location between these two extremes with one wind box offset (wind box 6/7).

3.3.4 Second Parametric Series - Current Cooler Baseline: The full factorial design called for 81 simulations; we carried out a partial factorial of 27, which at this time appears sufficient. Table 9 details the conditions, and Table 11 presents the results. At two simulations per day, 14 days were required to complete each series. JMP statistical software was used for the statistical analysis and linear model regression.

3.3.4.1 Linear Regression - Variable Abbreviations: The results of the linear regression are presented in Figure 49. The equation parameters are given in the box at the top of the page. Response variables run across the top of the table, control variables are listed vertically on the left. Variable names are abbreviated as much as possible to conserve space, given below is a complete listing of all variables presented in these plots:

| <u>Full Name</u> <u>Response Variables</u> | <u>Abbreviation</u> |
|-----------------------------------------------|-------------------------------|
| 3A Overbed Pressure, in. H ₂ O | 3A OB PRS in.H ₂ O |
| Total Kiln Flow, lbs/min | T Kiln Lbs/Min |
| Average Kiln Gas Temperature, °F | A Kiln Temp F |
| Total Recoup Flow, lbs/min | T Rec Lbs/Min |
| Average Recoup Gas Temperature, °F | A Rec Temp F |
| Pellet Exit Temperature, (top cent) °F | Pell Ext Tmp F |
| Average Vent Stack Temperature, °F | Vent Stk Tmp F |
| <u>Control Variables</u> | |
| % Magnetite in Pellets Entering Cooler, % wt | % Mag |
| Furnace Grate Feed, WLTPH | Feed LTPH |
| 3A Fan Flow, lbs/min | 3A Lbs/Min |
| 3B Fan Flow, lbs/min | 3B Lbs/min |

3.3.4.2 Linear Regression - Prediction Profiles: In Figure 49, the box entitled Prediction Profile provides matrix of responses for each control variable. This chart shows the effect of each control variable on each response. Vertical center lines in each plot show the current control variable level, for example:

% Mag is at 22%, Feed at 485 WLTPH, 3A Fan at 13,500 lbs/min, 3B Fan at 13,500 lbs/min

On a computer screen, these vertical lines are active and can be dragged to any level within the variable range. The response level is shown centered on each vertical scale; this value changes with changes in the control variable settings, for example, the above settings result in:

Vent stack temp = 613.9°F, Ave Rec Temp = 1430°F, Total kiln flow = 7879.9 lbs/min

The slope of these lines provides a visual comparison of control variable effects. For example, examining 3A overbed pressure, one can see that changes in magnetite content or feed rate have little impact on pressure. But both fans have significant effects on pressure, and comparing the fans, the 3A fan has the most significant effect. This would be expected, since 3A fan flow is closest to the overbed sensor. The impact of the 3B fan is attributed to the fact that there is no overbed wall in this cooler. Taking this analysis one step further, if the 3A fan is held constant, and the 3B fan flow is increased, it is possible, (depending on how much 3A air is supplied), for the overbed pressure to become positive. If primary cooling overbed pressure exceeds +0.05 in.H₂O, firing hood pressure will become positive (see plant data relation between firing hood pressure and primary cooling overbed pressure in Figure 79). If a positive firing hood pressure results in the plant, the 3A fan cuts back to maintain a negative firing hood pressure. In normal plant operation, the 3A fan is maintained in automatic control, flow determined by a firing hood pressure, and the 3B is set in manual mode to a level that achieves the desired final cooling for the current production rate.

This analysis can be extended to all the response variables in similar manner. In general, magnetite content and feed rate have no direct effect on cooler outlet flows, which is expected. They do affect temperatures in the process, and if temperatures become too hot, cooler inlet flows are increased to achieve desired cooling. Magnetite content has the largest impact on kiln gas temperature, and its effects on recoup and vent stack gases diminish. This is expected because the magnetite oxidation is readily completed upstream of the recoup and stack outlets, and the bulk of this heat is carried back into the kiln. Feed rate, however, affects temperatures throughout the cooler.

As process fan inlet flows increase, there are corresponding increases in the outlet flows, while temperatures in these streams decrease. It is clear that increasing 3B flow will also drive up flow through the kiln, as is observed in the plant. However, the 3B affect on kiln flow is less than the 3A effect for a similar increase. Looking at the kiln gas temperature, the 3A fan has the more pronounced affect. The effect of both fans on recoup flow is about the same slope. One can then use these linear equations to evaluate relative changes in fan flow by comparing the response variable parameter constants. For example, the 3A constant for average recoup temperature is -0.1098 vs -0.0429 for the 3B fan; thus a 1 lb/min loss in flow by the 3A fan requires a 2.38 lb/min gain in flow by the 3B fan to maintain constant temperature, all other control variables remaining constant.

Pellet plants do not measure a pellet exit temperature. However, they do measure vent stack temperature, and, with enough data, we think a correlation could be made relating vent stack temperatures to hot product. This relationship will have an impact on the development of a cooler operating window, which is defined section 3.3.4.3. With this relationship, MEDUSA/CFD models can avoid analysis of operating regimes where hot product may result, or at least could warn the user that his choice of operating conditions may cause problems in the plant.

The analysis of this parametric series is not complete. Due to the magnitude of this project, we limited our analysis to the variables that directly influence material and energy balance calculations in MEDUSA. More detailed studies could be carried out evaluating leakage effects, pellet bed temperature profiles, pressure profiles relative to sensor locations, and evaluation of sensor locations for better temperature and pressure measurement. Control variables could also be included for kiln discharge solids temperature, bed depth, and pressure fluctuations at the cooler outlets. The cost is in the additional simulations required by the experimental design, given the current computation limitations.

3.3.4.3 Current Cooler Operating Window: This step defines an operating window of possible 3A/3B fan flows. The window is bounded on the high flow side by a maximum 3A overbed pressure and on the low flow side by a simulated maximum pellet exit temperature or maximum vent stack temperature. Because the CFD simulation pressure value trended slightly more negative than the plant, a limit of -0.05 in.H₂O was initially selected. In the plant this corresponded to pressure values between 0.0 and 0.075 in.H₂O. The pellet exit temperature is a direct indicator, but it is not measured in the plant. However, vent stack temperature is, and vent stack temperature tracks with pellet exit temperature.

3.3.4.3.1 Vent Stack Temperature vs Pellet Exit Temperature: Figure 50 plots vent stack temperature as a function of pellet exit temperature. It is believed that using the CFD simulations, a soft sensor for pellet exit temperature could be developed. This involves running CFD simulations for enough operating conditions to completely quantify a pellet temperature in the bed. From these simulations, a model of pellet exit temperature vs cooler operating conditions could be developed. This model could then be linked through a data base to plant instrumentation, from which the model would calculate a pellet exit temperature. This temperature could then be compared against the operating times when the cooler is discharging hot product, to develop a relation between hot product and pellet exit temperature. This model could run in the background several times a shift and be used to alert operators to cooler conditions where hot product is a likely result. Alternatively, a more direct method would track cooler operating conditions and relate vent stack temperature to those conditions where hot product results. If vent stack temperature exceeds this limit, operators would be alerted to possible problems.

3.3.4.3.2 Operating Variable Constraints: Figure 51 shows the operating window; 3A fan flow is plotted on the x-axis, 3B flow on the y-axis. This window is based on 485 WLTPH to the grate. The upper limit on combined flow is determined by 3A overbed pressure set at -0.05 in.H₂O in this window. Any combination of flows that moves across the limit (moving right into dark area) will generate pressures exceeding plant control limits. Similarly, a 500°F pellet exit temperature limit bounds the low flow conditions, and any combination of flows that crosses this line (moving left into dark area) will result in excessively hot pellets. The vent stack limit is also shown; it has slightly different slope but the principle is the same. On the left side of this limit, conditions are too hot in the cooler. Any combination of flows that remains in the white region should yield acceptable operating conditions, based on firing hood pressure and hot product. It will be demonstrated in section 3.4.4 that productivity and fuel consumption change depending on the location in this window.

3.3.4.3.3 Effect of Feed Rate on Operating Window: The effect of feed rate on the size of this window can be seen in Figure 52, which shows how the operating window shrinks at 520 WLTPH. The model simulations and comparisons with plant data were based on the 485 LTPH window. Since the higher feed rate appeared to be a subset of lower tonnage flow combinations, the 485 rate was used as the baseline. Further plant validation work could be carried out comparing various operating windows (defined by tonnage) with plant conditions, if the feed rate in the plant could be correspondingly controlled. This would be a difficult set of tests, requiring operators to maintain both production as well as specific fan flows. The approach taken uses a lower tonnage window (485) and requires operators to control fan flows, allowing feed rates to vary according to normal plant guidelines.

The models used to constrain the operating window were based on two variables, primary cooling overbed pressure, and vent stack or pellet exit temperature. The software package allows any number of variables. Thus, if additional parameters were desired, such as maximum recoup gas temperature or maximum secondary cooling overbed pressure, they could be incorporated as well. The goal was to keep the model as simple as possible using only these two constraints, until the plant validation tests could be completed.

3.3.6 Third Parametric Series - Cooler with Overbed Dividing Wall: Figure 53 shows the linear model parameters and prediction profiles for the third parametric series, simulating the installation of a wall off-set one wind box into the primary cooling zone. The most important changes from the wall are the diminished effect of the 3B fan on kiln gas flow and temperature. The wall effectively isolates the 3A and 3B fans, preventing the 3B fan from overriding the 3A fan, and it also diverts some of the 3A fan flow to the secondary cooling zone. There is still some 3B effect due to cross wind box leakage below the bed and leakage between the bottom of the dividing wall and the pellet bed (6" clearance). One can also compare the values of the response variables at the same control variable levels, (22 % Mag, 485 WLTPH, 3A 13500, 3B 13500) to see that installation of a wall results in:

| | |
|-----------------------------------------------------------------|--------------------|
| a very slight decrease in overbed pressure, in H ₂ O | -0.0805 to -0.0918 |
| a decrease in kiln gas flow, lbs/min | 7879 to 7720 |
| a very slight increase in kiln gas temperature, °F | 2242 to 2243 |
| an increase in total recoup flow, lbs/min | 6142 to 6212 |
| an increase in average recoup temperature, °F | 1430 to 1447 |
| a very slight increase in pellet exit temperature, °F | 394 to 395 |
| a slight increase in vent stack temperature, °F | 614 to 620 |

One can also compare the relative ratios of the parameter estimates. For example, using 3A overbed pressure the ratio of 3A:3B flow for the no wall case is 2.59, and increases to 8.76 with the wall in place, indicating a significant reduction in the influence of the 3B fan on primary cooling overbed pressure.

3.3.6.1 Vent Stack Temperature vs Pellet Exit Temperature: Figure 54 plots the relation between vent stack temperature and pellet exit temperature for this cooler layout. For all practical purposes the relation is identical to the one shown for the baseline cooler in Figure 50.

3.3.6.2 Operating Variable Constraints: Figure 55 shows the operating window as defined at 485 WLTPH; note that the window has shifted to the right. Because some of the 3A fan flow is now diverted away from the kiln, the 3A overbed pressure becomes more negative at low 3A fan flows. If a minimum hood pressure is to be maintained, the 3A fan must now operate at slightly higher flow levels. Pellet exit and vent stack limits also cut off some of the operating window at lower 3B fan flows. Correspondingly, the window has shifted to the right, allowing higher 3A fan flows with high 3B flows before the maximum overbed pressure is reached. This is a positive benefit because the window has shifted in the region where optimum productivity and fuel consumption exist. Thus, installation of the wall should make it possible to operate at higher levels of productivity and lower levels of fuel consumption.

3.3.6.3 Effect of Feed Rate: Figure 56 illustrates the corresponding window at 520 WLTPH. Again, the window is shifted, relative to the window of the current cooler.

3.3.7 Section Summary: The CFD cooler model simulations permitted the definition of a plant operating window for the 3A and 3B fans, constrained by a maximum overbed pressure and a maximum pellet exit temperature or vent stack gas temperature, for each cooler configuration.

The size of this window is dependent on operating conditions. Increasing feed rates will shrink the size of the window; 3A overbed pressure can be related to firing hood pressure (see Figure 79), and a model of pellet exit temperature based on cooler operating conditions could be developed with sufficient CFD simulations.

3.4 MEDUSA/CFD Hybrid Simulations:

In this step, the linear equations defining kiln secondary air temperature and flow, and total recoup flow and temperature, were embedded into the MEDUSA model, defining the MEDUSA/CFD hybrid version. This model was used to evaluate various cooler fan flow combinations extracted from the operating windows shown in Figures 51 and 55. The goal was to establish response surfaces for feed to the grate and fuel consumption.

3.4.1 Target Constraints: These simulations were performed under the following constraints:

| | |
|---------------------------------------|------|
| Preheat fan temperature, °F | 680 |
| Kiln solids discharge temperature, °F | 2268 |
| Kiln Fuel Flow, SMCFH | 179 |
| Preheat Fuel Flow, SMCFH | 68.3 |

3.4.2 Flow Conditions: Various combinations of 3A and 3B fan flows were extracted from each operating window and plugged into the hybrid model. The hybrid model used the respective equations that define kiln gas and recoup gas temperature and flow in terms of production rate, ferrous iron content, 3A fan flow and 3B fan flow. The user specified 3A/3B flow combinations, and, as the simulator adjusted production rate to hit the target temperatures, the cooler responses were adjusted accordingly. Twenty-four simulations were performed within each window. Tables 13-14 list the results. The actual values for preheat fan and kiln solids discharge temperature are provided for comparison to the target. The DD2 Zone flow and temperature reflect perfect mixing with furnace leakages. The recoup flows and temperature at cooler were generated from the linear equations themselves, since the MEDUSA output did not provide these values at the time.

3.4.3 Target Temperature vs Simulation Results: Figure 57 shows the preheat fan temperature calculated vs the optimized feed rate for both cooler series. The optimization routine appears to converge on the target temperature with increasing production rates. Figure 58 compares kiln discharge temperature in a similar manner, and, again, the optimization appears better at higher tonnages. Figure 59 plots simulation deviation from the target as a percent of the target value $((\text{simulation value} - \text{target}) / \text{target}) * 100$ for both targets. Preheat fan temperature showed a maximum deviation of about 4.8% at 446 WLTPH, while kiln discharge solids temperature had a maximum deviation of about 1.2% at 445 WLTPH. The cooler series with an overbed dividing wall appeared to have a slightly better match between target and actual values.

3.4.4 Feed Rate and Fuel Consumption Response Surfaces: JMP software was then used to generate surface responses of feed rate and fuel consumption for 3A and 3B fan flows in both cooler operating windows. The linear models were determined using the data contained in

Tables 13 and 14; 3A and 3B fan flow were the control variables, and feed rate and fuel consumption were the responses. Figures 60 and 61 summarize the results. Two plots are shown for feed rate and fuel consumption respectively. The approximate location of the operating window limits are drawn on the surface responses for reference.

The best feed rate (highest level 470-480 WLTPH) and the lowest fuel consumption (570-590,000 BTU/LT) fall in the same region of both windows. This region occurs where the 3B fan is maximized between 16,000 and 17,000 lbs/min and 3A fan is operating between 12,500 and 13,500 lbs/min. The prediction profiles for fuel and feed rate from these simulations are shown in Figures 62 A and 63 A. Production rate increased with increasing fan flows, and fuel consumption decreased with increasing fan flows. Figures 62 B and 62 B present a second model, showing that production and fuel are more significantly affected by changes in recoup flow than preheat fan flow. Again, increasing recoup flow increases feed rate and decreases fuel consumption. These effects will be discussed further in sections 3.4.5.1 – 3.4.5.3.

3.4.5 Current Cooler vs Cooler with Wall Comparison: Referring to Figures 60 and 61, several comparisons can be made. First, the shape of the operating window changes with the installation of the wall, the slope of the pressure and temperature limits becoming steeper with the wall in place. Second, the window is shifted to the right in the higher 3B region, indicating that higher 3A flow can now be achieved before the maximum overbed pressure is reached. Correspondingly, the lower pressure limit also shifts to the right with the wall, meaning that the 3A fan will operate at slightly higher flows to maintain the minimum overbed pressure, unless control set points are changed. Third, the slope of the iso feed and fuel levels have increased with the wall. Again the implication is that for the same level of 3A fan increase, the cooler with the wall should result in more significant increases in production and decreases in fuel consumption. This can be seen in comparing the ratio of 3A parameter constants. Without the wall, the constant is 0.00579; with the wall the constant increases to 0.0081. Thus, the same increase in 3A fan flow with the wall will generate a 39% increase in grate feed rate, and a 49% decrease in fuel, with respect to the cooler without the wall. However, since the production and fuel levels start out at slightly lower levels with the wall, the benefits begin appearing at higher flow conditions. This is discussed in more detail in sections 3.8.4 – 3.8.6.

3.4.5.1 Cooler Flow vs System Feed Rate and Fuel Consumption: Figures 62 and 63 present additional information about the cooler behaviors. In 62 and 63 A, production and fuel trends are shown as functions of cooler fan performance. The significance of these trends is given by the t Ratio statistic contained in the parameter estimates box in Figures 60 and 61. The variable increases in significance as the absolute value of the t Ratio increases from 2. At values below 2 the variable is considered insignificant. A more detailed definition is given in Appendix II. For both coolers, the t Ratio (absolute value) is greater than 18 for both cooler fans, indicating significant effects from both.

3.4.5.2 Preheat and Recoup Flow vs Feed Rate and Fuel Consumption: In Figures 62 and 63 B, the analysis goes one step further. In these plots, fuel and productivity are compared to preheat flow and total recoup flow in the MEDUSA/CFD results. For the current cooler, the t statistic is low for preheat fan flow 2.4 and 2.28 (feed rate and fuel respectively), but relatively high for recoup flow, indicating a poorer correlation with the preheat fan flow, relative

to the recoup flow variable. But with the cooler containing a wall, the preheat fan t statistic increases to 18.9 for feed rate and 17.5 for fuel. Thus, installing the wall appears to improve the correlation of furnace performance with preheat fan flow. This may be one more reason why it is so difficult to correlate plant data with the current cooler configuration.

3.4.5.3 Least Squares Model Fitting Analysis: The JMP software provides additional insight, by using least squares model fitting. Leverage plots are shown for each proposed model, these plots contain confidence curves. The plots indicate whether the test is significant at the 5% level by showing a confidence region for the line of fit. If the confidence region between the curves contains the horizontal line, the effect is not significant. If the curves cross the line, the effect is significant. A more detailed explanation is found in Appendix II.

Figure 64 compares the models for fuel consumption response using 3A and 3B fan flow as control variables. The plots show that 3A and 3B flow is significant in both coolers. Figure 65 shows a similar comparison for feed to the grate as a function of 3A and 3B flow, and again, both fan flows are significant in both coolers. Figure 66 compares fuel to preheat and recoup flow. In this Figure preheat flow is shown to have a marginal effect for the current cooler, while it has a significant effect in the cooler containing a wall. Figure 67 shows the same effects for productivity. If one compares relative size of the parameter constants for preheat and recoup flow in the cooler with a wall, one sees that pound for pound recoup flow has a more significant effect on production and fuel consumption, about 61% greater. Figure 68 shows leverage plots for a model predicting preheat flow from 3A fan flow for both coolers. The effect of the wall is clear. The correlation is considerably stronger for the cooler with wall, t ratio 27.3 vs 6.6 without wall, and can be seen visually by the scatter in the leverage plots. Figure 69 demonstrates that if 3B flow is accounted for, the correlation between preheat flow and cooler flow is significantly improved. In the plant, such a correlation would be difficult to sort out without some knowledge of how flows develop in the cooler outlet streams.

3.4.6 Section Summary: The simulations using the hybrid MEDUSA/CFD model predicted an optimum fuel and production region in the operating window as defined by the CFD cooler model. This optimum region occurred in the same location for both production and fuel, and required a maximized 3B fan flow. However, to maximize the 3B fan on a continuous basis it should be under automatic control. This cannot be done in the current cooler without affecting the 3A fan performance. The simulations indicated that recoup flow has a significant affect on production and fuel relative to the preheat fan, so recoup flow should be maximized as well for the best plant performance, but this implies adequate waste gas fan capacity to move recoup air. In terms of fuel consumption and production levels, the current cooler appears to yield slightly better numbers at lower fan flows. But installation of a wall increases the slopes of these responses and increases the potential 3A flow at maximized 3B levels, such that marginal gains in fuel and productivity would be expected. Since these simulations were constrained by primary cooling overbed pressure in the operating window, they should all be attainable under normal operating conditions.

One key assumption must be pointed out regarding pressure at the recoup duct outlet in the CFD model. For these simulations it is assumed that the pressure drop between furnace and secondary cooling can be maintained, which means that the waste gas fan must be capable of

increasing the differential if the recoup flow is to increase as shown. This issue was not investigated in this study, but as will be shown in sections 3.5.4 and 3.6.2.4, the capacity of the waste gas fan may have limits on line 6, which prevent attaining the higher levels of recoup flow. One other point to make is that Line 6 operators maintain the 3B fan in manual control, which means that as operating conditions change, this fan may not be at its best flow rate for overall plant performance all of the time.

3.5 Plant Validation Tests:

3.5.1 Minntac Project Review - Test Criteria: A presentation was made to Minntac personnel in December 1999, showing the operating window for the current cooler and the effects of 3A and 3B fan flow on production and fuel consumption. In February and March, two series of plant tests were conducted to test the predictions of the MEDUSA/CFD model. The operating window was divided into five regions comprising a flow range for both cooler fans. Operators were instructed to hold the fans within these ranges, while fuel and production were allowed to fluctuate according to normal operating procedures. Six tests were conducted in February, one for each flow region, and a duplicate of the one most preferred by operators. These tests lasted 48 hours each. Three additional tests were conducted in March, intending to duplicate test regions, I,II, and V. Data was logged automatically using ten-minute averages. Pitot tube traverses were carried out on the 3B cooler fan flow meter, but the 3A was inaccessible on a regular basis and no checks were performed. By this time the recoup B meter had failed, although the recoup A meter appeared to be giving reliable information. Meter drift is suspected in the waste gas and preheat meters, but these flows were not rechecked during these tests. As it turned out, the 3A meter readings coincided with the target ranges. The 3B flows, when corrected by a factor determined by the pitot tube traverses, compared reasonably well to the test targets.

3.5.2 Test Data Manipulation: The plant data is referred to as “unedited” or “edited”. Unedited data is chronologically complete consisting of all data points logged, including plant upsets. Edited data represents a single pass to remove data based solely on plant production upsets. This procedure was somewhat subjective, in that only the points lying outside (>50 tons/hr) of the mean were eliminated. No attempt was made to edit the data for furnace residence time effects. Thus, the first point average back at acceptable feed rate was included, even though the effects of the upset were still within the furnace. The edited data was used in the construction of plant models for comparison with the simulation models. Ideally, additional duplicate tests were desired to confirm the results presented. Figures 70-77 show statistics on feed rate to the grate before and after editing. The goal was to remove most or all of the statistical outliers in a single pass. Tests 7 and 8 were sufficiently stable, so no editing was performed. Test 5 was the least stable and required the most editing.

3.5.3 Plant Cooler Flow vs Operating Window: Figure 78 shows the test regions, test number designations, and the edited data points. The approximate location of the predicted operating window is also included. One can see a significant number of points lying outside of the -0.05 pressure contour. A second pressure contour limit is included for 0.01 in.H₂O. At this level virtually all data points are included.

As mentioned earlier, the CFD 3A overbed pressure prediction corresponds to a more positive plant value, (plant = CFD value + 0.07). For the plant tests, the mean maximum 3A overbed pressure was +0.02 in.H₂O, which would correspond with the simulated contour at -0.05. However, to include all of the plant data in the window, a simulated value of +0.01 is required, which corresponds to a plant value of approximately +0.08, thus there is a small level of error in the initial tuning. Figure 79 relates the primary overbed pressure to firing hood pressure. Figure 80 plots the mean and standard deviations for primary cooling overbed pressure. Note that multiple data points at the same value plot as a single point on the vertical axis.

In reference to the JMP plots that will follow, note that the software limits marker types to 8. Each test series was given a label, and where symbols are the same, a different color is used, which may or may not appear in the report reproductions. JMP is also limited at times in displaying grids. This is apparent in the operating windows in Figures 51, 52, 55 and 56. Finally, JMP does not permit easy resizing of grids so that figure size varies slightly from plot to plot.

3.5.4 Unedited Data Observations: As the data was analyzed, it was apparent that there were significant fluctuations in the process fan operating conditions. These trends show up in both the edited and unedited data. However, illustrating the trends with edited data destroys the time sequence. For this reason, a number of plots are presented to illustrate the variability in the plant data. The data was normalized in order to plot the variable responses on a single y-axis, with JMP. A 70-minute running average was then computed to smooth the curves in these plots. The normalization was done as follows:

$$(\text{variable value} - \text{variable mean}) / \text{std dev variable}$$

The normalized value is referred to as the “Relative Deviation from the Mean, (RDM)” in units of the standard deviation. Tests 1-5 and 7 were selected to illustrate this unsteady nature. Figures 81-86 show relevant statistics for Tests 1-5 and 7; these figures give the number of data points, mean and standard deviations for the fan amps, recoup A duct flow, kiln secondary air temperature, average recoup air temperature, and vent stack temperature. These variables were selected because they highlight the process instability during these tests. The reader is referred to Figures 81-86 for the standard deviation values when evaluating the trend plots that will follow.

3.5.4.1 Process Fan Damper Position: Figures 87-92 plot the averaged damper % open for the preheat (1A/B), furnace waste gas (2A), and cooler fans (3A/B). In these six tests, there is considerable fluctuation in the damper settings. In typical operation, the preheat fans, waste gas fan and 3A fan are all under automatic control. The preheat fans are controlled off wind box thermocouples, and the waste gas is controlled to maintain a DD1 overbed pressure and the 3A fan by firing hood pressure.

In all these plots, it appears that the preheat fans are at the center of the fluctuations. When they open up or close down, the waste gas fan follows according to DD1 overbed pressure, and the 3A fan, according to the effect of preheat fan on firing hood pressure. The 3B is

relatively stable because it is normally in manual mode. Based on these tests, Line 6 demonstrated an unstable mode of operation. The cycles do not appear at regular intervals, and as a result, the reasons for them are uncertain. However, changes in bed permeability, flux addition, pellet size distribution and green ball moisture are all suspected as having some influence on these cycles. Also, it appears that the waste gas fan keeps up with preheat fans, until they reach about 45 to 55 % open, at which time the waste gas fan damper reaches its maximum at 100 % open, even though the preheat fans can continue to open further. The 3A fan appears to keep up with the preheats throughout the operating ranges.

3.5.4.2 Process Fan Power vs Fan Damper Position: Figure 93 illustrates plots of fan amps vs fan damper for Test 1. This plot will be constructed later as a composite for all the tests. The point to note is that the preheat fans operate on the linear part of their fan curve; the 3A fan operates over the range of the curve, but does not appear to reach a maximum. The 2A fan, on the other hand, does reach its maximum, which may be an indication that this fan is undersized for the demands being placed upon it, or that there is some other restriction between the fan and the wind box. Figure 94 plots the normalized (70 minute average RDM values) fan amps, and again, the cycles are very prominent. The cyclical curve for the 3B fan tracks with outside air temperature variations between night and day.

3.5.4.3 Process Fan Power vs Recoup Flow: Figures 95-100 relate fan power to recoup flow. This was accomplished by defining a parameter called “net fan power,” based on fan power “relative deviations from the mean” for each fan. The relationship was defined as follows:

$$\text{Net AMP RDM} = 2A \text{ AMPS RDM} - 1A/B \text{ AMPS RDM} + 3A \text{ AMPS RDM} + 3B \text{ AMPS RDM}$$

where RDM = Relative Deviation from Mean

This relation is based on the fact that waste gas fan flow is limited and is comprised of recoup flow and preheat fan flow, and that at constant waste gas fan damper position, increases in preheat power draw or flow will displace recoup air. Increases in 3A and 3B power indicate more air entering the cooler, being made available to the process. For example, if the waste gas fan power is constant, preheat power is increasing, 3A and 3B are constant, there should be a decrease in recoup flow, having been displaced by preheat fan flow. Thus, if the Net AMP RDM is increasing in value (more positive), recoup flow should likewise be increasing, and conversely, if the Net AMP is decreasing in value, recoup flow should be decreasing. These trends show up clearly in Figures 95-100. The reader can judge the significance of changes in recoup flow by multiplying the standard deviation of flow by the deviation value. For example, in Test 1 a two sigma deviation in Recoup A flow equates to $2 \times 104 = 208$ lbs/min change in flow. Note that because the recoup B flow sensor had malfunctioned by this time, there is no corresponding B flow data. Tests when both recoup sensors were working indicated approximately equal flows in both ducts. So, not only were the process fans cycling, but their affects were also seen in the recoup system.

3.5.4.4 Recoup A Flow vs Average Recoup Temperature: Figures 101-106 relate recoup A flow to average recoup temperature. Temperature data was available for both

ducts, and was averaged (numerically). For reference the reader is referred to Figure 49, which shows the cooler fan impacts on the mass weighted average recoup temperature and flow. In general, as recoup flow increased (Figure 49), average recoup temperature decreased. And since both recoup ducts share a common plenum, increases in flow to one duct must also occur in the other. Thus recoup A flow in the plant is indicative of the change in flow in recoup B duct. In Figures 101-106, it is obvious that this trend shows up in the plant; increases in A duct flow coincide with decreases in the averaged recoup temperature, with the exception of a few times where other upsets were clearly involved. Thus the cycles in process fan flow and recoup flow also generated cycles in the recoup temperatures in the system.

3.5.4.5 Cooler Outlet Stream Temperature Oscillations: Figures 107-112 plot deviations in kiln secondary air, average recoup temperature, and vent stack temperature. The purpose of these plots is again to demonstrate the cyclical instabilities in Line 6.

3.5.5 Section Summary: Based on the tests carried out in this study, Line 6 appears to be operating in a highly unstable mode, and while this plant data will be correlated with simulations in section 3.8.0, it would prove worthwhile to repeat the tests at a later time. From a process point of view, these cycles must have an impact on line productivity, quality and fuel consumption. Eliminating these cycles would certainly have a positive effect on process efficiency. As already mentioned, the periods of production upsets were removed from the data, and a composite data file of all tests was generated, in order to continue the validation process.

3.6 Edited Plant Data:

3.6.1 General Statistics: Figures 113 -124 provide mean and standard deviation comparisons for the composite test data by variable. The JMP software plots the means and standard deviation limits on these figures. Some tests contain significant amounts of data scatter, which also show up in the plots. No attempt was made to remove these points because the process of editing the data then becomes too subjective. It was thought that the relative number of data points provided a reasonable weighting to the overall test averages. In all these plots, temperature is °F, pressure is in.H₂O, and flow is lbs/min. Because of heading limitations, the units do not always appear in the figures.

3.6.1.1 Estimated Feed Rate: Figure 113 shows the estimated feed to the grate (WLTPH) which is calculated as the green ball production rate minus the pro-rated roll feeder recycle rate. When these tests were conducted, Lines 6 and 7 shared a belt scale for roll feeder fines return. For tests 1 – 5, Line 7 was down and the recycle material is 100% attributable to Line 6. For tests 6 - 9 the return rate was calculated as:

$$\text{Line 6 returns} = \text{Tot Returns} * (\text{Line 6 Grn Ball Prod} / (\text{Line 6} + \text{Line 7 Grn Ball Prod}))$$

Note that while green ball production remained relatively constant, the amount of fines steadily decreased by 33 % based on Test 1. Test 1 produced 73.9 WLTPH recycle as compared to Test 9 at 49.8 WLTPH. The standard deviation in feed to the grate ranged from 4.8 in Test 7 to 10.9

in Test 5, while the grate feed rate ranged from 469 to 504 WLTPH. By comparison, the CFD model simulations were based on a grate feed range of 450 to 520 WLTPH.

3.6.1.2 DD1 and DD2 Overbed Temperatures: Figure 114 plots the DD1 and DD2 overbed temperatures. DD1 mean temperatures ranged from 646 in Test 1 to 692 in Test 5. Tests 4 and 5 exhibited the largest standard deviations in DD1 temperature at 23.4 and 21.9°F, respectively, while the remaining tests ranged between 4 and 8°F. DD2 overbed temperature is a combination of the two recoup ducts and a single burner input. Plant personnel suspect that the location of this thermocouple prevents an accurate reading, being out of the gas streams entering the zone. However, it does trend well with recoup temperatures measured at the cooler, which are discussed in section 3.6.2.3. DD2 overbed mean temperature steadily increased over the course of these tests from 963 to 1224°F. The standard deviation in these tests ranged from 26.3 (Test 4) to 88.4 (Test 5). Most of the tests exhibited standard deviations between 26 and 32°F.

3.6.1.3 DD1 and DD2 Overbed Pressures: Figure 115 plots DD1 and DD2 overbed pressures. In DD1, pressure is limited to -0.6 in.H₂O by waste gas fan damper control. If pressure becomes more negative, the fan damper closes down. With the exception of Test 4 at -0.13 in.H₂O, all the remaining tests ranged between -0.51 and -0.62 in.H₂O. Standard deviations were mostly below 0.2 in.H₂O, with the exception of Test 4 at 0.42 in.H₂O. DD2 overbed pressure was also relatively stable, ranging between -1.2 and -1.5 in.H₂O, while the standard deviations were less than 0.13 in.H₂O.

3.6.1.4 Preheat Fan - Damper Control Thermocouples: Figure 116 plots preheat wind box thermocouples designated as 1A WBOX 3A and 1B WBOX 3B. These temperatures are used for control of the 1A and 1B preheat fans, respectively. These values are provided for reference. In general, the B side tends to run slightly hotter. Mean temperatures fell between 949 and 980°F, while standard deviations ranged between 13 and 20°F.

3.6.1.5 Recoup A Duct Flow and Temperature: Figure 117 plots Recoup A duct flow and temperature, the flow sensor was located about midway between the furnace and the cooler, while the thermocouple is relatively close to the cooler (see Figure 2). Flow ranged from 2297 (Test 4) to 2842 (Test 5) lbs/min. Standard deviations ranged from 65 to 110 lbs/min. The mean recoup temperature ranged from 1226°F (Test 6) to 1474°F (Test 9), and standard deviations fell between 44°F and 60°F with the exception of Test 5 at 173°F.

3.6.1.6 Average Recoup Temperature: Figure 118 displays average recoup temperature, $(A+B)/2$, and the total preheat flow rate. Plant personnel estimate the error in the preheat flow sensors at 20 -30%, although this was not checked during the tests, so no correction factor is applied to the data. Average recoup temperature mean values ranged from 1309°F to 1570°F, and standard deviations fell between 38°F and 54°F, with the exception of Test 5 at 157°F. Preheat fan flow means ranged from 18,425 to 19,447 with standard deviations falling between 293 lbs/min and 530 lbs/min.

3.6.1.7 Waste Gas Fan and Primary Cooling Fan Flows: Figure 119 displays waste gas fan 2A flow and primary cooling fan 3A flow. Plant personnel estimate there may be 15-25% error in the waste gas fan flow measurement. At this time it is thought that the 3A fan is

relatively accurate, but this has not been verified, because it is difficult to access this sensor. Mean waste gas fan flow ranged from 24,810 to 26,100 lbs/min, and standard deviations fell between 1435 and 1997 lbs/min. Primary cooling fan flow means ranged from 11,620 to 14,045 lbs/min, while the standard deviations ranged between 203 and 843 lbs/min.

3.6.1.8 Secondary Cooling Fan Correction Factor and Cooling Fan Inlet

Temperatures: Figure 120 shows the secondary cooling fan 3B correction factor as determined by comparison with pitot tube traverses performed during the tests, and the inlet cooling fan air temperatures. The range in temperature for each test reflects the changes between night and day during the test. For these tests, the means ranged from 3°F to 48°F.

3.6.1.8.1 Secondary Cooling Fan - Indicated Flow and Corrected

Flow: Figure 121 plots secondary cooling fan flow as measured and as corrected by the factors shown in Figure 120. The corrected flow values are used in the plots that follow, as well as the model development. In general, the relative changes in flow were reflected after the correction was applied, except for Tests 7 and 8, which show little or no decrease in flow relative to Test 6, after the correction. For the uncorrected flow, the means ranged from 8,480 to 12,512 lbs/min, with standard deviations ranging from 163 to 352 lbs/min. In the corrected flows, the means ranged from 10,092 to 15,515 lbs/min, and the standard deviations ranged from 203 to 458 lbs/min.

3.6.1.9 Process Fan Power: Figures 122 and 123 display process fan power draw in amps. The preheat fan power draw is the numerical average of both fans; total preheat fan power is double this value. For the waste gas fan, means ranged from 344 to 380 amps, with standard deviations ranging from 6 to 16 amps. The preheat fan means ranged from 139 to 147 amps, with standard deviations of 2 to 7 amps. In Figure 123, primary cooling fan power means ranged from 110 to 127 amps, with standard deviations 0.5 to 3.9 amps. The secondary cooling fan power means ranged from 109 to 128 amps, with standard deviations of 0.5 to 2.8 amps.

3.6.1.10 Cooler Vent Stack Flow and Temperature: Figure 124 shows cooler vent stack flow and temperature. These measurements are made down stream of the junction between the two stacks, so they represent the total flow in the stack system. Plant personnel estimate the error in this sensor around 25-30%, but this was not checked during the tests. Stack mean flows ranged from 8,710 to 12,179 lbs/min, with standard deviations of 366 to 1,051 lbs/min. Stack mean temperatures ranged from 605 to 765°F, with standard deviations between 29 and 99°F.

3.6.2 Data Trends - XY Format: Figures 125-142 are X-Y plots of selected variables to illustrate various trends, or lack thereof, in the data. Summary of fit, and parameter estimates are also given. When possible, the line fit is kept linear, and polynomial degree 2 curves are used when there is a significant improvement in the R-square term. For some reason, the minus signs in the parameters show up as ù symbol in the regression equation. Individual data points in the test composite data file are plotted. Each test series is plotted as a different symbol, or color if using the same symbol, but given the number of points, it is difficult to distinguish between them.

3.6.2.1 Waste Gas Fan Power vs Waste Gas Fan Damper

Waste Gas Fan Power vs Average Preheat Fan Power

Figure 125 displays waste gas fan power as functions of waste gas fan damper % open, or preheat fan power (average of two fans). Waste gas fan power appears to reach a maximum between 80 and 90 % damper or at an average preheat fan power of 150 amps. The correlation with fan damper is $R^2 = 0.92$, while the correlation with preheat fan power is $R^2 = 0.56$. Figure 126 plots waste gas fan flow as a function of waste gas fan damper position and waste gas fan power. A linear fit is displayed, but the fit is poor; $R^2 < 0.2$ in both plots due to the scatter in the flow readings.

3.6.2.2 DD1 Wind Box Pressure vs Waste Gas Fan Damper

DD1 Wind Box Pressure vs Waste Gas Fan Power

Figure 127 shows DD1 wind box pressure as functions of waste gas fan damper position or waste gas fan power. The correlation R^2 terms are 0.72 and 0.66 respectively. Wind box pressure appears to stop decreasing around 80% damper.

3.6.2.3 DD1 Overbed Temperature vs Preheat Fan Inlet Temperature

DD2 Overbed Temperature vs Average Recoup Temperature

Figure 128 plots DD1 overbed temperature as a function of the averaged preheat fan inlet temperature, and DD2 overbed temperature as a function of the averaged recoup duct temperatures. The R^2 terms are 0.95 and 0.81 respectively. In general, the DD1 overbed temperature is about 15°F less than the average preheat fan inlet temperature, and the strong correlation supports our decision to use preheat fan temperature as the target in the MEDUSA simulations. In the DD2 zone there is some question as to the accuracy of this thermocouple due to its location. It does pick up the trends in recoup temperature very well, even though the absolute value may be off 200-300°F.

3.6.2.4 DD1 Overbed Pressure vs Waste Gas Fan Power

DD1 Overbed Pressure vs Average Preheat Fan Power

Figure 129 plots DD1 overbed pressure as functions of waste gas fan power and preheat fan power. The R^2 for fan power is 0.16, but the plant control philosophy is clear; overbed pressure is maintained constant, out to the point where the preheat fans appear to overpower the waste gas fan, thereby increasing the DD1 overbed pressure. This point occurs where under bed pressure stops increasing as indicated in Figure 127. The correlation is better with preheat fan power, $R^2 = 0.74$. Note that relatively small increases in preheat fan power rapidly raise DD1 overbed pressure. Figure 130 plots DD1 and DD2 overbed pressure as functions of wind box pressure. The R^2 terms are 0.42 and 0.22, respectively. In these plots, the waste gas fan maintains overbed pressure with wind box pressures down to -10 in.H₂O, after which DD1 overbed pressure begins to rise. The correlation with DD2 overbed pressure is less certain.

3.6.2.5 Recoup A Duct Flow vs Recoup A Duct Temperature

Recoup A Duct Flow vs Average Preheat Fan Power

Figure 131 plots Recoup A duct flow as a function of Recoup A temperature and preheat fan average power. The R^2 terms are < 0.15 in both plots. The trends as indicated by the linear fits show flow decreasing with increasing gas temperature, and increasing preheat fan power, although data scatter is so great that these relations need further investigation.

3.6.2.6 Average Preheat Fan Power vs Preheat Fan Damper Total Preheat Fan Flow vs Preheat Fan Power

Figure 132 plots average preheat fan power as a function of average preheat fan damper position, and total preheat fan flow as a function of preheat fan power. Fan power vs damper position has an $R^2 = 0.72$, while flow vs fan power exhibits an R^2 of 0.46. The increase in fan power draw and flow show no signs of reaching a maximum, indicating the preheat fans are capable of supplying more air than the waste gas fan can exhaust from the DD1 zone.

3.6.2.7 Preheat Overbed Pressure vs Average Preheat Fan Damper Preheat Overbed Pressure vs Average Preheat Fan Power

Figure 133 plots preheat zone overbed pressure as a function of average damper position and average fan power. These fans appear capable of developing significant negative overbed pressure. The R^2 values are 0.58 and 0.44 respectively. Figure 134 plots preheat overbed pressure vs wind box pressure, and preheat wind box pressure vs average preheat fan power. Again, it appears that the preheat fans have more than adequate capacity to move air through this zone; the R^2 terms are 0.39 and 0.74 respectively. Figure 135 plots total preheat fan flow as a function of wind box pressure; the increase in flow is linear throughout the operating conditions tested. Also shown in Figure 135 is a plot of kiln firing hood pressure vs preheat overbed pressure, showing that firing hood pressure decreases with corresponding decreases in preheat overbed pressure. Since the 3A fan control is tied to firing hood pressure, this fan will open up or close down in accordance with the preheat fans. The R^2 values are 0.55 and 0.72 respectively.

3.6.2.8 Primary Cooling Fan Flow vs Average Preheat Fan Power Primary Cooling Fan Flow vs Firing Hood Pressure

Figure 136 displays primary cooling 3A fan flow as functions of preheat average fan power and firing hood pressure. The correlations are poor in these plots, with R^2 values < 0.24 . In an attempt to improve the fit, a Net Flow to the Kiln was calculated as follows:

$$\text{Net Flow to Kiln} = (3A \text{ Flow} + 3B \text{ Corr Flow}) - (\text{Total Recoup Flow} + \text{Vent Stack Flow})$$

Where total recoup flow is based on the CFD model relation between total recoup and recoup A duct flow.

$$\text{Total Recoup Flow} = 627 + 1.848 * \text{Recoup A Flow}$$

In Figure 137, net flow to the kiln is plotted vs firing hood pressure and preheat fan power. The correlations are not much better than in Figure 136. Sensor drift may be partly to blame for the lack of correlation in this data.

3.6.2.9 Kiln Exit Gas Temperature vs Cooler Flow to Kiln Kiln Discharge Solids Temperature vs Calculated Flow to Cooler

Figure 138 looked for correlations between kiln exit gas temperature and net gas flow to kiln, and kiln solids discharge temperature and net gas flow to kiln. The correlations again were poor, with R^2 values < 0.16 .

3.6.2.10 Primary Cooling Fan Flow vs Primary Cooling Fan Power Secondary Cooling Fan Flow vs Secondary Cooling Fan Power

Figure 139 plots 3A flow and 3B flow as functions of their respective fan amps. In these plots, the 3B flow is the uncorrected sensor output. There is some scatter in the 3A flow vs amps relation ($R^2 = 0.64$), while the 3B correlation is considerably better ($R^2 = 0.93$). Figure 140 plots the 3B correction factor and corrected 3B flow vs fan amps. At this time it is not clear why at low fan amps the correction factor was also low at 1.2 and then suddenly jumps to 1.33 and then decreases with increasing fan power draw. The R^2 term for the corrected 3B flow is slightly worse than the uncorrected fit ($R^2 = 0.89$), but is still very good.

3.6.2.11 Recoup A Duct Flow vs Total Cooler Inlet Flow Recoup A Duct Temperature vs Total Cooler Inlet Flow

Figure 141 plots recoup A duct flow and temperature as functions of the total cooler inlet flow. Recoup flow appears to increase with increasing cooler flow ($R^2 = 0.48$), but the correlation of temperature with total cooler flow is poor ($R^2 = 0.1$). In Figure 142, averaged recoup temperature is plotted vs total cooler flow, and, again, the correlation is poor ($R^2 = 0.08$). Also shown in Figure 142 is vent stack temperature vs vent stack flow where the fit is better ($R^2 = 0.52$).

3.6.3 Section Summary: Nine plant tests were performed, data collected, and analyzed. Trends in the plant data indicated an unsteady state of operation, with frequent upsets, and a waste gas fan that is undersized for the demands placed on it. It appears that the waste gas fan cannot keep up with the preheat fans as they increase in flow beyond about 50% damper. A number of correlations were plotted, looking for trends in the plant data. For those plots in which the fit is poor, it may be due to the influence of more than one variable, sensor drift or other undetected changes in operating conditions.

3.7 Plant Data Models:

3.7.1 Description: Two models were generated from the plant data. The first model was patterned after the CFD cooler model, using grate feed rate, 3A fan flow, and 3B fan flow as control variables to predict selected response variables. The only difference between the plant and CFD models was the absence of a ferrous iron content at the kiln discharge point. The second model was patterned after the hybrid MEDUSA/CFD model, in which only the 3A and 3B flows serve as control variables to predict grate feed rate and fuel consumption.

3.7.2 Linear Regression - CFD Model Criteria: Figures 143-145 give the linear regression results for the plant data model using CFD criteria. The Prediction Profiles are contained in Figures 145 and 146, respectively. For comparison, the corresponding CFD simulation profiles are found in Figure 49, along with a Table of parameter estimates.

Two pressures are reported in the plant profiles. The 3A overbed pressure corresponds to the 3A overbed value in the CFD model; this is not the pressure that controls the 3A fan, but it is measured in the plant cooler. The firing hood pressure controls the 3A fan operation, but was not part of the CFD cooler model. The relation between these two measurements in the plant data is found in Figure 79.

As already mentioned, there is no direct measurement of cooler flow to the kiln, so it must be inferred from a mass balance between cooler input and cooler output measured at the stack and in the recoup ducts. Further, since the recoup B duct sensor had malfunctioned, total plant recoup flow was estimated using the CFD model relation between recoup A flow and total recoup flow, this was described in detail in section 3.6.2.8.

Kiln secondary air temperature is a direct measurement whose accuracy is questioned. Based on CFD simulations (see Figure 10), the temperature in this duct is not uniform, and the largest deviations appear on the side opposite the thermocouple. In the plant data, actual recoup A duct flow and temperature, as well as the estimated total recoup flow and average temperature are included. The total recoup flow and averaged recoup temperature are used for comparison with the CFD model. Keep in mind that the CFD average is mass weighted, and the plant average is numerically averaged from single point sources. Vent stack temperature is provided, as it is felt that this could serve as an indicator of potentially hot product in the system. Vent stack flow was omitted since this flow exits the system.

3.7.2.1 Correlation Fit: Overall, the data fit with the predictions is not too bad, given the variability in the data. The R^2 terms are listed below for the plant model:

| | |
|----------------------------|------|
| 3A Overbed pressure | 0.37 |
| Firing Hood Pressure | 0.59 |
| Net Flow to Kiln | 0.66 |
| Kiln Sec Air Temperature | 0.48 |
| Recoup A Duct flow | 0.58 |
| Recoup A Duct Temperature | 0.60 |
| Recoup Total Flow | 0.58 |
| Average Recoup Temperature | 0.66 |
| Vent Stack Temperature | 0.41 |

With the exception of Kiln secondary air temperature trends, the model based solely on plant data gives the same general trends as does the CFD model. Relative slopes may vary, but given the limited number of CFD runs and operating parameters tested, the overall comparison is acceptable. The predictions from both of these models are compared in the next section.

3.7.2.2 Operating Window: An operating window can be constructed in the same manner as was done with the CFD model. This window is shown in Figure 147. The 3A overbed pressure high limit of 0.01 in.H₂O is specified based on the maximum mean values listed in Figure 80. This window with its vent stack temperature and maximum 3A overbed pressure constraints is superimposed on a plot of 3B corrected flow vs 3A flow in Figure 148. Figure 148 shows that the operating window predicted by the plant data is similar in shape and location to the CFD base window, and that it encompasses most of the operating data.

3.7.3 Linear Regression - MEDUSA/CFD Hybrid: The second plant model is developed using only 3A flow and 3B flow control variables and is used to predict the feed rate and fuel consumption as responses. This allows comparison to the hybrid MEDUSA/CFD simulations.

3.7.3.1 Feed Rate and Fuel Consumption Response Surfaces: Figure 149, displays the linear regression results and the surface plots for the plant data. The R^2 values are relatively low at 0.24 for feed rate and 0.18 for fuel consumption, but the trends predicted match with the computer simulations. The highest production rate and lowest fuel consumption values fall in the same region of the operating window as they do in the computer simulations, indicating the best efficiency at highest 3B flow, and moderate 3A flow levels. The question of how much improvement in the R^2 could be expected if the plant had been operating under more stable conditions remains unanswered at this time.

3.8 Comparison of Plant Data Model with CFD or MEDUSA/CFD Models

3.8.1 Description: The final step in the analysis compares the predictions of the computer models with a model developed solely from plant data using the same criteria. The plant model can be compared with the CFD model or MEDUSA/CFD model. The same plant data is used for both comparisons, and the differences between the two models are the control variables used to predict the responses in the plant data. There is also the question of choosing the conditions under which the comparison should be performed. The JMP software once again provides a means by which this task can be accomplished.

Within the prediction profile menu is an option entitled “desirability functions”. These functions allow the user to give a weighted desirability to each response variable in the profile. The desirability factor runs from zero to one, zero being the least desirable, one being the most desirable. These factors are then attached to minimum, mid-range, and maximum response levels by the user. These functions are set for each response variable. The JMP software then finds the combination of control variables that maximize the total desirability of all functions.

3.8.2 Desirability Criteria: The desirability criteria were established to approximate plant operating conditions. Note that there is a range of values that could be selected, and these yield reasonable results.

| | Levels | | | Desirability | | |
|---------------------|----------------|------------------|----------------|--------------|-------------|------------|
| | <u>Minimum</u> | <u>Mid-Range</u> | <u>Maximum</u> | <u>Min.</u> | <u>Mid.</u> | <u>Max</u> |
| 3A Overbed pressure | -0.30 | -0.10 | +0.05 | 0 | 1.0 | 0 |
| 3B Overbed pressure | -0.40 | -0.25 | -0.10 | 0 | 1.0 | 0 |
| Feed Rate to Grate | 450 | 485 | 525 | 0 | 0.5 | 1.0 |
| Fuel Consumption | 550,000 | 595,000 | 640,000 | 1.0 | 0.5 | 0 |

3.8.3 Secondary Cooling Overbed Pressure Correlations: Before we can complete this discussion, one more response variable must be discussed. This is the 3B overbed pressure. In the current Line 6 cooler, the 3B fan is maintained in manual mode, to avoid overriding the 3A. Also the 3B fan flow cannot be set so high that a positive overbed pressure in secondary cooling results. From experience, the operators know approximately how much 3B fan can be tolerated to maximize cooling without affecting the 3A fan. Remember, from Figure 78, that Region II is the preferred fan configuration, 14,000 - 16,000 lbs/min 3B flow and 12,000 - 14,000 3A flow.

3.8.3.1 Secondary Cooling Overbed Pressure - CFD Current Cooler Series:

The relation of 3B overbed pressure to the four control variables (% Mag, WLTPH, 3A Flow, 3B Flow) is shown for the current cooler in Figure 150, with 3A overbed pressure also included for reference. These profiles are from the same database used to generate the profiles shown in Figure 49. The point to note is that the 3B fan affects 3A overbed pressure, and the 3A fan has a slight affect on 3B overbed pressure. This is because there is no wall separating the two zones.

3.8.3.2 Secondary Cooling Overbed Pressure - CFD Cooler with Wall Series:

In Figure 151, the corresponding plot for the cooler with an overbed wall, we see that the affect of 3B fan flow on 3A overbed pressure is significantly reduced, and the affect of 3A fan on 3B overbed pressure is reversed, although the impact can be considered minimal at best. The 3A fan still has a small impact on 3B overbed pressure because there is one wind box of primary cooling entering the secondary cooling zone. Thus, installation of a wall breaks the cross zone interaction of the 3B fan on the 3A fan, allowing the 3B fan to operate in automatic control. This cannot be done in the current cooler.

3.8.3.3 Secondary Cooling Overbed Pressure - Plant Data: Figure 152 plots these same interactions in the plant data. We see that the cross zone interactions on pressure sensors are considerably more pronounced than in the CFD simulations. In the prediction profiles, the 3A fan appears to have a large affect on the 3B overbed pressure sensor. Under these conditions it is impossible to have both fans in automatic control based on overbed pressures. This control state is unstable, and is the reason that the 3B is now in manual mode. Figures 153 and 154 tabulate mean and standard deviations in the plant data by test, for reference to the following discussion. Firing hood pressure means range from -0.31 to 0.00 in.H₂O; 3A overbed pressure means range from -0.06 to +0.02 in.H₂O; and 3B overbed pressure means range from -0.61 to -0.35 in.H₂O.

3.8.4 Statistics and Prediction Profiles - Plant Data: Figures 155-156 present the summary of fit, with parameter estimates and prediction profiles for the plant data model constructed using 3A and 3B fan flow as the control variables. This is the format used to compare to the MEDUSA/CFD simulations. The desirability functions in the JMP software optimize the plant data model (maximum desirability) and show that optimum 3B fan flow is 15,960 lbs/min and the 3A fan flow is 13,960 lbs/min. This is expected since this flow combination falls in the region where plant production is highest and fuel consumption is lowest.

The desirability values are also printed on the plots shown in Figure 156. The highest desirability for the overbed pressures is placed mid-range so that the optimization will find values close to the means in the plant data. Feed rate is desired as high as possible, so desirability increases to a maximum at maximum feed rate. Similarly, low levels of fuel consumption are desirable, so maximum desirability occurs at lowest fuel consumption per ton. The variable levels were chosen to fit the levels occurring in all three data sets, (two CFD parametric series, and the plant data series).

At the optimum, the predicted feed rate to the grate is 495.2 WLTPH, at 581,800 BTU/LT. The middle plot shows what happens if 3B flow is reduced by 2,000 lbs/min, which can occur if an operator is not running at peak 3B fan flow. In this case, feed rate drops to 485.8

WLTPH and fuel increases to 595,800 BTU/LT. Conversely, if the 3B fan is normally operated below the predicted optimum, cooler and furnace conditions will prevent achieving the highest possible production level. Using 330 operating days per year (24 hrs/day, \$2.50/MMBTU, and a production factor of 0.77), this amounts to 57,325 LTPY of lost production on Line 6. Comparing total fuel costs based on these two feed rates, there is a fuel penalty of about \$20,000 per year at the lower production level. This is based on:

$$495.2 * 0.77 * 330 * 24 * (581,800 / 1,000,000) * 2.5 \quad \text{vs} \quad 485.8 * 0.77 * 330 * 24 * (595,800 / 1,000,000) * 2.5$$

Thus, not only are fewer tons produced, but fuel costs are slightly higher.

Another aspect to consider is NO_x generation. These comparisons were carried out at constant fuel flow. Total tons produced with this fuel flow varies. Thus, using this example, as much as 57,325 LTPY might be produced or lost at the same NO_x rate. This loss or gain in production depends on how close to the optimum operators run the plant. The process fan cycles must certainly work against them in this goal. The third plot in Figure 156 shows that if the 3A fan flow increases to fill the void left by the 3B fan, there is small gain in productivity from 485.8 to 487.8 WLTPH, but the full optimum is not achieved.

3.8.5 Statistics and Prediction Profiles - CFD Current Cooler Series: Figures 157 and 158 follow the same format as 155 and 156, using the MEDUSA/CFD simulations for the current cooler design. In the first plot of Figure 158, the fully optimized conditions occur for a 3A fan flow of 12,750 lbs/min and a 3B fan flow of 15,275 lbs/min; again, these conditions are found in the same general region of the operating window. In this case the optimum production rate is 469.9 WLTPH, as compared to 495.2 WLTPH from the plant data. This absolute difference is not important. What is important is the effect on production if the 3B flow is reduced from optimum. This condition is shown in the second plot where 3B flow is decreased by 1000 lbs/min. Feed rate to the grate is reduced from 469.9 to 463.0 WLTPH. This equates to 42,080 LTPY loss in production if the 3B optimum is missed by this averaged amount over the year. On the other hand, if the 3B is operated at 900 lbs/min above the optimum, yearly production increases by 22,560 LTPY, (473.6 WLTPH). However, under these conditions, the 3B overbed pressure is becoming more positive. Obviously, the plant will deviate on both sides of the optimum. What is not known is whether the deviations cancel or whether they are weighted to one side or the other. Common sense says they are weighted to the side that yields the least maintenance problems and highest operating margin of safety. Minntac personnel could determine this point if interested.

3.8.6 Statistics and Prediction Profiles - CFD Cooler with Wall Series: Figures 159 and 160 extend the analysis to the cooler with wall series of MEDUSA/CFD simulations. Now the comparison changes slightly, because with a wall in the cooler, the 3B fan can be placed back under automatic control, and continuously operated near optimum. The optimum flow occurs with 3A fan at 15,000 lbs/min and 3B fan at 13,550 lbs/min. Feed rate is essentially the same under these conditions at 469.88 WLTPH. This is shown in the first plot of Figure 160. This feed rate can be used again to judge the relative deviations explained in section 3.8.5, when the plant is not at full optimum. In this case, the additional control of the 3B fan should maintain the

plant at optimum most of the time. The additional tonnage possible by installation of a wall can be computed under several scenarios:

Scenario One: Operators using manual mode maintain plant at optimum with the current cooler vs the cooler with wall that has automatic control installed on 3B fan; 3B overbed desirability limits are the same in both coolers:

| | |
|-----------------------|-------------|
| Cooler without wall | 469.9 WLTPH |
| Cooler with wall | 469.9 WLTPH |
| No benefit with wall. | |

Scenario Two: Operators using manual mode maintain plant at a yearly averaged feed rate equivalent to 463.0 WLTPH (3B flow 1000 lbs/min < optimum) vs cooler with wall and automatic 3B control:

| | |
|----------------------------------------------|-------------|
| Cooler without wall | 463.0 WLTPH |
| Cooler with wall | 469.9 WLTPH |
| 42,080 LTPY benefit with the wall installed. | |

Scenario Three: If the 3B overbed high pressure limit can be tightened using automatic control, raising the set point levels on 3B overbed pressure to:

| | | |
|------------|-------|---------------------|
| low level | -0.25 | in.H ₂ O |
| mid range | -0.15 | in.H ₂ O |
| high limit | -0.05 | in.H ₂ O |

| | |
|------------------------------------------------------|-------------|
| a) Cooler without wall, 3B flow at optimum | 469.9 WLTPH |
| b) Cooler without wall, 3B flow below optimum | 463.0 WLTPH |
| vs | |
| Cooler with wall, 3B flow continually at new optimum | 478.5 WLTPH |

| | |
|----|-----------------------------------------|
| a) | 52,450 LTPY benefit with wall installed |
| b) | 94,525 LTPH benefit with wall installed |

3.8.7 Waste Gas Fan Operating Issues: Installation of a wall accomplishes three things:

1. Allows both cooler fans to operate in automatic control.
2. Dampens out the air flow oscillations moving through the kiln, preheat and DD1 zones, which are in part caused by 1A/B fans.
3. Results in more air available to the heat recoup system, possibly at slightly hotter temperatures.

The waste gas fan, however, must be operated differently from the present mode, where it is allowed to float with the preheat fan oscillations. If the full advantage of the wall is to be

achieved, the waste gas fan must be run at maximum flow all the time. This will ensure moving the most recoup flow possible under any given operating conditions. If the waste gas fan continues to cycle with the preheats, the advantage of increased recoup heat recovery is lost, and this heat is vented up the stack. In addition, by not moving the maximum recoup flow, secondary cooling overbed pressure will increase slightly, which may limit the 3B flow under certain operating conditions.

3.8.8 Comparison of Plant Model to CFD and Hybrid Models:

The last set of figures compares the CFD and MEDUSA/CFD predictions with similar models generated from the plant data. These plots do not reflect cooler operation under optimum conditions, but rather operation through a range of conditions. The range chosen is patterned after current operation, where the 3A fan cycles through a range of flow, while the 3B fan is held constant in manual mode. Variable responses are plotted as a function of total cooler flow, where the 3A fan flow ranges from 10,000 to 17,000 lbs/min and the 3B flow is fixed at 13,500 lbs/min.

3.8.8.1 Comparison with CFD Models: Figures 161-166 compare the predictions of the plant data model with the CFD cooler model. Control variables in the plant data are feed rate, 3A flow and 3B flow. Control variables in the CFD model also include the ferrous iron content at the kiln discharge point.

3.8.8.1.1 Primary Cooling Overbed Pressure vs Total Cooler Flow:

In Figure 161, overbed pressure is plotted for primary cooling zone in the plant and CFD models. Plant firing hood pressure is also included for reference. From about 26,000 lbs/min up to the maximum of 30,500 lbs/min, the plant and CFD predictions fall within 0.1 in.H₂O of each other. The installation of a wall offset one wind box does not significantly affect the primary cooling overbed pressure; it is essentially the same as the current cooler. Three simulations with a wall offset two wind boxes show that overbed pressure is decreased about -0.1 in.H₂O relative to the current cooler. This is because substantially more flow is diverted to secondary cooling. It is presumed that the firing hood pressure would be correspondingly lower, which implies that the 3A fan would operate at a higher level of flow if the same pressure control scheme is in place. Moving the wall one additional wind box would also increase the effect of 3A flow on 3B overbed pressure. This aspect has not been investigated in this study.

3.8.8.1.2 Kiln Secondary Air Temperature vs Total Cooler Flow:

Figure 162 plots the kiln secondary air temperature as a function of cooler flow. The plant data shows relatively no change in temperature, while the CFD models predict a significant drop in temperature over the flow range (2350 to 2140°F). The presence of a wall offset one wind box does not significantly affect secondary air temperature. But if the wall is offset two wind boxes temperature is increased by 50 to 75°F by diverting the coolest portion of these gases to secondary cooling. Remember, the walls are being moved into the primary cooling zone, so that the zone size is reduced with each wind box of offset.

3.8.8.1.3 Calculated Flow to Kiln vs Total Cooler Flow:

Figure 163 compares mass flow to the kiln. For the plant data, this is calculated as the difference between total flow into the cooler and that going out through the recoup and stack. Recoup flow is

estimated using the CFD relationship between total flow and recoup A flow, since only the recoup A flow sensor was working during these tests. The plant data shows steeper slope over the flow range, doubling in mass flow (7,000 to 14000 lbs/min) as the 3A fan flow increases from 10,000 to 17,000 lbs/min. The CFD data tracks in the same direction, with flow ranging from 6,300 to 8,800 lbs/min. Placement of a wall with one wind box offset, again shows little impact on cooler flow. This is because the location chosen is near the natural break point (between flow reporting to kiln and flow reporting to recoup) in the cooler without a wall. However, shifting the wall another wind box (2 wind box offset) drops 1,000 to 1,500 lbs/min out of the kiln flow.

3.8.8.1.4 Total Recoup Flow vs Total Cooler Flow: Figure 164 displays predicted total recoup flow. In this figure, the plant and CFD models exhibit approximately the same slope, and the CFD prediction is approximately 1,000 lbs higher for both ducts. The effect of the wall shows slight deviations in flow, indicating slightly more flow at low 3A fan, and slightly less flow at high 3A fan, because with low 3A fan flow, the natural tendency is for 3A air entering through the last few wind boxes of primary cooling to move toward the kiln. Placement of a wall prevents this and keeps the air in the secondary cooling zone. At high 3A fan flow, the tendency is for 3A air in this same region to now move toward the secondary cooling zone, and the wall in this case prevents air from migrating to the recoup ducts. In moving the wall an additional wind box, there is a significant increase in recoup flow, because the wall is located upstream from the natural break point, and now diverts more 3A air to the secondary cooling zone. In the flow range tested, the wall at two wind box offset increases recoup flow approximately 200-400 lbs/min.

3.8.8.1.5 Averaged Recoup Temperature vs Total Cooler Flow: Figure 165 shows how the averaged recoup temperature for the total flow is affected by cooler flow. In this plot, the plant and CFD models track within 100°F or less over the flow range. The plant average is numerical, while the CFD values are mass weighted. The CFD values are slightly hotter on the low flow range and slightly cooler on the high flow range. The effect of the wall at one wind box offset further raises temperature at low flows (30-60°F) and very slightly decreases temperature under the high flow conditions (10-30°F). Moving the wall an additional wind box significantly raises the temperature by 100-150 °F. This was expected, since more primary cooling gas was diverted to secondary cooling.

3.8.8.1.6 Vent Stack Temperature vs Total Cooler Flow: Figure 166 plots vent stack temperature vs total cooler flow. The plant and CFD models start out the same at low flow, and then diverge at maximum flow, the plant temperature remaining approximately 150°F hotter. The effect of the wall with one wind box offset is minimal, but with a two wind box offset the vent stack temperature is increased approximately 50°F.

3.8.8.1.7 Section Summary: The trends predicted by the CFD cooler simulations are reflected in the plant data, when analyzed in a similar manner. In some cases, the comparison is quite close to actual values, but in other instances the actual values vary significantly. However, both models demonstrate similar trends, which is most important. The weakest comparison occurs for kiln secondary air temperature. An additional validation test could be performed by obtaining a temperature profile across this duct for comparison to the

CFD simulations. If this gradient exists, it might be useful to monitor temperature at several locations across the duct and average the temperatures in this process stream.

3.8.8.2 Comparison with Hybrid Model: The last three figures are based on the same cooler flow conditions, just discussed, but now the plant model is compared on the same basis as the MEDUSA/CFD models. The interest is in predicting overall impact on furnace productivity and fuel consumption. The predictions were carried out over a flow range; they do not necessarily represent attainable operating conditions, which are limited by firing hood pressure, cooler overbed pressures and pellet exit temperatures from the cooler.

3.8.8.2.1 Estimated Feed Rate vs Total Cooler Flow: Figure 167 shows predicted feed rate to the grate as a function of cooler flow. Remember this is wet feed, and actual production must be adjusted for moisture and dust losses, and net LOI or GOI for magnetite and flux additions. The plant model consistently predicted a higher feed rate than MEDUSA/CFD, but the slopes of the two simulations are nearly equal, indicating that MEDUSA/CFD predicted a similar increase in production over the cooler flow range. This amounted to about a 35 WLTPH increase in the plant model, as compared to a 45 WLTPH increase in the computer model. The impact of a wall offset one wind box is also shown. The wall results in a loss of about 10 LTPH under low flow conditions, and an increase in flow of about 4 LTPH under the high 3A flow conditions.

3.8.8.2.2 Calculated Flow to Kiln vs Total Cooler Flow: Figure 168 is a second comparison of flow to the kiln. The flows are slightly different from those shown in figure 163, but the trends are essentially the same.

3.8.8.2.3 Fuel Consumption vs Total Cooler Flow: Figure 169 plots fuel consumption as a function of cooler flow. Fuel consumption decreases as cooler flow increases. The plant model has a steeper slope, intersecting the computer simulation at about 28,000 lbs/min. Under low flow conditions, the computer model predicted about 30,000 BTU/LT lower fuel than the plant model. Under the high flow conditions, the computer prediction was about 30,000 BTU/LT higher. The effect of the wall in the MEDUSA/CFD simulations resulted in a 20,000 BTU/LT increase in fuel consumption under low flow conditions and a 10,000 BTU/LT decrease under high flow conditions, relative to the simulations without a wall.

3.8.8.2.4 Section Summary: The plant data model yielded trends similar to those in the MEDUSA/CFD simulations. Feed rate predictions were offset about 25 WLTPH, but the slopes in the trends were nearly the same. For fuel consumption, the slope in the plant data was steeper over the flow range, indicating a greater sensitivity to cooler conditions. Improvement in model fit might also be attained by performing the full factorial design, instead of the one third used in this study, and by including the kiln solids discharge temperature as a variable in the CFD model design. MEDUSA calculates the kiln solids discharge temperature, and the greater the deviation between the MEDUSA value and the assumed CFD value, the greater the error in cooler heat flows. However, adding another variable to the CFD cooler design increases the full factorial simulations from 81 to 243, and the one third design from 27 to 81. Computer resources would have to at least double to keep the analysis on

a reasonable time frame, or if a long range plan to model the current cooler in significantly more detail were approved, such an experimental design could be achieved over a three to six month time frame.

3.9 Conclusions:

3.9.1 General:

3.9.1.1 A three dimensional CFD cooler model was developed , validated and used to predict cooler performance over a range of plant operating conditions.

3.9.1.2 The MEDUSA mass and energy balance model has been validated against an operating Grate-Kiln induration line and proven capable of predicting plant performance with regard to changes in feed rate and fuel consumption.

3.9.1.3 An analytical method was developed using the CFD and MEDUSA models to optimize a Grate-Kiln induration line.

3.9.2 Specific to Minntac Line 6:

3.9.2.1 The waste gas fan appears undersized on Line 6 and probably limits furnace performance. The cooler does not appear to present any limitations under the conditions tested.

3.9.2.2 The computer simulations predicted an optimum cooler fan flow combination for maximum production and minimum fuel consumption. The plant tests duplicated this optimum, and indicated that the plant operates in this region most of the time.

3.9.2.3 Impact of a Cooler Wall:

3.9.2.3.1 Without a wall, the 3A and 3B fans are interdependent, and as a result, the 3B fan must be operated in manual to avoid affecting 3A fan operation.

3.9.2.3.2 A wall placed in the original location, aligned with the under bed damper, will restrict 3A fan flow to about 50% of its operating range, using firing hood pressure as an operating constraint.

3.9.2.3.3 A wall offset by one wind box from the original location, moving into the primary cooling zone, has the potential to increase production up to 94,500 LTPY. The production benefit is dependent on cooler fan operation, and on waste gas fan operation. The 3B cooler fan must be placed under automatic control, and the waste gas fan flow must be maximized at all times. If the waste gas fan is not maximized, 3B fan flow may be restricted, and cooling efficiency lost.

3.10 Recommendations:

3.10.1 General:

3.10.1.1 A complete factorial CFD model series should be completed and compared against the one third design used in this study, to test for non-linearity and overall accuracy.

3.10.1.2 A database model should be developed from the CFD simulations, for prediction of cooler responses to operating conditions. The list of control variables should also include kiln solids discharge temperature, cooler fan inlet air temperature, recoup duct outlet pressure, parallel flow duct outlet pressure, bed depth, bed permeability and pellet bulk density.

3.10.1.3 CMRL should purchase additional workstations to improve cooler simulation turn around time.

3.10.1.4 The cooler model should be used to study changes in cooler operating conditions under the Svedala Ported Kiln concept.

3.10.1.5 A more detailed analysis of pressure drop across the bed as function of air flow and bed characteristics should be performed.

3.10.2 Specific to Minntac Line 6:

3.10.2.1 A comprehensive study should be performed to isolate the causes of the oscillations in the Line 6 process fans, looking at filter, balling line, and roller screen operation.

3.10.2.2 Waste gas fan performance should be fully investigated, to determine if modifications can be made that would increase fan capacity.

3.10.2.3 A waste gas fan test should be conducted with this fan in manual at 90 to 100 % open damper, to test maximized recoup flow conditions in the plant. This test should last 5-10 days minimum.

3.10.2.4 A study of waste gas fan capacity could be conducted to define process productivity as a function of waste gas fan capacity. This study could also evaluate the relative sizes of the DD1 and DD2 drying zones, and substitution of hydrate lime for limestone on firing cycle.

3.10.2.5 An overbed dividing wall should be installed in the Line 6 cooler, offset one wind box from the under bed damper moving into the primary cooling zone (wind boxes 6/7 see Figure 34). A simulation series evaluating the two wind box offset, could also be completed for comparison to aid in determining the final wall location.

TABLE 1
MINNTAC COOLER INITIAL VALIDATION TEST SUMMARY

| TEST DESCRIPTION | | GREEN BALL | | PRODUCTION FACTOR | | COOLER FEED RATE | | 3A FAN | | 3B FAN | | |
|------------------|-------------|------------|----------------|---------------------|---------|------------------|---------|---------|-------|---------|-------|---------|
| DATE | TIMES | ID | RATE WLTLPH | PRORATED RECYCLE | METH. 1 | METH. 2 | METH. 1 | METH. 2 | AMPS | LBS/MIN | AMPS | LBS/MIN |
| NOV 19, 1998 | 12:30-13:31 | RUN 1 | 537.46 | 38.36 | 0.77 | 0.789 | 413.84 | 424.06 | 104.0 | 10,366 | 141.0 | 15,968 |
| NOV 19, 1998 | 15:47-16:58 | RUN 3 | 536.61 | 47.51 | 0.77 | 0.771 | 413.19 | 413.73 | 117.0 | 14,074 | 119.0 | 12,554 |
| FEB 11, 1999 | 13:34-14:40 | RUN 1 | 545.89 | 36.56 | 0.77 | 0.793 | 420.34 | 432.89 | 114.8 | 12,985 | 137.3 | 14,822 |
| FEB 11, 1999 | 14:32-16:38 | RUN 2 | 545.51 | 39.13 | 0.77 | 0.788 | 420.04 | 429.86 | 117.1 | 13,402 | 130.6 | 13,721 |
| FEB 17, 1999 | 08:40-14:02 | RUN 1 | 540.06 | 61.60 | 0.77 | 0.746 | 415.85 | 402.88 | 117.6 | 13,408 | 136.2 | 14,259 |
| FEB 17, 1999 | 14:04-18:00 | RUN 2 | 543.6 | 59.68 | 0.77 | 0.750 | 418.57 | 407.70 | 122.2 | 14,473 | 126.7 | 13,019 |
| FEB 17, 1999 | 18:02-22:02 | RUN 3 | 545.5 | 60.51 | 0.77 | 0.749 | 420.04 | 408.58 | 125.8 | 15,411 | 120.1 | 11,321 |
| FEB 17, 1999 | 22:04-06:00 | RUN 4 | 543.12 | 59.56 | 0.77 | 0.750 | 418.20 | 407.34 | 119.6 | 14,090 | 136.5 | 14,438 |
| APR 19, 1999 | 13:22-17:04 | RUN 1 | 549.05 | 67.76 | 0.77 | 0.737 | 422.77 | 404.65 | 115.3 | 13,823 | 116.2 | 12,105 |
| APR 19, 1999 | 17:06-21:02 | RUN 2 | 535.01 | 76.87 | 0.77 | 0.716 | 411.96 | 383.07 | 104.6 | 11,333 | 125.9 | 13,621 |
| APR 19, 1999 | 21:04-00:44 | RUN 3 | 548.77 | 70.70 | 0.77 | 0.731 | 422.55 | 401.15 | 101.6 | 10,329 | 137.0 | 15,355 |
| APR 19, 1999 | 02:14-07:12 | RUN 4 | 546.56 | 72.67 | 0.77 | 0.727 | 420.85 | 397.35 | 106.3 | 11,731 | 127.1 | 13,854 |
| APR 19, 1999 | 07:14-0:814 | RUN 5 | 546.71 | 78.45 | 0.77 | 0.716 | 420.97 | 391.44 | 105.1 | 11,493 | 124.6 | 13,406 |

3-47

COOLER FEED RATE CALCULATION

METHOD 1 GREENBALL RATE X PRODUCTION FACTOR₁
 METHOD 2 (GREEN BALL RATE - PRORATED LINE 6 FINES RECYCLE) X (PRODUCTION FACTOR₂)

METHOD 1 PRODUCTION FACTOR₁ = 0.77
 METHOD 2 PRODUCTION FACTOR₂ = 1-(NET FURNACE LOSS)
 NET FURNACE LOSS = MOISTURE+ CALCINATION - OXIDATION GAIN + DUST/SPILLAGE LOSS = 0.14

| | %WT | % LOI/GOI | FACTOR |
|-----------------|------|-----------|--------|
| AVE MOISTURE = | 9.5 | 100.00 | 0.095 |
| AVE LIMESTONE = | 8.0 | 44.00 | 0.035 |
| AVE MAGNETITE = | 87.0 | 3.45 | -0.020 |
| EST DUST LOSS = | 2.9 | 100.00 | 0.029 |
| TOTAL | | | 0.140 |

65% ON GRATE

METHOD 2 PRODUCTION FACTOR₂ = 1-(.14+RECYCLE/FEED)

TABLE 2:
MINNTAC PLANT VALIDATION TESTS

NOVEMBER 19, 1998 TESTS

| | | | | USX | | USX | | CFD | |
|-----------------------------------------|--------|---------|---------|------------|-----------|-----------|----------|-----------|-----------|
| | | | | RUN 1 | CFD | CFD | RUN 3 | RUN 3_1 | RUN 18 |
| | | | | 11/19/98 | 1_20_0800 | 1_21_0705 | 11/19/98 | 1_22_0735 | 3_16_0830 |
| GREENBALL FEED RATE | | LTPH | | 537.46 | NA | NA | 536.61 | NA | NA |
| PRODUCTION FACTOR METHOD 1 | | | | 0.77 | NA | NA | 0.77 | NA | NA |
| RECYCLE PRORATED PROD FACT. METHOD 2 | | | | 0.79 | | | 0.77 | | |
| PELLET FEED TO COOLER METH. 1 | | LTPH | | 413.84 | 413.79 | 413.79 | 413.19 | 413.79 | 413.79 |
| PRORATED FEED TO COOLER METH. 2 | | | | 423.86 | | | 413.67 | | |
| GREENBALL MAGNETITE %WT | | | | NA | 87.00 | 87.00 | NA | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | 4.56-6.94 | 3.86 | 6.75 | NA | 6.75 | 5.31 |
| FE3O4 IN COOLER FEED (FE3O4=FE++/.2412) | | %WT | | 18.9 -28.8 | 16.00 | 28.00 | NA | 28.00 | 22 |
| PELL. TEMP 15' FROM KILN DISCHG | | DEGF | | 2,262 | NA | NA | 2,284 | NA | NA |
| AVG PELLET TEMP ENTERING COOLER | | DEGF | | NA | 2,199 | 2,199 | NA | 2,199 | 2,250 |
| COOLER SPEED | | IN/MIN | | 122 | 91 | 91 | 116 | 91 | |
| COOLER BED DEPTH | | IN | | 28 | 28 | 28 | 28 | 28 | |
| PRI. COOLING ZONE | 3A FAN | FLOW | LBS/MIN | 10,366 | 10,366 | 10,884 | 14,074 | 14,074 | 14,074 |
| | | G/S | | 0.6551 | | | 0.9113 | | |
| | | POWER | AMPS | 104 | NA | NA | 117 | NA | NA |
| | | INLET | DEGF | 19 | 19.4 | 19.4 | 16 | 19.4 | 19.4 |
| | | O'BED | IN.H2O | -0.119 | -0.105 | -0.059 | 0.030 | 0.022 | -0.037 |
| | | U'BED | IN.H2O | 14.385 | 14.140 | 14.920 | 15.686 | 17.450 | 16.86 |
| | | KFACT | | NA | 545 | 545 | NA | 545 | 545 |
| KILN SECONDARY AIR | | PLANT | DEGF | 2,047 | NA | NA | 2,051 | NA | NA |
| | | AVG | DEGF | NA | 2,194 | 2,265 | NA | 2,166 | 2,219 |
| | | | LBS/MIN | NA | 4,740 | 5,027 | NA | 5,582 | 5,139 |
| | | OUTLET | INH2O | NA | -0.40 | -0.40 | NA | -0.40 | -0.40 |
| FURNACE PHEAT O'BED | | INH2O | | -0.584 | NA | NA | -0.506 | NA | NA |
| | | LBS/MIN | | 23,199 | NA | NA | 22,951 | NA | NA |
| | | G/S | | 1.4661 | | | 1.4861 | | |
| FIRING HOOD AIR | | DEGF | | NA | 2,216 | 2,245 | NA | 2,235 | 2,297 |
| | | LBS/MIN | | NA | 2,747 | 2,834 | NA | 3,055 | 2,851 |
| | OUTLET | INH2O | | NA | -0.73 | -0.73 | NA | -0.73 | -0.73 |
| WINDBOX LEAKAGE | | LBS/MIN | | NA | 861 | 887 | NA | 974 | 3,306 |
| GAP HEIGHT | | INCHES | | NA | 1 | 1 | NA | 1 | 3.62 |
| WINDBOX DAMPER POSITION | | | | OPEN | OPEN | OPEN | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | INCHES | | NA | NA | NA | 4.7 | 1.67 | |
| SEC. COOLING ZONE | 3B FAN | FLOW | LBS/MIN | 15,968 | 15,969 | 16,767 | 12,554 | 12,554 | 12,554 |
| | | G/S | | 1.0091 | | | 0.8129 | | |
| | | POWER | AMPS | 141 | NA | NA | 119 | NA | NA |
| | | INLET | DEGF | 19 | 19.4 | 19.4 | 16 | 19.4 | 19.4 |
| | | O'BED | IN.H2O | -0.113 | -0.088 | -0.015 | -0.169 | -0.175 | -0.2457 |
| | | U'BED | IN.H2O | 14.493 | 14.030 | 14.810 | 10.449 | 11.600 | 10.52 |
| RECOUP B SIDE (WB 9) | | PLANT | DEGF | 1,607 | 1600-1625 | 1652-1668 | 1,558 | 1350-1370 | |
| | | AVG | DEGF | NA | 1,647 | 1,684 | NA | 1,423 | 1,547 |
| | | | LBS/MIN | NA | 2,862 | 2,946 | NA | 2,921 | 2,728 |
| | | OUTLET | INH2O | NA | -1.00 | -1.00 | NA | -1.00 | -1.00 |
| FURNACE DD2 O'BED | | INH2O | | -1.007 | NA | NA | -0.979 | NA | NA |
| | | DEGF | | 1,171 | NA | NA | 1,156 | NA | NA |
| RECOUP A SIDE (WB10) | | PLANT | DEGF | 1,348 | 1297-1398 | 1296-1409 | 1,282 | 1140-1220 | |
| | | AVG | DEGF | NA | 1,279 | 1,285 | NA | 1,121 | 1,265 |
| | | | LBS/MIN | NA | 3,314 | 3,441 | NA | 3,321 | 3,059 |
| | | OUTLET | INH2O | NA | -1.00 | -1.00 | NA | -1.00 | -1.00 |
| COOLER VENT STACK | | PLANT | DEGF | 727 | NA | NA | 687 | NA | NA |
| | | AVG | DEGF | NA | 508 | 483 | NA | 527 | 584 |
| | | | LBS/MIN | 13,131 | 11,296 | 11,978 | 12,176 | 10,339 | 9,511 |
| | | OUTLET | INH2O | NA | -0.88 | -0.88 | NA | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | | | | | | | |
| WINDBOX LEAKAGE | | LBS/MIN | | NA | 581 | 594 | NA | 537 | 153 |
| GAP HEIGHT | | INCHES | | NA | 1 | 1 | NA | 1.0 | 1.0 |
| O'BED LEAKAGE | | LBS/MIN | | NA | (68) | (58) | NA | (101) | (119) |
| GAP HEIGHT | | INCHES | | NA | 1 | 1 | NA | 1 | 1 |
| TOTAL AIR IN | | LBS/MIN | | | 26,403 | 27,710 | | 26,729 | 26,747 |
| TOTAL AIR OUT | | LBS/MIN | | | 26,401 | 27,708 | | 26,729 | 26,746 |

NOTES:

1. RECOUP B SIDE TC LOCATION IN CFD IS 20-70 F COLDER THAN AVE. OUT
2. RECOUP A SIDE TC LOCATION IN CFD IS 20-120 F HOTTER THAN AVE. OUT
3. GAP ON VENT STACK SEPARATION WALL IS 8"
4. CFD PRESSURES CORRESPOND TO APPROX PLANT SENSOR LOCATIONS

TABLE 2:
MINNTAC PLANT VALIDATION TESTS

FEBRUARY 11, 1999 TESTS

| | | | | USX | CFD | | USX | CFD | |
|-----------------------------------------|--------|---------|---------|---------|--------------|-----------|----------|-----------|-----------|
| | | | | RUN 1 | RUN_4 | RUN 17 | RUN 2 | RUN 5 | RUN 16 |
| | | | | 2/11/99 | 2_17_99_0800 | 3_15_0800 | 02/11/99 | 2_18_2202 | 3_12_0855 |
| GREENBALL FEED RATE | | LTPH | | 545.89 | NA | NA | 545.51 | NA | NA |
| PRODUCTION FACTOR METHOD 1 | | | | 0.77 | NA | NA | 0.77 | NA | NA |
| RECYCLE PRORATED PROD FACT. METHOD 2 | | | | 0.79 | | | 0.79 | | |
| PELLET FEED TO COOLER METH. 1 | | LTPH | | 420.34 | 420.33 | 420.33 | 420.04 | 420.33 | 420.33 |
| PRORATED FEED TO COOLER METH. 2 | | | | 432.88 | | | 430.03 | | |
| GREENBALL MAGNETITE %WT | | | | NA | 87.00 | 87.00 | NA | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | NA | 5.31 | 5.31 | NA | 5.31 | 5.31 |
| FE3O4 IN COOLER FEED (FE3O4=FE++/.2412) | | %WT | | NA | 22 | 22 | NA | 22 | 22 |
| PELL. TEMP 15' FROM KILN DISCHG | | DEGF | | 2,272 | NA | NA | 2,270 | NA | NA |
| AVG PELLET TEMP ENTERING COOLER | | DEGF | | NA | 2,199 | 2,250 | NA | 2,199 | 2,250 |
| COOLER SPEED | | IN/MIN | | 119.3 | 92 | | 119.1 | | |
| COOLER BED DEPTH | | IN | | 28 | 28 | | 28 | | |
| PRI. COOLING ZONE | 3A FAN | FLOW | LBS/MIN | 12,985 | 12,985 | 12,985 | 13,403 | 13,402 | 13,402 |
| | | G/S | | 0.8035 | | | 0.8348 | | |
| | | POWER | AMPS | 114.83 | NA | NA | 117.05 | NA | NA |
| | | INLET | DEGF | 13 | 12.2 | 12.2 | 12.6 | 12.2 | 12.2 |
| | | O'BED | IN.H2O | 0.05 | 0.024 | -0.042 | 0.0415 | 0.022 | -0.0436 |
| | | U'BED | IN.H2O | 16.16 | 16.990 | 16.17 | 16.2 | 17.18 | 16.45 |
| | | KFACT | | NA | 545 | 545 | NA | 545 | 545 |
| KILN SECONDARY AIR | | PLANT | DEGF | 2,057 | NA | NA | 2,055 | NA | NA |
| | | AVG | DEGF | NA | 2,146 | 2,249 | NA | 2,142 | 2,243 |
| | | | LBS/MIN | NA | 5,652 | 5,115 | NA | 5,619 | 5,095 |
| | | OUTLET | INH2O | NA | -0.40 | -0.40 | NA | -0.40 | -0.40 |
| FURNACE PHEAT O'BED | | INH2O | | -0.55 | NA | NA | -0.56 | NA | NA |
| | | LBS/MIN | | 23,501 | NA | NA | 23,336 | NA | NA |
| | | | G/S | 1.4542 | | | 1.4536 | | |
| FIRING HOOD AIR | | | DEGF | NA | 2,222 | 2,297 | NA | 2,221 | 2,297 |
| | | | LBS/MIN | NA | 3,020 | 2,819 | NA | 3,026 | 2,826 |
| | | OUTLET | INH2O | NA | -0.73 | -0.73 | NA | -0.73 | -0.73 |
| WINDBOX LEAKAGE | | | LBS/MIN | NA | 952 | 3,215 | NA | 960 | 3,249 |
| GAP HEIGHT | | | INCHES | NA | 1 | 3.62 | NA | 1 | 3.62 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | | INCHES | | 4.7 | 1.67 | | 4.7 | 1.67 |
| SEC. COOLING ZONE | 3B FAN | FLOW | LBS/MIN | 14,822 | 14,818 | 14,818 | 13,721 | 13,720 | 13,720 |
| | | G/S | | 0.9172 | | | 0.8547 | | |
| | | POWER | AMPS | 137.31 | NA | NA | 130.62 | NA | NA |
| | | INLET | DEGF | 13 | 12.2 | 12.2 | 13 | 12.2 | 12.2 |
| | | O'BED | IN.H2O | -0.15 | -0.104 | -0.145 | -0.175 | -0.147 | -0.191 |
| | | U'BED | IN.H2O | 14.07 | 12.5 | 12.22 | 12.5 | 11.91 | 11.49 |
| RECOUP B SIDE (WB 9) | | PLANT | DEGF | 1528 | NA | NA | 1522 | NA | NA |
| | | AVG | DEGF | NA | 1,422 | 1,622 | NA | 1,416 | 1,609 |
| | | | LBS/MIN | NA | 3,032 | 2,825 | NA | 2,973 | 2,765 |
| | | OUTLET | INH2O | NA | -1.00 | -1.00 | NA | -1.00 | -1.00 |
| FURNACE DD2 O'BED | | INH2O | | -1.04 | NA | NA | -1.06 | NA | NA |
| | | DEGF | | 1,151 | NA | NA | 1,153 | NA | NA |
| RECOUP A SIDE (WB10) | PLANT | DEGF | | 1,293 | | | 1,308 | | |
| | AVG | DEGF | | NA | 1,102 | 1,290 | NA | 1,111 | 1,303 |
| | | LBS/MIN | | NA | 3,481 | 3,218 | NA | 3,390 | 3,125 |
| | OUTLET | INH2O | | NA | -1.00 | -1.00 | NA | -1.00 | -1.00 |
| COOLER VENT STACK | PLANT | DEGF | | 687 | NA | NA | 690 | NA | NA |
| | AVG | DEGF | | NA | 471 | 541 | NA | 498 | 574 |
| | | LBS/MIN | | 12,500 | 11,197 | 10,543 | 12,274 | 10,704 | 10,007 |
| | OUTLET | INH2O | | NA | -0.88 | -0.88 | NA | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | | 258.8 | 291.2 | | 284 | 320 | |
| WINDBOX LEAKAGE | | LBS/MIN | | NA | 556 | 158 | NA | 545 | 156 |
| GAP HEIGHT | | INCHES | | NA | 1.0 | 1.0 | NA | 1.0 | 1.0 |
| O'BED LEAKAGE | | LBS/MIN | | NA | (83) | (89) | NA | (93) | (101) |
| GAP HEIGHT | | INCHES | | NA | 1 | 1 | NA | 1 | 1 |
| TOTAL AIR IN | | LBS/MIN | | | 27,886 | 27,891 | | 27,214 | 27,223 |
| TOTAL AIR OUT | | LBS/MIN | | | 27,890 | 27,892 | | 27,217 | 27,223 |

NOTES:

1. RECOUP B SIDE TC LOCATION IN CFD IS 20-70 F COLDER THAN AVE. OUT
2. RECOUP A SIDE TC LOCATION IN CFD IS 20-120 F HOTTER THAN AVE. OUT
3. GAP ON VENT STACK SEPARATION WALL IS 8"
4. CFD PRESSURES CORRESPOND TO APPROX PLANT SENSOR LOCATIONS

TABLE 2:
MINNTAC PLANT VALIDATION TESTS

3 OF 7

FEBRUARY 17, 1999 TESTS

| | | | | USX | CFD | | USX | CFD | CFD |
|-----------------------------------------|---------------|---------|---------|---------|-----------|-----------|---------|-----------|-----------|
| | | | | RUN 1 | RUN 6 | RUN 15 | RUN 2 | RUN 7 | RUN 14 |
| | | | | 2/17/99 | 2_24_0740 | 3_11_0735 | 2/17/99 | 2_25_0720 | 3_10_0930 |
| GREENBALL FEED RATE | | LTPH | | 540.06 | NA | NA | 543.6 | NA | NA |
| PRODUCTION FACTOR METHOD 1 | | | | 0.77 | NA | NA | 0.77 | NA | NA |
| RECYCLE PRORATED PROD FACT. METHOD 2 | | | | 0.75 | | | 0.75 | | |
| PELLET FEED TO COOLER METH. 1 | | LTPH | | 415.85 | 415.85 | 415.85 | 418.57 | 418.57 | 418.57 |
| PRORATED FEED TO COOLER METH. 2 | | | | 402.89 | | | 407.80 | | |
| GREENBALL MAGNETITE %WT | | | | NA | 87.00 | 87.00 | NA | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | NA | 5.31 | 5.31 | NA | 5.31 | 5.31 |
| FE3O4 IN COOLER FEED (FE3O4=FE++/.2412) | | %WT | | NA | 22 | 22 | NA | 22 | 22 |
| PELL. TEMP 15' FROM KILN DISCHG | | DEGF | | 2,259 | NA | NA | 2269 | NA | NA |
| AVG PELLET TEMP ENTERING COOLER | | DEGF | | NA | 2,199 | 2,250 | NA | 2,199 | 2,250 |
| COOLER SPEED | | IN/MIN | | 116.2 | | | 117.6 | 92 | 92 |
| COOLER BED DEPTH | | IN | | 28 | | | 28 | | |
| PRI. COOLING ZONE | 3A FAN | FLOW | LBS/MIN | 13,408 | 13,407 | 13,407 | 14,473 | 14,472 | 14,472 |
| | | G/S | | 0.8914 | | | 0.9506 | | |
| | | POWER | AMPS | 117.66 | NA | NA | 122.17 | NA | NA |
| | | INLET | DEGF | 4.5 | 3.2 | 3.2 | 13 | 12.2 | 12.2 |
| | | O'BED | IN.H2O | 0.025 | 0.0278 | -0.0364 | 0.0266 | 0.0578 | -0.0072 |
| | | U'BED | IN.H2O | 18.125 | 17.11 | 18.4 | 17.45 | 17.85 | 17.26 |
| | | KFACT | | NA | 545 | 545 | NA | 545 | 545 |
| KILN SECONDARY AIR | | PLANT | DEGF | 2,036 | NA | NA | 2,036 | | |
| | | AVG | DEGF | NA | 2,130 | 2,233 | NA | 2,101 | 2,202 |
| | | | LBS/MIN | NA | 5,682 | 5,161 | NA | 5,875 | 5,363 |
| | | OUTLET | INH2O | NA | -0.40 | -0.40 | NA | -0.40 | -0.40 |
| FURNACE PHEAT O'BED | | INH2O | | -0.495 | NA | NA | -0.544 | NA | NA |
| | | | LBS/MIN | 23,328 | NA | NA | 23,846 | NA | NA |
| | | | G/S | 1.5509 | | | 1.5663 | | |
| FIRING HOOD AIR | | | DEGF | NA | 2,221 | 2,296 | NA | 2,218 | 2,295 |
| | | | LBS/MIN | NA | 3,034 | 2,838 | NA | 3,114 | 2,913 |
| | | OUTLET | INH2O | NA | -0.73 | -0.73 | NA | -0.73 | -0.73 |
| WINDBOX LEAKAGE | | | LBS/MIN | NA | 957 | 3,239 | NA | 984 | 3,346 |
| GAP HEIGHT | | | INCHES | NA | 1 | 3.62 | NA | 1 | 3.62 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | | INCHES | | 4.7 | 1.67 | | 4.7 | 1.67 |
| SEC. COOLING ZONE | 3B FAN | FLOW | LBS/MIN | 14,259 | 14,259 | 14,259 | 13,019 | 13,020 | 13,020 |
| | | G/S | | 0.9480 | | | 0.8551 | | |
| | | POWER | AMPS | 136.17 | NA | NA | 126.72 | NA | NA |
| | | INLET | DEGF | 4.5 | 3.2 | 3.2 | 13 | 12.2 | 12.2 |
| | | O'BED | IN.H2O | -0.188 | -0.1307 | -0.1745 | -0.22 | -0.167 | -0.2185 |
| | | U'BED | IN.H2O | 13.26 | 11.99 | 11.6 | 11.649 | 11.33 | 10.68 |
| RECOUP B SIDE (WB 9) | | PLANT | DEGF | 1,507 | | | 1,483 | | |
| | | AVG | DEGF | NA | 1,377 | 1,570 | NA | 1,326 | 1,505 |
| | | | LBS/MIN | NA | 3,032 | 2,821 | NA | 3,028 | 2,810 |
| | | OUTLET | INH2O | NA | -1.00 | -1.00 | NA | -1.00 | -1.00 |
| FURNACE DD2 O'BED | | INH2O | | -1.000 | NA | NA | -0.988 | NA | NA |
| | | | DEGF | 1,111 | NA | NA | 1,113 | NA | NA |
| RECOUP A SIDE (WB10) | PLANT | DEGF | | 1,285 | | | 1,286 | | |
| | AVG | DEGF | | NA | 1,065 | 1,255 | NA | 1,035 | 1,220 |
| | | | LBS/MIN | NA | 3,474 | 3,202 | NA | 3,438 | 3,158 |
| | OUTLET | INH2O | | NA | -1.00 | -1.00 | NA | -1.00 | -1.00 |
| COOLER VENT STACK | PLANT | DEGF | | 625 | NA | NA | 676 | NA | NA |
| | AVG | DEGF | | | 459 | 530 | | 478 | 551 |
| | | | LBS/MIN | 13,596 | 11,032 | 10,350 | 13,610 | 10,620 | 9,862 |
| | OUTLET | INH2O | | NA | -0.88 | -0.88 | NA | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | | | 251.6 | 284 | | 276.8 | 309.2 |
| WINDBOX LEAKAGE | | LBS/MIN | | NA | 544 | 155 | NA | 533 | 152 |
| GAP HEIGHT | | INCHES | | NA | 1.0 | 1.0 | NA | 1.0 | 1.0 |
| O'BED LEAKAGE | | LBS/MIN | | NA | (89) | (97) | NA | (102) | (113) |
| GAP HEIGHT | | INCHES | | NA | 1 | 1 | NA | 1 | 1 |
| | TOTAL AIR IN | LBS/MIN | | | 27,756 | 27,763 | | 27,593 | 27,605 |
| | TOTAL AIR OUT | LBS/MIN | | | 27,755 | 27,764 | | 27,594 | 27,604 |

NOTES:

1. RECOUP B SIDE TC LOCATION IN CFD IS 20-70 F COLDER THAN AVE. OUT
2. RECOUP A SIDE TC LOCATION IN CFD IS 20-120 F HOTTER THAN AVE. OUT
3. GAP ON VENT STACK SEPARATION WALL IS 8"
4. CFD PRESSURES CORRESPOND TO APPROX PLANT SENSOR LOCATIONS

TABLE 2:
MINNTAC PLANT VALIDATION TESTS

FEBRUARY 17, 1999 TESTS

| | | | | USX | CFD | CFD | USX | CFD | CFD |
|-----------------------------------------|--------|---------|---------|---------|-----------|--------|---------|----------|----------|
| | | | | RUN 3 | RUN 8 | RUN 13 | RUN 4 | RUN 9 | RUN 10 |
| | | | | 2/17/99 | 2_26_0725 | 3_09_ | 2/17/99 | 3_1_0725 | 3_2_0900 |
| GREENBALL FEED RATE | | LTPH | | 545.5 | NA | NA | 543.1 | NA | NA |
| PRODUCTION FACTOR METHOD 1 | | | | 0.77 | NA | NA | 0.77 | NA | NA |
| RECYCLE PRORATED PROD FACT. METHOD 2 | | | | 0.75 | | | 0.75 | | |
| PELLET FEED TO COOLER METH. 1 | | LTPH | | 420.04 | 418.57 | 418.57 | 418.19 | 418.57 | 418.57 |
| PRORATED FEED TO COOLER METH. 2 | | | | 408.63 | | | 407.57 | | |
| GREENBALL MAGNETITE %WT | | | | NA | 87.00 | 87.00 | NA | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | NA | 5.31 | 5.31 | NA | 5.31 | 5.31 |
| FE3O4 IN COOLER FEED (FE3O4=FE++/.2412) | | %WT | | NA | 22 | 22 | NA | 22 | 22 |
| PELL. TEMP 15' FROM KILN DISCHG | | DEGF | | 2268 | NA | NA | 2268 | NA | NA |
| AVG PELLET TEMP ENTERING COOLER | | DEGF | | NA | 2,199 | 2,250 | NA | 2,199 | 2,250 |
| COOLER SPEED | | IN/MIN | | 119.4 | 92 | 92 | 118.6 | 92 | 92 |
| COOLER BED DEPTH | | IN | | 28 | | | 28 | | |
| PRI. COOLING ZONE | 3A FAN | FLOW | LBS/MIN | 15,411 | 15,412 | 15,412 | 14,091 | 14,091 | 14,091 |
| | | G/S | | 1.0102 | | | 0.9261 | | |
| | | POWER | AMPS | 125.84 | NA | NA | 119.64 | NA | NA |
| | | INLET | DEGF | 5.5 | 5 | 5 | 1.3 | 1.4 | 1.4 |
| | | O'BED | IN.H2O | -0.028 | 0.0671 | 0.0042 | 0.0652 | 0.0665 | 0.123 |
| | | U'BED | IN.H2O | 17.69 | 18.3 | 17.86 | 16.765 | 17.65 | 19.02 |
| | | KFACT | | NA | 545 | 545 | NA | 545 | 545 |
| KILN SECONDARY AIR | | PLANT | DEGF | 2,027 | | | 2,029 | | |
| | | AVG | DEGF | NA | 2,085 | 2,182 | NA | 2,101 | 2,122 |
| | | | LBS/MIN | NA | 5,915 | 5,431 | NA | 5,957 | 6,274 |
| | | OUTLET | INH2O | NA | -0.40 | -0.40 | NA | -0.40 | -0.40 |
| FURNACE PHEAT O'BED | | INH2O | | -0.625 | NA | NA | -0.516 | NA | NA |
| | | LBS/MIN | | 24,094 | NA | NA | 23,910 | NA | NA |
| | | G/S | | 1.5794 | | | 1.5714 | | |
| FIRING HOOD AIR | | | DEGF | NA | 2,215 | 2,291 | NA | 2,219 | 2,261 |
| | | | LBS/MIN | NA | 3,159 | 2,961 | NA | 3,116 | 3,210 |
| | OUTLET | INH2O | | NA | -0.73 | -0.73 | NA | -0.73 | -0.73 |
| WINDBOX LEAKAGE | | | LBS/MIN | NA | 1,000 | 3,415 | NA | 974 | 1,006 |
| GAP HEIGHT | | | INCHES | NA | 1 | 3.62 | NA | 1 | 1 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | | INCHES | | 4.7 | 1.67 | | 4.7 | 1.67 |
| SEC. COOLING ZONE | 3B FAN | FLOW | LBS/MIN | 11,321 | 11,321 | 11,321 | 14,438 | 14,438 | 14,438 |
| | | G/S | | 0.7421 | | | 0.9489 | | |
| | | POWER | AMPS | 120.06 | NA | NA | 136.54 | NA | NA |
| | | INLET | DEGF | 5.5 | 5 | 5 | 1.3 | 1.4 | 1.4 |
| | | O'BED | IN.H2O | -0.342 | -0.231 | -0.289 | -0.136 | -0.1125 | -0.157 |
| | | U'BED | IN.H2O | 8.711 | 10.26 | 9.39 | 13.389 | 11.97 | 10.53 |
| RECOUP B SIDE (WB 9) | | PLANT | DEGF | 1,433 | | | 1,476 | | |
| | | AVG | DEGF | NA | 1,296 | 1,466 | NA | 1,314 | 1,288 |
| | | | LBS/MIN | NA | 2,965 | 2,743 | NA | 3,128 | 3,136 |
| | | OUTLET | INH2O | NA | -1.00 | -1.00 | NA | -1.00 | -1.00 |
| FURNACE DD2 O'BED | | INH2O | | -1.083 | NA | NA | -0.945 | NA | NA |
| | | DEGF | | 1,098 | NA | NA | 1,108 | NA | NA |
| RECOUP A SIDE (WB10) | PLANT | DEGF | | 1,303 | | | 1,268 | | |
| | AVG | DEGF | | NA | 1,015 | 1,201 | NA | 1,007 | 1,011 |
| | | LBS/MIN | | NA | 3,334 | 3,044 | NA | 3,584 | 3,532 |
| | OUTLET | INH2O | | NA | -1.00 | -1.00 | NA | -1.00 | -1.00 |
| COOLER VENT STACK | PLANT | DEGF | | 707 | NA | NA | 635 | NA | NA |
| | AVG | DEGF | | | 501 | 583 | | 432 | 420 |
| | | LBS/MIN | | 13,503 | 9,973 | 9,137 | 13,683 | 11,314 | 10,964 |
| | OUTLET | INH2O | | NA | -0.88 | -0.88 | NA | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | | | 303.8 | 339.8 | | 235.4 | |
| WINDBOX LEAKAGE | | LBS/MIN | | NA | 511 | 147 | NA | 542 | |
| GAP HEIGHT | | INCHES | | NA | 1.0 | 0.5 | NA | 1.0 | 1.0 |
| O'BED LEAKAGE | | LBS/MIN | | NA | (123) | (142) | NA | (88) | (103) |
| GAP HEIGHT | | INCHES | | NA | 1 | 1 | NA | 1 | 1 |
| TOTAL AIR IN | | LBS/MIN | | | 26,856 | 26,875 | | 28,617 | 28,632 |
| TOTAL AIR OUT | | LBS/MIN | | | 26,857 | 26,876 | | 28,616 | 28,121 |

NOTES:

1. RECOUP B SIDE TC LOCATION IN CFD IS 20-70 F COLDER THAN AVE. OUT
2. RECOUP A SIDE TC LOCATION IN CFD IS 20-120 F HOTTER THAN AVE. OUT
3. GAP ON VENT STACK SEPARATION WALL IS 8"
4. CFD PRESSURES CORRESPOND TO APPROX PLANT SENSOR LOCATIONS

TABLE 2:
MINNTAC PLANT VALIDATION TESTS

APRIL 19, 1999 TESTS

| | | | | CFD | CFD | USX | CFD | USX | CFD |
|-----------------------------------------|--------|---------------|---------|----------|----------|---------|-----------|---------|-----------|
| | | | | RUN 11 | RUN 12 | RUN 1 | RUN 19 | RUN 2 | RUN 20 |
| | | | | 3_5_0730 | 3_8_1240 | 4/19/99 | 4_22_0715 | 4/19/99 | 4_23_0725 |
| GREENBALL FEED RATE | | LTPH | | NA | NA | 549.05 | NA | 535.01 | NA |
| PRODUCTION FACTOR METHOD 1 | | | | NA | NA | 0.77 | NA | 0.77 | NA |
| RECYCLE PRORATED PROD FACT. METHOD 2 | | | | | | 0.74 | | 0.72 | |
| PELLET FEED TO COOLER METH. 1 | | LTPH | | 418.57 | 418.57 | 422.77 | 422.76 | 411.96 | 411.95 |
| PRORATED FEED TO COOLER METH. 2 | | | | | | 404.43 | | 383.20 | |
| GREENBALL MAGNETITE %WT | | | | 87.00 | 87.00 | NA | 87.00 | NA | 87.00 |
| FE++ IN COOLER FEED | | | | 5.31 | 5.31 | NA | 5.31 | NA | 5.31 |
| FE3O4 IN COOLER FEED (FE3O4=FE++/.2412) | | %WT | | 22 | 22 | NA | 22 | NA | 22 |
| PELL. TEMP 15' FROM KILN DISCHG | | DEGF | | NA | NA | 2273 | NA | 2255 | NA |
| AVG PELLET TEMP ENTERING COOLER | | DEGF | | 2,250 | 2,250 | NA | 2,250 | NA | 2,250 |
| COOLER SPEED | | IN/MIN | | 92 | 92 | 114.7 | 93 | 109.5 | 91 |
| COOLER BED DEPTH | | IN | | | | 28 | | 28 | |
| PRI. COOLING ZONE | 3A FAN | FLOW | LBS/MIN | 14,091 | 14,091 | 13,823 | 13,823 | 11,333 | 11,333 |
| | | G/S | | | | 0.9155 | | 0.7922 | |
| | | POWER | AMPS | NA | NA | 115.26 | NA | 104.6 | |
| | | INLET | DEGF | 1.4 | 1.4 | 42.3 | 42.26 | 47.5 | 47.66 |
| | | O'BED | IN.H2O | 0.0619 | 0.0001 | -0.008 | -0.069 | -0.018 | -0.138 |
| | | U'BED | IN.H2O | 18.02 | 17 | 15.46 | 16.81 | 12.66 | 14.61 |
| | | KFACT | | 545 | 545 | NA | 545 | NA | 545 |
| KILN SECONDARY AIR | | PLANT | DEGF | | | 2,028 | | 2,031 | |
| | | AVG | DEGF | 2,163 | 2,204 | NA | 2,252 | NA | 2,315 |
| | | | LBS/MIN | 5,870 | 5,439 | NA | 4,857 | NA | 4,339 |
| | | OUTLET | INH2O | -0.40 | -0.40 | NA | -0.40 | NA | -0.40 |
| FURNACE PHEAT O'BED | | | INH2O | NA | NA | -0.475 | NA | -0.356 | NA |
| | | | LBS/MIN | NA | NA | 22,379 | NA | 21,075 | NA |
| | | | G/S | | | 1.4822 | | 1.4731 | |
| FIRING HOOD AIR | | | DEGF | 2,284 | 2,294 | NA | 2,296 | NA | 2,308 |
| | | | LBS/MIN | 3,059 | 2,917 | NA | 2,797 | NA | 2,606 |
| | | OUTLET | INH2O | -0.73 | -0.73 | NA | -0.73 | NA | -0.73 |
| WINDBOX LEAKAGE | | | LBS/MIN | 2,204 | 3,306 | NA | 3,313 | NA | 3,055 |
| GAP HEIGHT | | | INCHES | 2.24 | 3.62 | NA | 3.62 | NA | 3.62 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | | INCHES | 1.67 | 1.67 | | 1.67 | | 1.67 |
| SEC. COOLING ZONE | 3B FAN | FLOW | LBS/MIN | 14,438 | 14,438 | 12,105 | 12,104 | 13,621 | 13,622 |
| | | G/S | | | | 0.8017 | | 0.9521 | |
| | | POWER | AMPS | NA | NA | 116.15 | NA | 125.89 | NA |
| | | INLET | DEGF | 1.4 | 1.4 | 42.3 | 42.26 | 47.5 | 47.66 |
| | | O'BED | IN.H2O | -0.15 | -0.16 | -0.331 | -0.303 | -0.279 | -0.214 |
| | | U'BED | IN.H2O | 11.08 | 11.48 | 9.58 | 10.7 | 11.78 | 12.38 |
| RECOUP B SIDE (WB 9) | | PLANT | DEGF | | | 1,526 | | 1,622 | |
| | | AVG | DEGF | 1,386 | 1,496 | NA | 1,626 | NA | 1,816 |
| | | | LBS/MIN | 3,035 | 2,909 | 2635 | 3,026 | 2450 | 2,738 |
| | | OUTLET | INH2O | -1.00 | -1.00 | -1.3 | -1.30 | | -1.10 |
| FURNACE DD2 O'BED | | | INH2O | NA | NA | -1.23 | NA | -1.07 | NA |
| | | | DEGF | NA | NA | 1,104 | NA | 1,202 | NA |
| RECOUP A SIDE (WB10) | | PLANT | DEGF | | | 1,291 | | 1,358 | |
| | | AVG | DEGF | 1,091 | 1,187 | NA | 1,343 | NA | 1,487 |
| | | | LBS/MIN | 3,437 | 3,302 | 2,308 | 3,039 | 2,171 | 2,713 |
| | | OUTLET | INH2O | -1.00 | -1.00 | -1.1 | -1.10 | | -0.90 |
| COOLER VENT STACK | | PLANT | DEGF | NA | NA | 697 | NA | 685 | NA |
| | | AVG | DEGF | 450 | 497 | | 650 | | 691 |
| | | | LBS/MIN | 10,874 | 10,600 | 11,963 | 8,865 | 11,818 | 9,437 |
| | | OUTLET | INH2O | -0.88 | -0.88 | NA | -0.88 | NA | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | | DEGF | | 262.4 | | 406.4 | | 413.6 |
| WINDBOX LEAKAGE | | | LBS/MIN | 149 | 153 | NA | 157 | NA | 166 |
| GAP HEIGHT | | | INCHES | 0.5 | 0.5 | NA | 0.5 | NA | 0.5 |
| O'BED LEAKAGE | | | LBS/MIN | (99) | (96) | NA | (125) | NA | (97) |
| GAP HEIGHT | | | INCHES | 1 | 1 | NA | 1 | NA | 1 |
| | | TOTAL AIR IN | LBS/MIN | 28,628 | 28,625 | | 26,052 | | 25,052 |
| | | TOTAL AIR OUT | LBS/MIN | 28,628 | 28,626 | | 26,054 | | 25,053 |

NOTES:

1. RECOUP B SIDE TC LOCATION IN CFD IS 20-70 F COLDER THAN AVE. OUT
2. RECOUP A SIDE TC LOCATION IN CFD IS 20-120 F HOTTER THAN AVE. OUT
3. GAP ON VENT STACK SEPARATION WALL IS 8"
4. CFD PRESSURES CORRESPOND TO APPROX PLANT SENSOR LOCATIONS

TABLE 2:
MINNTAC PLANT VALIDATION TESTS

APRIL 19 1999

| | | | | USX | CFD | USX | CFD | USX | CFD |
|-----------------------------------------|---------------|---------|---------|---------|-----------|---------|-----------|---------|-----------|
| | | | | RUN 3 | RUN 21 | RUN 4 | RUN 22 | RUN 5 | RUN 23 |
| | | | | 4/19/99 | 4_26_0720 | 4/19/99 | 4_27_0745 | 4/19/99 | 4_28_0710 |
| GREENBALL FEED RATE | | LTPH | | 548.77 | NA | 546.56 | NA | 546.71 | NA |
| PRODUCTION FACTOR METHOD 1 | | | | 0.77 | NA | 0.77 | NA | 0.77 | NA |
| RECYCLE PRORATED PROD FACT. METHOD 2 | | | | 0.73 | | 0.73 | | 0.72 | |
| PELLET FEED TO COOLER METH. 1 | | LTPH | | 422.55 | 422.48 | 420.85 | 420.87 | 420.97 | 420.87 |
| PRORATED FEED TO COOLER METH. 2 | | | | 401.27 | | 397.38 | | 391.76 | |
| GREENBALL MAGNETITE %WT | | | | NA | 87.00 | NA | 87.00 | NA | 87.00 |
| FE++ IN COOLER FEED | | | | NA | 5.31 | NA | 5.31 | NA | 5.31 |
| FE3O4 IN COOLER FEED (FE3O4=FE++/.2412) | | %WT | | NA | 22 | NA | 22 | NA | 22 |
| PELL. TEMP 15' FROM KILN DISCHG | | DEGF | | 2256 | NA | 2252 | NA | 2266 | NA |
| AVG PELLET TEMP ENTERING COOLER | | DEGF | | NA | 2,250 | NA | 2,250 | NA | 2,250 |
| COOLER SPEED | | IN/MIN | | 116 | 93 | 113.4 | 93 | 111.98 | 92 |
| COOLER BED DEPTH | | IN | | 28 | | 28 | | 28 | |
| PRI. COOLING ZONE | 3A FAN | FLOW | LBS/MIN | 10,329 | 10,331 | 11,731 | 11,731 | 11,493 | 11,498 |
| | | G/S | | 0.6895 | | 0.7907 | | 0.7858 | |
| | | POWER | AMPS | 101.6 | NA | 106.3 | NA | 105.13 | NA |
| | | INLET | DEGF | 40 | 40.46 | 35.7 | 35.6 | 37 | 37.4 |
| | | O'BED | IN.H2O | -0.048 | -0.152 | -0.025 | -0.124 | -0.055 | -0.141 |
| | | U'BED | IN.H2O | 12.11 | 14.05 | 13.15 | 15.06 | 12.47 | 14.81 |
| | | KFACT | | NA | 545 | NA | 545 | NA | 545 |
| KILN SECONDARY AIR | PLANT | DEGF | | 2,017 | | 2,037 | | 2,003 | |
| | AVG | DEGF | | NA | 2,347 | NA | 2,311 | NA | 2,323 |
| | | LBS/MIN | | NA | 4,232 | NA | 4,449 | NA | 4,293 |
| | OUTLET | INH2O | | NA | -0.40 | NA | -0.40 | NA | -0.40 |
| FURNACE PHEAT O'BED | | INH2O | | -0.494 | NA | -0.439 | NA | -0.457 | NA |
| | | LBS/MIN | | 21,876 | NA | 21,853 | NA | 21,779 | NA |
| | | G/S | | 1.4603 | | 1.4595 | | 1.4891 | |
| FIRING HOOD AIR | | DEGF | | NA | 2,308 | NA | 2,304 | NA | 2,305 |
| | | LBS/MIN | | NA | 2,569 | NA | 2,645 | NA | 2,606 |
| | OUTLET | INH2O | | NA | -0.73 | NA | -0.73 | NA | -0.73 |
| WINDBOX LEAKAGE | | LBS/MIN | | NA | 2,971 | NA | 3,098 | NA | 3,071 |
| GAP HEIGHT | | INCHES | | NA | 3.62 | NA | 3.62 | NA | 3.62 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | INCHES | | | 1.67 | | 1.67 | | 1.67 |
| SEC. COOLING ZONE | 3B FAN | FLOW | LBS/MIN | 15,355 | 15,353 | 13,854 | 13,854 | 13,406 | 13,405 |
| | | G/S | | 1.0250 | | 0.9338 | | 0.9166 | |
| | | POWER | AMPS | 137 | NA | 127.09 | NA | 124.6 | NA |
| | | INLET | DEGF | 40 | 40.46 | 35.7 | 35.6 | 37 | 37.4 |
| | | O'BED | IN.H2O | -0.279 | -0.166 | -0.297 | -0.218 | -0.348 | -0.239 |
| | | U'BED | IN.H2O | 13.73 | 13.79 | 11.77 | 12.42 | 11.547 | 12.3 |
| RECOUP B SIDE (WB 9) | PLANT | DEGF | | 1,664 | | 1,651 | | 1,641 | |
| | AVG | DEGF | | NA | 1,906 | NA | 1,799 | NA | 1,859 |
| | | LBS/MIN | | 2517 | 2,870 | 2525 | 2,881 | 2573 | 2,822 |
| | OUTLET | INH2O | | | -1.21 | | -1.21 | | -1.21 |
| FURNACE DD2 O'BED | | INH2O | | -1.19 | NA | -1.205 | NA | -1.268 | NA |
| | | DEGF | | 1,223 | NA | 1,231 | NA | 1,186 | NA |
| RECOUP A SIDE (WB10) | PLANT | DEGF | | 1,344 | | 1,356 | | 1,359 | |
| | AVG | DEGF | | NA | 1,509 | NA | 1,484 | NA | 1,514 |
| | | LBS/MIN | | 2,286 | 2,950 | 2,255 | 2,913 | 2,256 | 2,834 |
| | OUTLET | INH2O | | | -1.01 | | -1.01 | | -1.01 |
| COOLER VENT STACK | PLANT | DEGF | | 717 | NA | 692 | NA | 727 | NA |
| | AVG | DEGF | | | 671 | | 667 | | 710 |
| | | LBS/MIN | | 11,887 | 10,001 | 11,515 | 9,530 | 11,784 | 9,211 |
| | OUTLET | INH2O | | NA | -0.88 | NA | -0.88 | NA | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | | 401 | | 399.2 | | 435.2 | |
| WINDBOX LEAKAGE | | LBS/MIN | | NA | 170 | NA | 165 | NA | 166 |
| GAP HEIGHT | | INCHES | | NA | 0.5 | NA | 0.5 | NA | 0.5 |
| O'BED LEAKAGE | | LBS/MIN | | NA | (79) | NA | (96) | NA | (97) |
| GAP HEIGHT | | INCHES | | NA | 1 | NA | 1 | NA | 1 |
| | TOTAL AIR IN | LBS/MIN | | | 25,763 | | 25,681 | | 24,999 |
| | TOTAL AIR OUT | LBS/MIN | | | 25,764 | | 25,682 | | 25,003 |

NOTES:

1. RECOUP B SIDE TC LOCATION IN CFD IS 20-70 F COLDER THAN AVE. OUT
2. RECOUP A SIDE TC LOCATION IN CFD IS 20-120 F HOTTER THAN AVE. OUT
3. GAP ON VENT STACK SEPARATION WALL IS 8"
4. CFD PRESSURES CORRESPOND TO APPROX PLANT SENSOR LOCATIONS







TABLE 2:
MINNTAC PLANT VALIDATION TESTS

| | | | | ADJUSTED TONNAGE RUNS | | | | | |
|-----------------------------------------|---------------|----------|---------|-----------------------|----------|----------|----------|----------|----------|
| | | | | 4/19-R5 | 2/17-R4 | 2/11-R1 | 4/19-R2 | 2/17-R3 | 4/19-R3 |
| | | | | RUN 24 | RUN 25 | RUN 26 | RUN 27 | RUN 28 | RUN 29 |
| | | | | 4_30_0710 | 5_3_0805 | 5_4_0930 | 5_5_0755 | 5_6_0800 | 5_7_1410 |
| GREENBALL FEED RATE | | LTPH | | NA | NA | NA | NA | NA | NA |
| PRODUCTION FACTOR METHOD 1 | | | | NA | NA | NA | NA | NA | NA |
| RECYCLE PRORATED PROD FACT. METHOD 2 | | | | NA | NA | NA | NA | NA | NA |
| PELLET FEED TO COOLER METH. 1 | | LTPH | | | | | | | |
| PRORATED FEED TO COOLER METH. 2 | | | | 391.34 | 407.53 | 432.88 | 383.27 | 408.66 | 401.18 |
| GREENBALL MAGNETITE %WT | | | | 87.00 | 87.00 | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | 5.31 | 5.31 | 5.31 | 5.31 | 5.31 | 5.31 |
| FE3O4 IN COOLER FEED (FE3O4=FE++/.2412) | | %WT | | 22 | 22 | 22 | 22 | 22 | 22 |
| PELL. TEMP 15' FROM KILN DISCHG | | DEGF | | NA | NA | NA | NA | NA | NA |
| AVG PELLET TEMP ENTERING COOLER | | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 | 2,250 | 2,250 |
| COOLER SPEED | | IN/MIN | | 86 | 90 | 95 | 84 | 90 | 88 |
| COOLER BED DEPTH | | IN | | | | | | | |
| PRI. COOLING ZONE | 3A FAN | FLOW G/S | LBS/MIN | 11,498 | 14,091 | 12,985 | 11,333 | 15,412 | 10,331 |
| | | POWER | AMPS | NA | NA | NA | NA | NA | NA |
| | | INLET | DEGF | 37.4 | 1.4 | 12.2 | 47.66 | 5 | 40.46 |
| | | O'BED | IN.H2O | -0.154 | 0.0047 | -0.0253 | -0.1509 | -0.0017 | -0.1587 |
| | | U'BED | IN.H2O | 14.45 | 16.84 | 16.36 | 14.26 | 17.69 | 13.76 |
| | | KFACT | | 545 | 545 | 545 | 545 | 545 | 545 |
| KILN SECONDARY AIR | PLANT | DEGF | | | | | | | |
| | AVG | DEGF | | 2,300 | 2,182 | 2,256 | 2,289 | 2,169 | 2,336 |
| | | LBS/MIN | | 4,195 | 5,494 | 5,243 | 4,243 | 5,403 | 4,177 |
| | OUTLET | INH2O | | -0.40 | -0.40 | -0.40 | -0.40 | -0.40 | -0.40 |
| FURNACE PHEAT O'BED | | INH2O | | NA | NA | NA | NA | NA | NA |
| | | LBS/MIN | | NA | NA | NA | NA | NA | NA |
| | | G/S | | | | | | | |
| FIRING HOOD AIR | | DEGF | | 2,310 | 2,296 | 2,296 | 2,311 | 2,293 | 2,310 |
| | | LBS/MIN | | 2,572 | 2,919 | 2,854 | 2,573 | 2,946 | 2,499 |
| | OUTLET | INH2O | | -0.73 | -0.73 | -0.73 | -0.73 | -0.73 | -0.73 |
| WINDBOX LEAKAGE | | LBS/MIN | | 3,035 | 3,292 | 3,232 | 3,019 | 3,400 | 2,944 |
| GAP HEIGHT | | INCHES | | 3.62 | 3.62 | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | INCHES | | 1.67 | 1.67 | 1.67 | 1.67 | 1.67 | 1.67 |
| SEC. COOLING ZONE | 3B FAN | FLOW G/S | LBS/MIN | 13,405 | 14,438 | 14,818 | 13,622 | 11,321 | 15,353 |
| | | POWER | AMPS | NA | NA | NA | NA | NA | NA |
| | | INLET | DEGF | 37.4 | 1.4 | 12.2 | 47.66 | 5 | 40.46 |
| | | O'BED | IN.H2O | -0.273 | -0.1472 | -0.0999 | -0.2486 | -0.2992 | -0.1887 |
| | | U'BED | IN.H2O | 11.57 | 11.25 | 12.55 | 11.66 | 9.19 | 13.27 |
| RECOUP B SIDE (WB 9) | PLANT | DEGF | | | | | | | |
| | AVG | DEGF | | 1,730 | 1,430 | 1,654 | 1,705 | 1,411 | 1,842 |
| | | LBS/MIN | | 2,847 | 3,011 | 2,893 | 2,758 | 2,961 | 2,883 |
| | OUTLET | INH2O | | -1.21 | -1.00 | -1.00 | -1.10 | -1.10 | -1.21 |
| FURNACE DD2 O'BED | | INH2O | | NA | NA | NA | NA | NA | NA |
| | | DEGF | | NA | NA | NA | NA | NA | NA |
| RECOUP A SIDE (WB10) | PLANT | DEGF | | | | | | | |
| | AVG | DEGF | | 1,392 | 1,138 | 1,340 | 1,366 | 1,156 | 1,432 |
| | | LBS/MIN | | 2,866 | 2,975 | 2,880 | 2,737 | 2,846 | 2,974 |
| | OUTLET | INH2O | | -1.01 | -0.80 | -0.80 | -0.90 | -0.90 | -1.01 |
| COOLER VENT STACK | PLANT | DEGF | | NA | NA | NA | NA | NA | NA |
| | AVG | DEGF | | 608 | 472 | 586 | 590 | 553 | 599 |
| | | LBS/MIN | | 9,334 | 10,785 | 10,624 | 9,569 | 9,176 | 10,125 |
| | OUTLET | INH2O | | -0.88 | -0.88 | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | | 348.8 | 240.8 | 321.8 | 332.6 | 314.6 | 338 |
| WINDBOX LEAKAGE | | LBS/MIN | | 159 | 151 | 161 | 159 | 144 | 166 |
| GAP HEIGHT | | INCHES | | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| O'BED LEAKAGE | | LBS/MIN | | (107) | (97) | (84) | (104) | (145) | (83) |
| GAP HEIGHT | | INCHES | | 1 | 1 | 1 | 1 | 1 | 1 |
| | TOTAL AIR IN | LBS/MIN | | 25,010 | 28,626 | 27,887 | 25,059 | 26,877 | 25,767 |
| | TOTAL AIR OUT | LBS/MIN | | 25,008 | 28,627 | 27,887 | 25,059 | 26,877 | 25,767 |

NOTES:

1. RECOUP B SIDE TC LOCATION IN CFD IS 20-70 F COLDER THAN AVE. OUT
2. RECOUP A SIDE TC LOCATION IN CFD IS 20-120 F HOTTER THAN AVE. OUT
3. GAP ON VENT STACK SEPARATION WALL IS 8"
4. CFD PRESSURES CORRESPOND TO APPROX PLANT SENSOR LOCATIONS

TABLE 3
INITIAL VALIDATION TESTS - PLOTTING SYMBOL INDEX

| Legend Label | BC-1 | BC-2 | BC-3 | BC-4 | BC-5 | BC-6 |
|------------------------------|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|
| Simulations |  |  |  |  |  |  |
| 11/19_R1 | X | X | — | — | — | — |
| 11/19_R3 | — | — | X | — | X | — |
| 2/11_R1 | — | — | — | X | X | X |
| 2/11_R2 | — | — | — | X | X | — |
| 2/17_R1 | — | — | — | X | X | — |
| 2/17_R2 | — | — | — | X | X | — |
| 2/17_R3 | — | — | — | X | X | X |
| 2/17_R4 | — | — | — | X | X | X |
| 4/19_R1 | — | — | — | — | X | — |
| 4/19_R2 | — | — | — | — | X | X |
| 4/19_R3 | — | — | — | — | X | X |
| 4/19_R4 | — | — | — | — | X | — |
| 4/19_R5 | — | — | — | — | X | X |
| Variable Parameters | | | | | | |
| % Magnetite | 16 | 28 | 28 | 22 | 22 | 22 |
| Pellet Feed to Cooler | Method 1 | Method 1 | Method 1 | Method 1 | Method 1 | Method 2 |
| Pellet Discharge Temp Deg | 2200 | 2200 | 2200 | 2200 | 2250 | 2250 |
| Primary Cooling Zone Leakage | LOW LEAKAGE RATE | | | | HIGH LEAKAGE RATE | |
| Under Bed Gap | 1 | 1 | 1 | 1 | 3.6 | 3.6 |
| Damper Gap | Open | Open | Closed - 4.7" | Closed - 4.7" | Closed - 1.7" | Closed - 1.7" |
| 3A Fan Flow | Plant | Plant+5% | Plant | Plant | Plant | Plant |
| 3B Fan Flow | Plant | Plant+5% | Plant | Plant | Plant | Plant |
| Recoup Outlet Pressures | A = B | A = B | A = B | A = B | A = B for Nov & Feb A is 0.2 > B for Apr | A is 0.2 > B |

MINNTAC MEDUSA VALIDATION SUMMARY:
FEED RATES CALC. FROM PLANT DATA

| Test | Nov19 | Nov19 | Nov19 | Nov19 | Nov19 | |
|--------------------------|----------------------------------------|-----------|----------------|-----------------|----------------|-----------------|
| | Run 1 | Run 3 | Run 3 | Run 1 | Run 1 | |
| | 1_20_0800 | 1_22_0735 | 3_16_0830 | 2_17_0800 | 3_15_0800 | |
| CFD DATA FILE: | | | | | | |
| Medusa Data Format | EQUAL OUTLET PRESSURES ON RECOUP DUCTS | | | | | |
| 3A/3B DAMPER POSITION | open | closed | closed | closed | closed | |
| GREEN BALLS | kg/s | 2 140.84 | 137.94 | 143.73 | 143.73 | |
| HEARTH LAYER | kg/s | 1 135.77 | 135.77 | 137.92 | 137.92 | |
| HEARTH LAYER | kg/s | 0 | 0 | 0 | 0 | |
| PELLET DIAMETER | M | 0.0111 | 0.0111 | 0.0111 | 0.0111 | |
| GREEN BALLS TEMPERATURE | K | 290 | 290 | 290 | 290 | |
| HEARTH LAYER TEMPERATURE | K | 290 | 290 | 290 | 290 | |
| MAGNETITE FRACTION | Xm | 0.7582 | 0.7582 | 0.7582 | 0.7582 | |
| HEARTH LAYER FRACTION | Xh | 0 | 0 | 0 | 0 | |
| INERT FRACTION | | 0.04380 | 0.04380 | 0.04380 | 0.04380 | |
| FLUX FRACTION | | 0.06934 | 0.06934 | 0.06934 | 0.06934 | |
| MOISTURE FRACTION | | 0.08759 | 0.08759 | 0.08759 | 0.08759 | |
| PELLET POROSITY | | 0.25 | 0.25 | 0.25 | 0.25 | |
| SOLIDS EMISSIVITY | | 0.60 | 0.60 | 0.60 | 0.60 | |
| OUTSIDE AIR TEMPERATURE | K | 266 | 264 | 262 | 262 | |
| LEAKAGE AIR TEMPERATURE | K | 290 | 290 | 290 | 290 | |
| NUMBER OF ZONES | | 7 | 7 | 7 | 7 | |
| MACHINE TYPE | | 1 | 1 | 1 | 1 | |
| KILN ZONE # | | 4 | 4 | 4 | 4 | |
| FIRING ZONE | | 4 | 4 | 4 | 4 | |
| AIR IN, KMOLS/S | | | Low Outleak | High Outleak | Low Outleak | High Outleak |
| 1 DD1 | | 0 | 0 | 0 | 0 | 0 |
| 2 DD2 | | 0 | 0 | 0 | 0 | 0 |
| 3 PH | | 0 | 0 | 0 | 0 | 0 |
| 4 KILN | | 0 | 0 | 0 | 0 | 0 |
| 5 C1 | | 1.9536 | 2.2537 | 2.0849 | 2.2629 | 2.0703 |
| 6 C2 | | 1.6116 | 1.6288 | 1.5100 | 1.6995 | 1.5768 |
| 7 C3 | | 2.9476 | 2.6978 | 2.4818 | 2.9217 | 2.7511 |
| TEMPS K | | | | | | |
| C1 | | 1479 | 1472 | 1503 | 1462 | 1514 |
| C2 | | 1061 | 957 | 1032 | 950 | 1058 |
| TARGET VARIABLES | | | | | | |
| DD1 OBED | K | 621 | 625 | 625 | 632 | 632 |
| PH FAN -1A | K | 616 | 624 | 624 | 622 | 622 |
| PH FAN -1B | K | 633 | 635 | 635 | 654 | 654 |
| KILN SEC AIR | K | 1392 | 1395 | 1395 | 1397 | 1397 |
| BURN ZONE (REFRAC) | K | 1629 | 1626 | 1626 | 1622 | 1622 |
| KILN SOLIDS EXIT | K | 1512 | 1524 | 1524 | 1517 | 1517 |
| PLANT OVER BED PRESSURES | | | | | | |
| DD1 | | -0.49 | -0.48 | -0.48 | -0.67 | -0.67 |
| DD2 | | -1.01 | -0.98 | -0.98 | -1.04 | -1.04 |
| PH | | -0.58 | -0.51 | -0.51 | -0.55 | -0.55 |
| PH | | -9.63 | -9.85 | -9.85 | -4.89 | -4.89 |
| UNDER BED PRESSURE | | | | | | |
| ESTIMATED LEAK KMOLS/S | | | | | | |
| DD1 OBED | | 0.53 | 0.52 | 0.52 | 0.61 | 0.61 |
| DD2 OBED | | 0.35 | 0.38 | 0.38 | 0.39 | 0.39 |
| PH OBED | | 0.81 | 0.75 | 0.75 | 0.79 | 0.79 |
| PH UBED | | 1.19 | 1.20 | 1.20 | 0.85 | 0.85 |
| FUEL, KMOLS/S | | | | | | |
| DD2 | | 0 | 0 | 0 | 0 | 0 |
| 3 PH | | 0.0288 | 0.0288 | 0.0288 | 0.0288 | 0.0288 |
| 4 KILN | | 0.0643 | 0.0533 | 0.0533 | 0.0588 | 0.0588 |

MINNTAC MEDUSA VALIDATION SUMMARY:
FEED RATES CALC. FROM PLANT DATA

| Test | Feb 11 | | Feb 17 | | Feb 17 | |
|--------------------------|----------------------------------------|-----------|-----------|-----------|-----------|-----------|
| | Run 2 | | Run 1 | | Run 2 | |
| | 2_18_2202 | 3_12_0855 | 2_24_0740 | 3_11_0735 | 2_25_0720 | 3_10_0930 |
| CFD DATA FILE: | | | | | | |
| Medusa Data Format | EQUAL OUTLET PRESSURES ON RECOUP DUCTS | | | | | |
| 3A/3B DAMPER POSITION | closed | | closed | | closed | |
| GREEN BALLS | kg/s | 2 | 142.89 | 135.02 | 136.56 | |
| | | 1 | 137.92 | 136.45 | 137.34 | |
| HEARTH LAYER | kg/s | | 0 | 0 | 0 | |
| PELLET DIAMETER | M | | 0.0111 | 0.0111 | 0.0111 | |
| GREEN BALLS TEMPERATURE | K | | 290 | 290 | 290 | |
| HEARTH LAYER TEMPERATURE | K | | 290 | 290 | 290 | |
| MAGNETITE FRACTION | Xm | | 0.7582 | 0.7582 | 0.7582 | |
| HEARTH LAYER FRACTION | Xh | | 0 | 0 | 0 | |
| INERT FRACTION | | | 0.04380 | 0.04380 | 0.04380 | |
| FLUX FRACTION | | | 0.06934 | 0.06934 | 0.06934 | |
| MOISTURE FRACTION | | | 0.08759 | 0.08759 | 0.08759 | |
| PELLET POROSITY | | | 0.25 | 0.25 | 0.25 | |
| SOLIDS EMISSITIVITY | | | 0.60 | 0.60 | 0.60 | |
| OUTSIDE AIR TEMPERATURE | K | | 262 | 257 | 262 | |
| LEAKAGE AIR TEMPERATURE | K | | 290 | 290 | 290 | |
| NUMBER OF ZONES | | | 7 | 7 | 7 | |
| MACHINE TYPE | | | 1 | 1 | 1 | |
| KILN ZONE # | | | 4 | 4 | 4 | |
| FIRING ZONE | | | 4 | 4 | 4 | |
| AIR IN, KMOLS/S | | | Low | High | Low | High |
| | | | Outleak | Outleak | Outleak | Outleak |
| 1 DD1 | | | 0 | 0 | 0 | 0 |
| 2 DD2 | | | 0 | 0 | 0 | 0 |
| 3 PH | | | 0 | 0 | 0 | 0 |
| 4 KILN | | | 0 | 0 | 0 | 0 |
| 5 C1 | | | 2.2558 | 2.0669 | 2.2743 | 2.0872 |
| 6 C2 | | | 1.6603 | 1.5369 | 1.6977 | 1.5716 |
| 7 C3 | | | 2.7931 | 2.7511 | 2.8787 | 2.7007 |
| TEMPS K | | | C1 | C2 | C1 | C2 |
| | | | 1461 | 1512 | 1456 | 1508 |
| | | | 952 | 1059 | 928 | 1034 |
| TARGET VARIALBLES | | | K | K | K | K |
| DD1 OBED | | | 631 | 627 | 631 | 626 |
| PH FAN -1A | | | 624 | 624 | 624 | 626 |
| PH FAN -1B | | | 652 | 645 | 645 | 647 |
| KILN SEC AIR | | | 1397 | 1386 | 1386 | 1386 |
| BURN ZONE (REFRAC) | | | 1620 | 1619 | 1619 | 1623 |
| KILN SOLIDS EXIT | | | 1516 | 1510 | 1510 | 1516 |
| PLANT OVER BED PRESSURES | | | DD1 | DD2 | PH | PH |
| | | | -0.64 | -0.58 | -0.50 | -0.54 |
| | | | -1.06 | -1.00 | -5.90 | -6.21 |
| UNDER BED PRESSURE | | | PH | PH | PH | PH |
| | | | -0.56 | -5.90 | 0.93 | 0.95 |
| ESTIMATED LEAK KMOLS/S | | | DD1 OBED | DD2 OBED | PH OBED | PH UBED |
| | | | 0.60 | 0.39 | 0.74 | 0.95 |
| | | | 0.79 | 0.38 | 0.57 | 0.41 |
| | | | 0.86 | 0.74 | 0.38 | 0.38 |
| FUEL, KMOLS/S | | | DD2 | 3 PH | 4 KILN | |
| | | | 0 | 0.0288 | 0.0576 | |
| | | | 0 | 0.0284 | 0.0584 | |
| | | | 0 | 0.0288 | 0.0596 | |

MINNTAC MEDUSA VALIDATION SUMMARY
FEED RATES CALC. FROM PLANT DATA

| CFD DATA FILE: | Test | Feb 17 | | Feb 17 | |
|--------------------------|------|-----------|-----------------|-----------------|-----------------|
| | | Run 3 | Run 4 | Run 3 | Run 4 |
| Medusa Data Format | | 2_26_0725 | 3_09_ | 3_1_0725 | 3_8_1240 |
| 3A/3B DAMPER POSITION | | closed | | closed | |
| GREEN BALLS | kg/s | 2 | 136.86 | 136.45 | |
| | | 1 | 137.34 | 137.34 | |
| HEARTH LAYER | kg/s | | 0 | 0 | |
| PELLET DIAMETER | M | | 0.0111 | 0.0111 | |
| GREEN BALLS TEMPERATURE | K | | 290 | 290 | |
| HEARTH LAYER TEMPERATURE | K | | 290 | 290 | |
| MAGNETITE FRACTION | Xm | | 0.7582 | 0.7582 | |
| HEARTH LAYER FRACTION | Xh | | 0 | 0 | |
| INERT FRACTION | | | 0.04380 | 0.04380 | |
| FLUX FRACTION | | | 0.06934 | 0.06934 | |
| MOISTURE FRACTION | | | 0.08759 | 0.08759 | |
| PELLET POROSITY | | | 0.25 | 0.25 | |
| SOLIDS EMISSIVITY | | | 0.60 | 0.60 | |
| OUTSIDE AIR TEMPERATURE | K | | 258 | 256 | |
| LEAKAGE AIR TEMPERATURE | K | | 290 | 290 | |
| NUMBER OF ZONES | | | 7 | 7 | |
| MACHINE TYPE | | | 1 | 1 | |
| KILN ZONE # | | | 4 | 4 | |
| FIRING ZONE | | | 4 | 4 | |
| AIR IN, KMOLS/S | | | Low Outleak | High Outleak | Low Outleak |
| | | | High Outleak | | High Outleak |
| 1 DD1 | | | 0 | 0 | 0 |
| 2 DD2 | | | 0 | 0 | 0 |
| 3 PH | | | 0 | 0 | 0 |
| 4 KILN | | | 0 | 0 | 0 |
| 5 C1 | | | 2.3677 | 2.1898 | 2.3675 |
| 6 C2 | | | 1.6436 | 1.5100 | 1.7514 |
| 7 C3 | | | 2.6023 | 2.3842 | 2.9522 |
| | | | 2.6023 | 2.3842 | 2.9522 |
| TEMPS K | | | C1 | 1439 | 1489 |
| | | | C2 | 893 | 992 |
| | | | C1 | 1445 | 1497 |
| | | | C2 | 894 | 995 |
| TARGET VARIABLLES | | | | | |
| DD1 OBED | K | | 632 | 629 | 629 |
| PH FAN -1A | K | | 626 | 622 | 622 |
| PH FAN -1B | K | | 646 | 644 | 644 |
| KILN SEC AIR | K | | 1381 | 1382 | 1382 |
| BURN ZONE (REFRAC) | K | | 1624 | 1620 | 1620 |
| KILN SOLIDS EXIT | K | | 1515 | 1515 | 1515 |
| PLANT OVER BED PRESSURES | | | DD1 | -0.33 | -0.25 |
| | | | DD2 | -1.08 | -0.95 |
| | | | PH | -0.63 | -0.52 |
| | | | PH | -6.24 | -6.22 |
| UNDER BED PRESSURE | | | | | |
| ESTIMATED LEAK KMOLS/S | | | DD1 OBED | 0.43 | 0.37 |
| | | | DD2 OBED | 0.40 | 0.37 |
| | | | PH OBED | 0.83 | 0.76 |
| | | | PH UBED | 0.96 | 0.95 |
| FUEL, KMOLS/S | | | DD2 | 0 | 0 |
| | | | 3 PH | 0.0288 | 0.0288 |
| | | | 4 KILN | 0.0614 | 0.0585 |

MINNTAC MEDUSA VALIDATION SUMMARY
FEED RATES CALC. FROM PLANT DATA

| | | Test | APR 19 RUN 1 4_22_0715 | APR 19 RUN 2 4_23_0725 | APR 19 RUN 3 4_26_0720 | APR 19 RUN 4 4_27_0745 | APR 19 RUN 5 4_28_0710 |
|--------------------------|--|------|------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
| CFD DATA FILE: | | | | | | | |
| Medusa Data Format | | | | | | | |
| 3A/3B DAMPER POSITION | | | | | | | |
| GREEN BALLS | | kg/s | 2 135.81 | 129.28 | 134.91 | 133.73 | 132.13 |
| HEARTH LAYER | | kg/s | 1 138.72 | 135.17 | 138.63 | 138.10 | 138.10 |
| PELLET DIAMETER | | M | 0.0111 | 0.0111 | 0.0111 | 0.0111 | 0.0111 |
| GREEN BALLS TEMPERATURE | | K | 290 | 290 | 290 | 290 | 290 |
| HEARTH LAYER TEMPERATURE | | K | 290 | 290 | 290 | 290 | 290 |
| MAGNETITE FRACTION | | Xm | 0.7582 | 0.7582 | 0.7582 | 0.7582 | 0.7582 |
| HEARTH LAYER FRACTION | | Xh | 0 | 0 | 0 | 0 | 0 |
| INERT FRACTION | | | 0.04380 | 0.04380 | 0.04380 | 0.04380 | 0.04380 |
| FLUX FRACTION | | | 0.06934 | 0.06934 | 0.06934 | 0.06934 | 0.06934 |
| MOISTURE FRACTION | | | 0.08759 | 0.08759 | 0.08759 | 0.08759 | 0.08759 |
| PELLET POROSITY | | | 0.25 | 0.25 | 0.25 | 0.25 | 0.25 |
| SOLIDS EMISSITIVITY | | | 0.60 | 0.60 | 0.60 | 0.60 | 0.60 |
| OUTSIDE AIR TEMPERATURE | | K | 279 | 281 | 277 | 275 | 276 |
| LEAKAGE AIR TEMPERATURE | | K | 290 | 290 | 290 | 290 | 290 |
| NUMBER OF ZONES | | | 7 | 7 | 7 | 7 | 7 |
| MACHINE TYPE | | | 1 | 1 | 1 | 1 | 1 |
| KILN ZONE # | | | 4 | 4 | 4 | 4 | 4 |
| FIRING ZONE | | | 4 | 4 | 4 | 4 | 4 |
| AIR IN, KMOLS/S | | | High Outleak | High Outleak | High Outleak | High Outleak | High Outleak |
| 1 DD1 | | | 0 | 0 | 0 | 0 | 0 |
| 2 DD2 | | | 0 | 0 | 0 | 0 | 0 |
| 3 PH | | | 0 | 0 | 0 | 0 | 0 |
| 4 KILN | | | 0 | 0 | 0 | 0 | 0 |
| 5 C1 | | | 1.9972 | 1.8122 | 1.7746 | 1.8511 | 1.8002 |
| 6 C2 | | | 1.5826 | 1.4218 | 1.5187 | 1.5119 | 1.4759 |
| 7 C3 | | | 2.3132 | 2.4625 | 2.6096 | 2.4867 | 2.4035 |
| TEMPS K | | | | | | | |
| C1 | | | 1515 | 1540 | 1551 | 1538 | 1542 |
| C2 | | | 1080 | 1173 | 1202 | 1161 | 1192 |
| TARGET VARIABLBS | | | | | | | |
| DD1 OBED | | K | 616 | 612 | 614 | 614 | 611 |
| PH FAN -1A | | K | 620 | 618 | 617 | 617 | 614 |
| PH FAN -1B | | K | 627 | 627 | 627 | 628 | 625 |
| KILN SEC AIR | | K | 1381 | 1383 | 1375 | 1387 | 1368 |
| BURN ZONE (REFRAC) | | K | 1622 | 1607 | 1617 | 1607 | 1617 |
| KILN SOLIDS EXIT | | K | 1518 | 1508 | 1509 | 1506 | 1514 |
| PLANT OVER BED PRESSURES | | | | | | | |
| DD1 | | | -0.67 | -0.69 | -0.69 | -0.71 | -0.72 |
| DD2 | | | -1.23 | -1.07 | -1.19 | -1.21 | -1.27 |
| PH | | | -0.48 | -0.36 | -0.49 | -0.44 | -0.46 |
| UNDER BED PRESSURE | | | | | | | |
| PH | | | -5.61 | -4.50 | -5.23 | -5.18 | -5.74 |
| ESTIMATED LEAK KMOLS/S | | | | | | | |
| DD1 OBED | | | 0.61 | 0.62 | 0.62 | 0.63 | 0.63 |
| DD2 OBED | | | 0.42 | 0.39 | 0.42 | 0.42 | 0.43 |
| PH OBED | | | 0.73 | 0.63 | 0.74 | 0.70 | 0.71 |
| PH UBED | | | 0.91 | 0.81 | 0.87 | 0.87 | 0.92 |
| FUEL, KMOLS/S | | | | | | | |
| DD2 | | | 0 | 0 | 0 | 0 | 0 |
| 3 PH | | | 0.0288 | 0.0285 | 0.0288 | 0.0287 | 0.0228 |
| 4 KILN | | | 0.0542 | 0.0509 | 0.0582 | 0.0536 | 0.0600 |

MINNTAC MEDUSA VALIDATION SUMMARY:
FEED RATES CALC. FROM PLANT DATA

TABLE 4 NOTES

Green ball rate method: 1. CFD Cooler value/0.86
2. Actual Feed to grate, adjusted for roll feeder return

| Basis for Composition Calculation | | | |
|-----------------------------------|-----------|-----------|------------|
| composition | dry basis | wet basis | %wet basis |
| magnetite | 83.1 | 83.1 | 0.758212 |
| hematite | 4.5 | 4.5 | 0.041058 |
| silica | 4.8 | 4.8 | 0.043796 |
| flux stone | 7.6 | 7.6 | 0.069343 |
| water | | 9.6 | 0.087591 |
| | 100 | 109.6 | 1 |

Actual moisture and flux vary , we assume constant values

Outside Air Temp is temperature used for air entering CFD cooler zones

| Basis for Cooler Inlet Flows |
|----------------------------------------------------------|
| C1 = CFD Kiln Sec +Firing Hood outlet flow |
| C2 = CFD Total Recoup Outlet flow |
| C3 = Stack Outlet flow |
| CFD values are based on matching Plant 3A and 3B |
| Sensor flows |
| A Relatively large CFD outleakage is taken in 3A windbox |
| assumes not all plant indicated flow passes through |
| bed |

TABLE 5
MINNTAC MEDUSA VALIDATION SUMMARY
FEED RATES OPTIMIZED BY MEDUSA

| | 1 | | 2 | | 3 | | 4 | | 5 | | 6 | | 7 | | 8 | | 9 | | 10 | | 11 | | 12 | | |
|----------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|------|--------|------|--------|------|--|
| | Nov19 | | Feb 11 | | Feb 11 | | Feb 17 | | Feb 17 | | Feb 17 | | Feb 17 | | APR 19 | | APR 19 | | APR 19 | | APR 19 | | APR 19 | | |
| | Run 3 | | Run 1 | | Run 2 | | Run 1 | | Run 2 | | Run 3 | | Run 4 | | RUN 1 | | RUN 2 | | RUN 3 | | RUN 4 | | RUN 5 | | |
| TARGETS | | | | | | | | | | | | | | | | | | | | | | | | | |
| DD1-OBED DEGK | 625 | | 632 | | 631 | | 627 | | 631 | | 632 | | 629 | | 616 | | 612 | | 614 | | 614 | | 611 | | |
| AVG PH FAN DEG K | 629 | | 638 | | 638 | | 634 | | 636 | | 636 | | 633 | | 624 | | 622 | | 622 | | 623 | | 619 | | |
| DD2 OBED DEGK | 897 | | 895 | | 896 | | 872 | | 874 | | 865 | | 871 | | 869 | | 923 | | 935 | | 939 | | 914 | | |
| KILN SEC AIR DEG K | 1395 | | 1397 | | 1397 | | 1386 | | 1386 | | 1381 | | 1382 | | 1381 | | 1383 | | 1375 | | 1387 | | 1368 | | |
| KILN SOLIDS EXIT DEG K | 1524 | | 1517 | | 1516 | | 1510 | | 1516 | | 1515 | | 1515 | | 1518 | | 1508 | | 1509 | | 1506 | | 1514 | | |
| GRATE FEED RATE KG/S | 137.94 | | 143.73 | | 142.89 | | 135.02 | | 136.56 | | 136.86 | | 136.45 | | 135.81 | | 129.28 | | 134.91 | | 133.73 | | 132.13 | | |
| PLANT AVG % MOIST | 9.6 | | 9.6 | | 9.6 | | 9.6 | | 9.6 | | 9.6 | | 9.6 | | 9.6 | | 9.6 | | 9.6 | | 9.6 | | 9.6 | | |
| WIND BOX LEAK LEVEL | LOW | HIGH | LOW | HIGH | LOW | HIGH | LOW | HIGH | LOW | HIGH | LOW | HIGH | LOW | HIGH | HIGH | HIGH | HIGH | HIGH | HIGH | HIGH | HIGH | HIGH | HIGH | HIGH | |
| DATA FILE VAULES | | | | | | | | | | | | | | | | | | | | | | | | | |
| PROD RATE KG/S | 135.40 | 133.50 | 140.50 | 139.70 | 140.70 | 138.70 | 138.70 | 137.00 | 140.60 | 138.90 | 141.10 | 139.50 | 141.10 | 139.70 | 136.80 | 129.40 | 135.20 | 134.30 | 132.9 | | | | | | |
| DD1 OBED KMOL/S | 0.2518 | 0.2518 | 0.2960 | 0.2960 | 0.2900 | 0.2900 | 0.2754 | 0.2754 | 0.1988 | 0.1988 | 0.2079 | 0.2079 | 0.1806 | 0.1806 | 0.2954 | 0.3011 | 0.3000 | 0.3045 | 0.3062 | | | | | | |
| DD2 - OBED KMOL/S | 0.3775 | 0.3775 | 0.3898 | 0.3898 | 0.3930 | 0.3930 | 0.3823 | 0.3823 | 0.3792 | 0.3792 | 0.3970 | 0.3970 | 0.3709 | 0.3709 | 0.4231 | 0.3946 | 0.4169 | 0.4188 | 0.4293 | | | | | | |
| PHEAT OBED KMOL/S | 0.7510 | 0.7510 | 0.7851 | 0.7851 | 0.7879 | 0.7879 | 0.7428 | 0.7428 | 0.7786 | 0.7786 | 0.8346 | 0.8346 | 0.7583 | 0.7583 | 0.7276 | 0.6299 | 0.7420 | 0.6995 | 0.7137 | | | | | | |
| PHEAT UBED KMOL/S | 1.5999 | 1.5999 | 1.1269 | 1.1269 | 1.1445 | 1.1445 | 1.2383 | 1.2383 | 1.2704 | 1.2704 | 1.2737 | 1.2737 | 1.2711 | 1.2711 | 1.2076 | 1.0817 | 1.1656 | 1.1597 | 1.2212 | | | | | | |
| C1 KMOLS/S | 2.2537 | 2.0849 | 2.2629 | 2.0703 | 2.2558 | 2.0669 | 2.2743 | 2.0872 | 2.3456 | 2.1595 | 2.3677 | 2.1898 | 2.3675 | 2.1804 | 1.9972 | 1.8122 | 1.7746 | 1.8511 | 1.8002 | | | | | | |
| C1 DEG K | 1452 | 1503 | 1462 | 1514 | 1461 | 1512 | 1456 | 1508 | 1445 | 1497 | 1439 | 1489 | 1445 | 1497 | 1515 | 1540 | 1551 | 1538 | 1542 | | | | | | |
| C2 KMOL/S | 1.6288 | 1.5100 | 1.6995 | 1.5768 | 1.6803 | 1.5369 | 1.6977 | 1.5716 | 1.8872 | 1.5573 | 1.6436 | 1.5100 | 1.7514 | 1.6207 | 1.5826 | 1.4218 | 1.5187 | 1.5119 | 1.4759 | | | | | | |
| C2 DEG K | 937 | 1032 | 950 | 1058 | 952 | 1059 | 928 | 1034 | 906 | 1008 | 893 | 992 | 894 | 995 | 1080 | 1173 | 1202 | 1161 | 1192 | | | | | | |
| PH FUEL | 0.0288 | 0.0288 | 0.0288 | 0.0288 | 0.0288 | 0.0288 | 0.0284 | 0.0284 | 0.0288 | 0.0288 | 0.0288 | 0.0288 | 0.0288 | 0.0288 | 0.0288 | 0.0285 | 0.0288 | 0.0287 | 0.0228 | | | | | | |
| KILN FUEL | 0.0533 | 0.0533 | 0.0588 | 0.0588 | 0.0576 | 0.0576 | 0.0584 | 0.0584 | 0.0596 | 0.0596 | 0.0614 | 0.0614 | 0.0585 | 0.0585 | 0.0542 | 0.0509 | 0.0582 | 0.0536 | 0.0600 | | | | | | |
| SIMULATION RESULTS: | | | | | | | | | | | | | | | | | | | | | | | | | |
| DD1-OBED DEGK | 620 | 616 | 627 | 624 | 626 | 625 | 624 | 622 | 629 | 625 | 630 | 626 | 625 | 621 | 610 | 601 | 603 | 602 | 599 | | | | | | |
| PHEAT FAN INLET DEG K | 636 | 633 | 648 | 645 | 646 | 645 | 643 | 641 | 643 | 639 | 643 | 640 | 637 | 634 | 630 | 624 | 625 | 623 | 621 | | | | | | |
| DD2 - OBEDK | 855 | 928 | 866 | 950 | 865 | 948 | 849 | 932 | 831 | 911 | 814 | 890 | 825 | 905 | 959 | 1031 | 1058 | 1021 | 1038 | | | | | | |
| KILN SEC AIR DEG F | 1452 | 1503 | 1462 | 1514 | 1461 | 1512 | 1456 | 1508 | 1445 | 1497 | 1439 | 1489 | 1445 | 1497 | 1515 | 1540 | 1551 | 1538 | 1542 | | | | | | |
| KILN SOLIDS EXIT DEG K | 1585 | 1616 | 1590 | 1621 | 1585 | 1617 | 1600 | 1632 | 1593 | 1624 | 1588 | 1618 | 1588 | 1618 | 1610 | 1641 | 1648 | 1626 | 1638 | | | | | | |
| OPTIM. FEED RATE KG/S | 135.40 | 133.50 | 140.50 | 139.70 | 140.70 | 138.70 | 138.70 | 137.00 | 140.60 | 138.90 | 141.10 | 139.50 | 141.10 | 139.70 | 136.80 | 129.40 | 135.20 | 134.30 | 132.90 | | | | | | |

TABLE 6
LINE 7 LINEAL AIR FLOW DUCT TEMPERATURE PROFILE
(SECONDARY AIR TEMPERATURE)

DATE: 5/13/99

DISCUSSION: A TEMPERATURE PROFILE WAS TAKEN AT THE LINE 7 LINEAL AIR FLOW DUCT THERMOCOUPLE LOCATION PORT. A SET OF TRAVERSES WERE TAKEN WITH A 4 FT HAND HELD THERMOCOUPLE WITH A FEED RATE OF 540 WLTPH AND THE LINE STABLE.

| TRAVERSE POINT INCHES | TEMPERATURE DEG F | CONTROL SECONDARY AIR TEMP DEG F |
|--------------------------|----------------------|----------------------------------------|
| 2 | 1995 | 1974 |
| 6 | 2021 | |
| 8 | 2030 | |
| 14 | 2032 | |
| 18 | 2035 | |
| 22 | 2039 | |
| 26 | 2031 | |
| 30 | 2040 | |
| 34 | 2035 | |
| 38 | 2031 | 1988 |

TESTED BY: R. BRASKI
 B. SCOTT

TABLE 7
TEMPERATURE PROFILE
LINE 6 RECOUP A DUCT
FEBRUARY 5, 1999

| POINT | DISTANCE FROM INSIDE EDGE INCHES | TEMPERATURE DEG F |
|-------|----------------------------------------|----------------------|
| 1 | 1 | 1195 |
| 2 | 6 | 1230 |
| 3 | 12 | 1238 |
| 4 | 18 | 1245 |
| 5 | 24 | 1253 |
| 6 | 30 | 1212 |
| 7 | 36 | 1248 |
| 8 | 42 | 1285 |
| 9 | 48 | 1272 |
| 10 | 54 | 1277 |
| 11 | 60 | 1257 |
| 12 | 66 | 1260 |
| 13 | 71 | 1228 |

**TABLE 8
USX CFD COOLER OPTIMIZATION
INITIAL OPTIMIZATION PARAMETERS**

| VARIABLE | | AVERAGE OR EXISTING STATUS | FAN FLOW SERIES | | | FIRST PARAMETRIC SERIES | | | SECOND PARAMETRIC SERIES | | | THIRD PARAMETRIC SERIES | | | |
|--------------------------------|----|----------------------------------|----------------------------|--------|-------|----------------------------|-----------------------|-------|-----------------------------|--------|-------|----------------------------|--------|-------|-------|
| | | | 1 | 2 | 3 | 1 | 2 | 3 | 1 | 2 | 3 | 1 | 2 | 3 | |
| | | | EXPERIMENTAL DESIGN LEVELS | | | | | | | | | | | | |
| PELLET MAGNETITE INTO COOLER | *1 | %WT | 22 | 22 | ---- | ---- | 16 | 22 | 28 | 16 | 22 | 28 | 16 | 22 | 28 |
| GREENBALL FEED RATE | | WLTPH | 485 | 485 | ---- | ---- | 450 | 485 | 520 | 450 | 485 | 520 | 450 | 485 | 520 |
| 3A FAN FLOW | *2 | LBS/MIN | 13500 | 10000 | 13500 | 17000 | DETERMINED BY 3B FLOW | | | 10000 | 13500 | 17000 | 10000 | 13500 | 17000 |
| 3B FAN FLOW | | LBS/MIN | 13500 | 10000 | 13500 | 17000 | 10000 | 13500 | 17000 | 10000 | 13500 | 17000 | 10000 | 13500 | 17000 |
| UNDERBED DAMPER | *3 | LOCATION | 7/8 | 7/8 | ---- | ---- | 7/8 | ---- | ---- | 7/8 | ---- | ---- | 7/8 | ---- | ---- |
| | | POSITION | CLOSED | CLOSED | ---- | ---- | CLOSED | ---- | ---- | CLOSED | ---- | ---- | CLOSED | ---- | ---- |
| OVERBED DIVIDING WALL (8" GAP) | | LOCATION | NONE | NONE | ---- | ---- | NONE | 5/6 | 7/8 | NONE | ---- | ---- | 6/7 | ---- | ---- |
| RECOUP DUCT (B-SIDE) | *4 | LOCATION | 9 | ---- | ---- | ---- | 5 | 9 | ---- | ---- | ---- | ---- | ---- | ---- | ---- |
| THREE RECOUP DUCTS (WB 5,9,10) | *5 | LOCATION | NONE | ---- | ---- | ---- | YES | ---- | ---- | ---- | ---- | ---- | ---- | ---- | ---- |

NOTES:

PELLET MAGNETITE DETERMINED BY SVEDALA KILN DISCHARGE SAMPLES, FE++; %WT MAG.=FE++/0.2411; RANGE WAS 4.56 TO 6.94 % FE++

3A FAN FLOW WILL BE DETERMINED FROM MULTIPLE REGRESSION OF PELLET EXIT TEMP (TOP OF BED) AND PRIMARY OVER BED PRESSURE, WITH THE THREE LEVELS OF 3B FAN FLOW. (FIRST SERIES ONLY)

LOCATIONS REFER TO WINDBOX #'S 7/8 WOULD BE WALL BETWEEN WBOX 7 AND WBOX 8 ETC (WBOX 1 STARTS AT SCREED WALL)

RECOUP DUCT (B-SIDE) REFERS TO EITHER WIND BOX 5 OR 9

THREE RECOUP DUCTS (WB 5,9,10), REFERS TO ADDING A THIRD DUCT IN WBOX 5

**TABLE 9
EXPERIMENTAL DESIGNS**

FAN FLOW SERIES: 22% MAGNETITE, 485 WLTPH

| 3A FAN FLOW LBS/MIN | 3A FAN FLOW LBS/MIN |
|------------------------|------------------------|
| 10000 | 10000 |
| 10000 | 13500 |
| 10000 | 17000 |
| 13500 | 10000 |
| 13500 | 13500 |
| 13500 | 17000 |
| 17000 | 10000 |
| 17000 | 13500 |
| 17000 | 17000 |

3A FAN FLOW RATES
AS DETERMINED BY
OVER BED PRESSURE

FIRST PARAMETRIC SERIES

| RECoup B DUCT LOCATION WIND BOX # | MAGNETITE % WT | GREEN BALL FEED WLTPH | 3A FAN FLOW LBS/MIN | 3B FAN FLOW LBS/MIN | OVER BED DIVIDING WALL WIND BOX # | 3A FLOW LBS/MIN |
|-----------------------------------------|-------------------|--------------------------|------------------------|------------------------|-----------------------------------------|-----------------------|
| 1 | 6 | 16 | 450 | 10000 | NO WALL | 14670 |
| 2 | 6 | 16 | 485 | 13500 | 7/8 WALL | 11722 |
| 3 | 6 | 16 | 520 | 17000 | 5/6 WALL | 14622 |
| 4 | 6 | 22 | 450 | 13500 | 5/6 WALL | 15622 |
| 5 | 6 | 22 | 485 | 17000 | NO WALL | 11722 |
| 6 | 6 | 22 | 520 | 10000 | 7/8 WALL | 18100 |
| 7 | 6 | 28 | 450 | 17000 | 7/8 WALL | 11722 |
| 8 | 6 | 28 | 485 | 10000 | 5/6 WALL | 16620 |
| 9 | 6 | 28 | 520 | 13500 | NO WALL | 13200 |
| 10 | 9 | 16 | 450 | 17000 | 5/6 WALL | 14622 |
| 11 | 9 | 16 | 485 | 10000 | NO WALL | 14670 |
| 12 | 9 | 16 | 520 | 13500 | 7/8 WALL | 11722 |
| 13 | 9 | 22 | 450 | 10000 | 7/8 WALL | 11722 |
| 14 | 9 | 22 | 485 | 13500 | 5/6 WALL | 12622 |
| 15 | 9 | 22 | 520 | 17000 | NO WALL | 11722 |
| 16 | 9 | 28 | 450 | 13500 | NO WALL | 13200 |
| 17 | 9 | 28 | 485 | 17000 | 7/8 WALL | 12622 |
| 18 | 9 | 28 | 520 | 10000 | 5/6 WALL | 18622 |

SECOND AND THIRD SERIES

| | | | | | SECOND | THIRD |
|----|---|----|-----|-------|--------|----------|
| 1 | 9 | 16 | 450 | 10000 | 10000 | 6/7 WALL |
| 2 | 9 | 16 | 450 | 13500 | 17000 | 6/7 WALL |
| 3 | 9 | 18 | 450 | 17000 | 13500 | 6/7 WALL |
| 4 | 9 | 16 | 485 | 10000 | 17000 | 6/7 WALL |
| 5 | 9 | 16 | 485 | 13500 | 13500 | 6/7 WALL |
| 6 | 9 | 16 | 485 | 17000 | 10000 | 6/7 WALL |
| 7 | 9 | 16 | 520 | 10000 | 13500 | 6/7 WALL |
| 8 | 9 | 18 | 520 | 13500 | 10000 | 6/7 WALL |
| 9 | 9 | 18 | 520 | 17000 | 17000 | 6/7 WALL |
| 10 | 9 | 22 | 450 | 10000 | 17000 | 6/7 WALL |
| 11 | 9 | 22 | 450 | 13500 | 13500 | 6/7 WALL |
| 12 | 9 | 22 | 450 | 17000 | 10000 | 6/7 WALL |
| 13 | 9 | 22 | 485 | 10000 | 13500 | 6/7 WALL |
| 14 | 9 | 22 | 485 | 13500 | 10000 | 6/7 WALL |
| 15 | 9 | 22 | 485 | 17000 | 17000 | 6/7 WALL |
| 16 | 9 | 22 | 520 | 10000 | 10000 | 6/7 WALL |
| 17 | 9 | 22 | 520 | 13500 | 17000 | 6/7 WALL |
| 18 | 9 | 22 | 520 | 17000 | 13500 | 6/7 WALL |
| 19 | 9 | 28 | 450 | 10000 | 13500 | 6/7 WALL |
| 20 | 9 | 28 | 450 | 13500 | 10000 | 6/7 WALL |
| 21 | 9 | 28 | 450 | 17000 | 17000 | 6/7 WALL |
| 22 | 9 | 28 | 485 | 10000 | 10000 | 6/7 WALL |
| 23 | 9 | 28 | 485 | 13500 | 17000 | 6/7 WALL |
| 24 | 9 | 28 | 485 | 17000 | 13500 | 6/7 WALL |
| 25 | 9 | 28 | 520 | 10000 | 17000 | 6/7 WALL |
| 26 | 9 | 28 | 520 | 13500 | 13500 | 6/7 WALL |
| 27 | 9 | 28 | 520 | 17000 | 10000 | 6/7 WALL |

**TABLE 10:
MINNTAC FIRST PARAMETRIC SERIES
VARIED COOLER MODIFICATIONS**

RECOUP B IN WBOX 9 POSITION

| | | | 3A/3B FAN FLOW SERIES | | | | |
|-----------------------------------|---------|--|-----------------------|-----------|-----------|-----------|-----------|
| | | | OPT_1 | OPT_2 | OPT_3 | OPT_4 | OPT_5 |
| | | | 5_14_0800 | 5_18_0805 | 5_19_0735 | 5_20_0745 | 5_21_0715 |
| FEED RATE (WET BALLS ON GRATE) | LTPH | | 485.00 | 485.00 | 485.00 | 485.00 | 485.00 |
| PRODUCTION FACTOR | | | 0.86 | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | | 417.10 | 417.10 | 417.10 | 417.10 | 417.10 |
| GREENBALL MAGNETITE %WT | | | 87.00 | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | 5.31 | 5.31 | 5.31 | 5.31 | 5.31 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | | 22.00 | 22.00 | 22.00 | 22.00 | 22.00 |
| AVG PELLET TEMP INTO COOLER | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 | 2,250 |
| COOLER SPEED | IN/MIN | | 92 | 92 | 92 | 92 | 92 |
| COOLER BED DEPTH | IN | | 28 | 28 | 28 | 28 | 28 |
| PRIMARY COOLING ZONE | | | | | | | |
| 3A FAN FLOW | LBS/MIN | | 10,000 | 10,000 | 10,000 | 13,500 | 13,500 |
| G/S (THRU BED) | LBS/LB | | 0.4581 | 0.4556 | 0.4517 | 0.6551 | 0.6563 |
| INLET | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | | -0.2467 | -0.1868 | -0.1213 | 0.0288 | -0.0372 |
| U'BED | IN.H2O | | 13.040 | 13.450 | 14.080 | 16.810 | 16.570 |
| KFACT | | | 545 | 545 | 545 | 545 | 545 |
| KILN SECONDARY AIR AVG | DEGF | | 2,388 | 2,366 | 2,334 | 2,196 | 2,235 |
| | LBS/MIN | | 3,260 | 3,902 | 4,523 | 5,666 | 5,135 |
| G/S | LBS/MIN | | 0.2093 | 0.2506 | 0.2905 | 0.3639 | 0.3297 |
| OUTLET | INH2O | | -0.40 | -0.40 | -0.40 | -0.40 | -0.40 |
| FIRING HOOD AIR | DEGF | | 2,309 | 2,309 | 2,306 | 2,297 | 2,299 |
| | LBS/MIN | | 2,318 | 2,441 | 2,579 | 2,896 | 2,784 |
| G/S | LBS/LB | | 0.1489 | 0.1568 | 0.1656 | 0.1860 | 0.1788 |
| OUTLET | INH2O | | -0.73 | -0.73 | -0.73 | -0.73 | -0.73 |
| WINDBOX LEAKAGE | LBS/MIN | | 2,867 | 2,905 | 2,966 | 3,300 | 3,280 |
| GAP HEIGHT | INCHES | | 3.62 | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | INCHES | | 1.67 | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | | | | |
| LOCATION (BETWEEN WBOXES) | | | NONE | NONE | NONE | NONE | NONE |
| GAP HEIGHT | INCHES | | NA | NA | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | LBS/MIN | | NA | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | | |
| 3B FAN FLOW | LBS/MIN | | 10,000 | 13,500 | 17,001 | 17,001 | 13,500 |
| G/S (THRU BED) | LBS/MIN | | 0.6311 | 0.8560 | 1.0809 | 1.0815 | 0.8568 |
| INLET | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | | -0.3799 | -0.2278 | -0.0840 | -0.0431 | -0.1987 |
| U'BED | IN.H2O | | 10.950 | 12.917 | 14.450 | 13.253 | 11.480 |
| RECOUP B SIDE (WB 6) AVG | DEGF | | | | | | |
| | LBS/MIN | | | | | | |
| OUTLET | INH2O | | | | | | |
| RECOUP B SIDE (WB 9) AVG | DEGF | | 2,098 | 1,986 | 1,840 | 1,475 | 1,585 |
| | LBS/MIN | | 2,326 | 2,604 | 2,885 | 3,268 | 2,944 |
| OUTLET | INH2O | | -1.11 | -1.11 | -1.11 | -1.11 | -1.11 |
| RECOUP A SIDE (WB10) AVG | DEGF | | 1,877 | 1,649 | 1,405 | 1,115 | 1,280 |
| | LBS/MIN | | 2,155 | 2,565 | 2,994 | 3,393 | 2,938 |
| OUTLET | INH2O | | -0.90 | -0.90 | -0.90 | -0.90 | -0.90 |
| COOLER VENT STACK AVG | DEGF | | 1,096 | 803 | 589 | 434 | 587 |
| | LBS/MIN | | 7,054 | 9,007 | 10,950 | 11,887 | 9,881 |
| OUTLET | INH2O | | -0.88 | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | DEGF | | 795 | 507 | 338 | 226 | 340 |
| WINDBOX LEAKAGE | LBS/MIN | | 172 | 171 | 169 | 159 | 158 |
| GAP HEIGHT | INCHES | | 1 | 1 | 1 | 1 | 1.0 |
| O'BED LEAKAGE | LBS/MIN | | (153) | (96) | (66) | (71) | (103) |
| GAP HEIGHT | INCHES | | 1 | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | 20,153 | 23,595 | 27,066 | 30,571 | 27,103 |
| TOTAL AIR OUT | | | 20,152 | 23,595 | 27,067 | 30,570 | 27,119 |

TABLE 10:
MINNTAC FIRST PARAMETRIC SERIES
VARIED COOLER MODIFICATIONS

2 OF 6

RECOUP B IN WBOX 9 POSITION

3A/3B FAN FLOW SERIES

| | | OPT_6 5_26_0715 | OPT_7 5_25_0955 | OPT_8 5_27_0655 | OPT_9 6_01_0715 | |
|-----------------------------------|----------------|--------------------|--------------------|--------------------|--------------------|---------|
| FEED RATE (WET BALLS ON GRATE) | LTPH | 485.00 | 485.00 | 485.00 | 485.00 | |
| PRODUCTION FACTOR | | 0.86 | 0.86 | 0.86 | 0.86 | |
| PELLET FEED TO COOLER | LTPH | 417.10 | 417.10 | 417.10 | 417.10 | |
| GREENBALL MAGNETITE %WT | | 87.00 | 87.00 | 87.00 | 87.00 | |
| FE++ IN COOLER FEED | | 5.31 | 5.31 | 5.31 | 5.31 | |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | 22.00 | 22.00 | 22.00 | 22.00 | |
| AVG PELLETT TEMP INTO COOLER | DEGF | 2,250 | 2,250 | 2,250 | 2,250 | |
| COOLER SPEED | IN/MIN | 92 | 92 | 92 | 92 | |
| COOLER BED DEPTH | IN | 28 | 28 | 28 | 28 | |
| PRIMARY COOLING ZONE | | | | | | |
| | 3A FAN FLOW | LBS/MIN | 13,500 | 17,001 | 17,001 | 17,001 |
| | G/S (THRU BED) | LBS/LB | 0.6575 | 0.8616 | 0.8607 | 0.8598 |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 |
| | O'BED | IN.H2O | -0.1036 | 0.0649 | 0.1382 | 0.2115 |
| | U'BED | IN.H2O | 16.34 | 19.080 | 19.27 | 19.46 |
| | KFACT | | 545 | 545 | 545 | 545 |
| KILN SECONDARY AIR | AVG | DEGF | 2,273 | 2,125 | 2,075 | 2,027 |
| | | LBS/MIN | 4,571 | 5,826 | 6,382 | 6,917 |
| | G/S | LBS/MIN | 0.2935 | 0.3742 | 0.4099 | 0.4442 |
| | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| FIRING HOOD AIR | | DEGF | 2,297 | 2,288 | 2,289 | 2,290 |
| | | LBS/MIN | 2,675 | 3,055 | 3,154 | 3,255 |
| | G/S | LBS/LB | 0.1718 | 0.1962 | 0.2025 | 0.2090 |
| | OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 |
| WINDBOX LEAKAGE | | LBS/MIN | 3,261 | 3,584 | 3,597 | 3,612 |
| GAP HEIGHT | | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | | | |
| LOCATION (BETWEEN WBOXES) | | | NONE | NONE | NONE | NONE |
| GAP HEIGHT | | INCHES | NA | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | LBS/MIN | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | |
| | 3B FAN FLOW | LBS/MIN | 10,000 | 10,000 | 13,500 | 17,001 |
| | G/S (THRU BED) | LBS/MIN | 0.6322 | 0.6329 | 0.8574 | 1.0820 |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 |
| | O'BED | IN.H2O | -0.3533 | -0.3339 | -0.1785 | -0.0206 |
| | U'BED | IN.H2O | 9.52 | 8.41 | 10.34 | 12.13 |
| RECOUP B SIDE (WB 6) | AVG | DEGF | | | | |
| | | LBS/MIN | | | | |
| | OUTLET | INH2O | | | | |
| RECOUP B SIDE (WB 9) | AVG | DEGF | 1,707 | 1,354 | 1,229 | 1,121 |
| | | LBS/MIN | 2,627 | 2,998 | 3,346 | 3,712 |
| | OUTLET | INH2O | -1.11 | -1.11 | -1.11 | -1.11 |
| RECOUP A SIDE (WB10) | AVG | DEGF | 1,468 | 1,108 | 972 | 840 |
| | | LBS/MIN | 2,465 | 2,825 | 3,317 | 3,826 |
| | OUTLET | INH2O | -0.90 | -0.90 | -0.90 | -0.90 |
| COOLER VENT STACK | AVG | DEGF | 798 | 585 | 440 | 334 |
| | | LBS/MIN | 7,908 | 8,738 | 10,666 | 12,603 |
| | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | 527 | 358 | 243 | 171 |
| WINDBOX LEAKAGE | | LBS/MIN | 156 | 144 | 148 | 151 |
| GAP HEIGHT | | INCHES | 1.0 | 1.0 | 1.0 | 1.0 |
| O'BED LEAKAGE | | LBS/MIN | (162) | (171) | (111) | (76) |
| GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | 23,661 | 27,171 | 30,611 | 34,078 |
| TOTAL AIR OUT | | | 23,663 | 27,170 | 30,610 | 34,076 |

**TABLE 10:
MINNTAC FIRST PARAMETRIC SERIES
VARIED COOLER MODIFICATIONS**

RECOUP B IN WBOX 9 POSITION

| | | | | O'BED DIVIDING WALL BETWEEN WBOXES 7 & 8 (ALIGNED W | | | | |
|-----------------------------------|----------------|---------|--|-----------------------------------------------------|----------|----------|------------------|-----------|
| | | | | 3A FLOW SERIES | | | FACTORIAL POINTS | |
| | | | | 3A12822 | 3A11722 | 3A10822 | 3A11722 | 3A11722 |
| | | | | 6_2_0800 | 6_3_0750 | 6_7_0700 | 6_9_0750 | 6_10_0000 |
| FEED RATE (WET BALLS ON GRATE) | LTPH | | | 485.00 | 485.00 | 485.00 | 520.00 | 450.00 |
| PRODUCTION FACTOR | | | | 0.86 | 0.88 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | | | 417.10 | 417.10 | 417.10 | 447.20 | 387.00 |
| GREENBALL MAGNETITE %WT | | | | 87.00 | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | 6.75 | 6.75 | 6.75 | 3.86 | 5.31 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | | | 28.00 | 28.00 | 28.00 | 16 | 22 |
| AVG PELLETTMP INTO COOLER | DEGF | | | 2,250 | 2,250 | 2,250 | 2,250 | 2,250 |
| COOLER SPEED | IN/MIN | | | 92 | 92 | 92 | 98 | 85 |
| COOLER BED DEPTH | IN | | | 28 | 28 | 28 | 28 | 28 |
| PRIMARY COOLING ZONE | | | | | | | | |
| | 3A FAN FLOW | LBS/MIN | | 12,622 | 11,722 | 10,822 | 11,722 | 11,722 |
| | G/S (THRU BED) | LBS/LB | | 0.6028 | 0.5509 | 0.4989 | 0.5156 | 0.6006 |
| | INLET | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 |
| | O'BED | IN.H2O | | 0.0466 | -0.0158 | -0.0689 | -0.0469 | -0.0781 |
| | U'BED | IN.H2O | | 16.31 | 15.53 | 14.79 | 15.19 | 14.46 |
| | KFACT | | | 545 | 545 | 545 | 545 | 545 |
| KILN SECONDARY AIR | AVG | DEGF | | 2,252 | 2,305 | 2,348 | 2,253 | 2,243 |
| | | LBS/MIN | | 5,797 | 5,337 | 4,926 | 5,150 | 4,916 |
| | G/S | LBS/MIN | | 0.3723 | 0.3427 | 0.3163 | 0.3085 | 0.3403 |
| | OUTLET | INH2O | | -0.40 | -0.40 | -0.40 | -0.40 | -0.40 |
| FIRING HOOD AIR | | DEGF | | 2,308 | 2,314 | 2,318 | 2,283 | 2,306 |
| | | LBS/MIN | | 2,913 | 2,790 | 2,682 | 2,745 | 2,665 |
| | G/S | LBS/LB | | 0.1871 | 0.1792 | 0.1722 | 0.1644 | 0.1844 |
| | OUTLET | INH2O | | -0.73 | -0.73 | -0.73 | -0.73 | -0.73 |
| WINDBOX LEAKAGE | | LBS/MIN | | 3,236 | 3,143 | 3,053 | 3,114 | 3,044 |
| GAP HEIGHT | | INCHES | | 3.62 | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | INCHES | | 1.67 | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | | | | | |
| LOCATION (BETWEEN WBOXES) | | | | 7/8 | 7/8 | 7/8 | 7/8 | 7/8 |
| GAP HEIGHT | | INCHES | | 8 | 8 | 8 | 8 | 8 |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | LBS/MIN | | -127.7 | -81.2 | -41.0 | -160.7 | -233.7 |
| SECONDARY COOLING ZONE | | | | | | | | |
| | 3B FAN FLOW | LBS/MIN | | 17,001 | 17,001 | 17,001 | 13,500 | 10,000 |
| | G/S (THRU BED) | LBS/MIN | | 1.0813 | 1.0811 | 1.0809 | 0.7985 | 0.6814 |
| | INLET | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 |
| | O'BED | IN.H2O | | -0.1124 | -0.0934 | -0.0837 | -0.2761 | -0.5229 |
| | U'BED | IN.H2O | | 13.7 | 14.11 | 11.99 | 12.66 | 9.45 |
| RECOUP B SIDE (WB 6) | AVG | DEGF | | | | | | |
| | | LBS/MIN | | | | | | |
| | OUTLET | INH2O | | | | | | |
| RECOUP B SIDE (WB 9) | AVG | DEGF | | 1,589 | 1,712 | 1,820 | 1,783 | 1,677 |
| | | LBS/MIN | | 3,031 | 2,966 | 2,901 | 2,627 | 2,244 |
| | OUTLET | INH2O | | -1.11 | -1.11 | -1.11 | -1.11 | -1.11 |
| RECOUP A SIDE (WB10) | AVG | DEGF | | 1,158 | 1,265 | 1,366 | 1,438 | 1,365 |
| | | LBS/MIN | | 3,178 | 3,105 | 3,030 | 2,593 | 2,048 |
| | OUTLET | INH2O | | -0.90 | -0.90 | -0.90 | -1.00 | -1.00 |
| COOLER VENT STACK | AVG | DEGF | | 458 | 508 | 501 | 738 | 743 |
| | | LBS/MIN | | 11,375 | 11,283 | 11,126 | 8,924 | 6,828 |
| | OUTLET | INH2O | | -0.88 | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | | 248 | 275 | 307.4 | 491 | 525.2 |
| WINDBOX LEAKAGE | | LBS/MIN | | 163 | 166 | 169 | 169 | 155 |
| GAP HEIGHT | | INCHES | | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| O'BED LEAKAGE | | LBS/MIN | | (71) | (68) | (65) | (101) | (178) |
| GAP HEIGHT | | INCHES | | 1 | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | | 29,694 | 28,790 | 27,888 | 25,323 | 21,900 |
| TOTAL AIR OUT | | | | 29,693 | 28,790 | 27,887 | 25,323 | 21,900 |

**TABLE 10:
MINNTAC FIRST PARAMETRIC SERIES
VARIED COOLER MODIFICATIONS**

4 OF 6

RECOUP B IN WBOX 9 POSITION

| | | OBED DIVIDING WALL BETWEEN WBOXES 5 & 6 | | | | |
|-----------------------------------|---------|-----------------------------------------|-----------|-----------|------------------|-----------|
| | | 3A FLOW SERIES | | | FACTORIAL POINTS | |
| | | 3A 12622 | 3A 13622 | 3A 14622 | 3A 16622 | 3A_14622 |
| | | 6_11_0710 | 6_12_0800 | 6_13_0905 | 6_14_0715 | 6_15_0800 |
| FEED RATE (WET BALLS ON GRATE) | LTPH | 485.00 | 485.00 | 485.00 | 520.00 | 450.00 |
| PRODUCTION FACTOR | | 0.86 | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | 417.10 | 417.10 | 417.10 | 447.20 | 387.00 |
| GREENBALL MAGNETITE %WT | | 87.00 | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | 5.31 | 5.31 | 5.31 | 6.75 | 3.86 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | 22 | 22 | 22 | 28 | 16 |
| AVG PELLETT TEMP INTO COOLER | DEGF | 2,250 | 2,250 | 2,250 | 2,250 | 2,250 |
| COOLER SPEED | IN/MIN | 92 | 92 | 92 | 98 | 85 |
| COOLER BED DEPTH | IN | 28 | 28 | 28 | 28 | 28 |
| PRIMARY COOLING ZONE | | | | | | |
| 3A FAN FLOW | LBS/MIN | 12,621 | 13,622 | 14,622 | 16,621 | 14,622 |
| G/S (THRU BED) | LBS/LB | 0.6053 | 0.6630 | 0.7211 | 0.7786 | 0.7805 |
| INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | -0.2376 | -0.2022 | -0.1648 | -0.0827 | -0.1674 |
| U'BED | IN.H2O | 15.89 | 16.75 | 17.57 | 19.65 | 17.06 |
| KFACT | | 545 | 545 | 545 | 545 | 545 |
| KILN SECONDARY AIR | AVG | 2,343 | 2,316 | 2,285 | 2,290 | 2,202 |
| | LBS/MIN | 3,490 | 3,817 | 4,144 | 4,698 | 4,246 |
| G/S | LBS/MIN | 0.2241 | 0.2451 | 0.2661 | 0.2814 | 0.2938 |
| OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 | -0.40 |
| FIRING HOOD AIR | DEGF | 2,294 | 2,290 | 2,288 | 2,290 | 2,280 |
| | LBS/MIN | 2,459 | 2,559 | 2,659 | 2,880 | 2,651 |
| G/S | LBS/LB | 0.1579 | 0.1643 | 0.1708 | 0.1725 | 0.1835 |
| OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 | -0.73 |
| WINDBOX LEAKAGE | LBS/MIN | 3,196 | 3,298 | 3,393 | 3,621 | 3,345 |
| GAP HEIGHT | INCHES | 3.62 | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | INCHES | 1.67 | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | | | |
| LOCATION (BETWEEN WBOXES) | | 5/6 | 5/6 | 5/6 | 5/6 | 5/6 |
| GAP HEIGHT | INCHES | 8 | 8 | 8 | 8 | 8 |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | LBS/MIN | 246.4 | 244.6 | 243.3 | 182.8 | 302.5 |
| SECONDARY COOLING ZONE | | | | | | |
| 3B FAN FLOW | LBS/MIN | 13,500 | 13,500 | 13,500 | 10,000 | 17,001 |
| G/S (THRU BED) | LBS/MIN | 0.8565 | 0.8567 | 0.8569 | 0.5897 | 1.1662 |
| INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | 0.0033 | 0.0086 | 0.0129 | -0.1583 | 0.175 |
| U'BED | IN.H2O | 12.04 | 11.65 | 11.29 | 9.34 | 12.31 |
| RECOUP B SIDE (WB 6) | AVG | | | | | |
| | LBS/MIN | | | | | |
| OUTLET | INH2O | | | | | |
| RECOUP B SIDE (WB 9) | AVG | 1,835 | 1,736 | 1,640 | 1,704 | 1,380 |
| | LBS/MIN | 3,155 | 3,260 | 3,370 | 3,155 | 3,843 |
| OUTLET | INH2O | -1.11 | -1.11 | -1.11 | -1.11 | -1.11 |
| RECOUP A SIDE (WB10) | AVG | 1,561 | 1,452 | 1,346 | 1,419 | 1,059 |
| | LBS/MIN | 3,133 | 3,244 | 3,359 | 2,990 | 3,981 |
| OUTLET | INH2O | -1.00 | -1.00 | -1.00 | -1.00 | -1.00 |
| COOLER VENT STACK | AVG | 708 | 650 | 598 | 773 | 385 |
| | LBS/MIN | 10,608 | 10,872 | 11,129 | 9,264 | 13,468 |
| OUTLET | INH2O | -0.88 | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | DEGF | 375.8 | 338 | 305.6 | 473 | 163.4 |
| WINDBOX LEAKAGE | LBS/MIN | 163 | 160 | 156 | 154 | 152 |
| GAP HEIGHT | INCHES | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| O'BED LEAKAGE | LBS/MIN | (84) | (87) | (89) | (143) | (63) |
| GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | 26,206 | 27,208 | 28,211 | 26,764 | 31,686 |
| TOTAL AIR OUT | | 26,205 | 27,210 | 28,211 | 26,762 | 31,685 |

TABLE 10:
MINNTAC FIRST PARAMETRIC SERIES
VARIED COOLER MODIFICATIONS

5 OF 6

| | | | | RECOUP B IN WBOX 9 POSITION | | | RECOUP B IN WBOX 6 POSITION | | |
|-----------------------------------|---------|---------|--------|-----------------------------|-----------|-----------|-----------------------------|-----------|-----------|
| | | | | NO OVER BED DIVIDING WALL | | | OBER DIV WALL WBOXES 5 & 6 | | |
| | | | | FACTORIAL POINTS | | | FACTORIAL POINTS | | |
| | | | | 3A_11722 | 3A_13200 | 3A_14670 | 3A_16620 | 3A_14622 | 3A_15622 |
| | | | | 6_16_0725 | 6_17_0705 | 6_18_0700 | 6_25_0725 | 6_28_0810 | 6_29_0710 |
| FEED RATE (WET BALLS ON GRATE) | LTPH | | | 520.00 | 450.00 | 485.00 | 485.00 | 520.00 | 450.00 |
| PRODUCTION FACTOR | | | | 0.86 | 0.86 | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | | | 447.20 | 387.00 | 417.10 | 417.10 | 447.20 | 386.99 |
| GREENBALL MAGNETITE %WT | | | | 87.00 | 87.00 | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | 5.31 | 6.75 | 3.86 | 6.75 | 3.86 | 5.31 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | | | 22 | 28 | 16 | 28 | 16 | 22 |
| AVG PELLET TEMP INTO COOLER | DEGF | | | 2,250 | 2,250 | 2,250 | 2,250 | 2,250 | 2,250 |
| COOLER SPEED | IN/MIN | | | 98 | 85 | 92 | 92 | 98 | 85 |
| COOLER BED DEPTH | IN | | | 28 | 28 | 28 | 28 | 28 | 28 |
| PRIMARY COOLING ZONE | | | | | | | | | |
| 3A FAN FLOW | LBS/MIN | | | 11,722 | 13,200 | 14,669 | 16,617 | 14,622 | 15,622 |
| G/S (THRU BED) | LBS/LB | | | 0.5129 | 0.6902 | 0.7267 | 0.8430 | 0.6751 | 0.8493 |
| INLET | DEGF | | | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | | | -0.03822 | -0.0617 | -0.0563 | -0.11 | -0.1613 | -0.1486 |
| U'BED | IN.H2O | | | 15.69 | 16.07 | 9.587 | 19.08 | 18.01 | 17.75 |
| KFACT | | | | 545 | 545 | 545 | 545 | 545 | 545 |
| KILN SECONDARY AIR | AVG | DEGF | | 2,300 | 2,259 | 2,181 | 2,271 | 2,262 | 2,227 |
| | | LBS/MIN | | 5,156 | 4,937 | 4,989 | 4,469 | 4,171 | 4,232 |
| | | G/S | | 0.3088 | 0.3417 | 0.3204 | 0.2870 | 0.2499 | 0.2929 |
| | | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 | -0.40 | -0.40 |
| FIRING HOOD AIR | | DEGF | | 2,297 | 2,318 | 2,280 | 2,296 | 2,272 | 2,292 |
| | | LBS/MIN | | 2,761 | 2,720 | 2,792 | 2,892 | 2,757 | 2,773 |
| | | G/S | LBS/LB | 0.1654 | 0.1883 | 0.1793 | 0.1857 | 0.1651 | 0.1919 |
| | | OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 | -0.73 | -0.73 |
| WINDBOX LEAKAGE | | LBS/MIN | | 3,159 | 3,228 | 3,354 | 3,490 | 3,350 | 3,351 |
| GAP HEIGHT | | INCHES | | 3.62 | 3.62 | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | INCHES | | 1.67 | 1.67 | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | NONE | NONE | NONE | 5/6 | 5/6 | 5/6 |
| LOCATION (BETWEEN WBOXES) | | | | | | | 8 | 8 | 8 |
| GAP HEIGHT | | INCHES | | | | | 8 | 8 | 8 |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | LBS/MIN | | NA | NA | NA | 82.7 | 214.9 | 133.8 |
| SECONDARY COOLING ZONE | | | | | | | | | |
| 3B FAN FLOW | LBS/MIN | | | 17,001 | 13,500 | 10,000 | 10,000 | 17,001 | 13,500 |
| G/S (THRU BED) | LBS/MIN | | | 1.0080 | 0.9237 | 0.6325 | 0.6330 | 1.0088 | 0.9245 |
| INLET | DEGF | | | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | | | -0.0131 | -0.2284 | -0.3354 | -0.1659 | 0.3235 | -0.0036 |
| U'BED | IN.H2O | | | 14.73 | 11.05 | 8.96 | 8.77 | 13.49 | 10.33 |
| RECOUP B SIDE (WB 6) | AVG | DEGF | | | | | 1,771 | 1,840 | 1,646 |
| | | LBS/MIN | | | | | 3,191 | 3,654 | 3,469 |
| | | OUTLET | INH2O | | | | -1.11 | -1.11 | -1.11 |
| RECOUP B SIDE (WB 9) | AVG | DEGF | | 1,789 | 1,544 | 1,529 | | | |
| | | LBS/MIN | | 3,039 | 2,926 | 2,766 | | | |
| | | OUTLET | INH2O | -1.11 | -1.11 | -1.11 | | | |
| RECOUP A SIDE (WB10) | AVG | DEGF | | 1,393 | 1,232 | 1,294 | 1,210 | 1,204 | 1,001 |
| | | LBS/MIN | | 3,151 | 2,909 | 2,594 | 3,002 | 3,882 | 3,539 |
| | | OUTLET | INH2O | -1.00 | -1.00 | -1.00 | -1.00 | -1.00 | -1.00 |
| COOLER VENT STACK | AVG | DEGF | | 593 | 527 | 694 | 652 | 533 | 453 |
| | | LBS/MIN | | 11,347 | 9,932 | 8,192 | 9,581 | 13,296 | 11,710 |
| | | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | DEGF | | | 338 | 287.6 | 446 | 384.8 | 258.8 | 221 |
| WINDBOX LEAKAGE | | LBS/MIN | | 171 | 154 | 150 | 142 | 157 | 143 |
| GAP HEIGHT | | INCHES | | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| O'BED LEAKAGE | | LBS/MIN | | (60) | (108) | (167) | (147) | (49) | (96) |
| GAP HEIGHT | | INCHES | | 1 | 1 | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | | 28,783 | 26,807 | 24,837 | 26,763 | 31,671 | 29,218 |
| TOTAL AIR OUT | | | | 28,785 | 26,807 | 24,837 | 26,768 | 31,268 | 29,217 |

**TABLE 10:
MINNTAC FIRST PARAMETRIC SERIES
VARIED COOLER MODIFICATIONS**

6 OF 6

RECOUP B IN WBOX 6 POSITION

| | | OBED DIV WALL WBOXES 7/8 | | | | NO OBED WALL | | |
|-----------------------------------|---------|--------------------------|----------|----------|----------|--------------|-----------|-----------|
| | | FACTORIAL POINTS | | | | | | |
| | | 3A 11722 | 3A 14672 | 3A 11672 | 3A 16100 | 3A 13200 | 3A 11722 | 3A 14670 |
| | | 6_30_1500 | 7_6_0900 | 7_8_0740 | 7_9_0955 | 7_14_0740 | 7_15_0730 | 7_16_0730 |
| FEED RATE (WET BALLS ON GRATE) | LTPH | 485.00 | 485.00 | 450.00 | 520.00 | 520.00 | 485 | 450 |
| PRODUCTION FACTOR | | 0.86 | 0.86 | 0.86 | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | 417.10 | 417.10 | 386.99 | 447.20 | 447.20 | 417.10 | 386.99 |
| GREENBALL MAGNETITE %WT | | 87.00 | 87.00 | 87.00 | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | 3.86 | 3.86 | 6.75 | 5.31 | 6.75 | 5.31 | 3.86 |
| FE3O4 IN FEED (FE3O4=FE++/1.2412) | %WT | 16 | 16 | 28 | 22 | 28 | 22 | 16 |
| AVG PELLET TEMP INTO COOLER | DEGF | 2,250 | 2,250 | 2,250 | 2,250 | 2,250 | 2,250 | 2,250 |
| COOLER SPEED | IN/MIN | 92 | 92 | 85 | 98 | 98 | 92 | 85 |
| COOLER BED DEPTH | IN | 28 | 28 | 28 | 28 | 28 | 28 | 28 |
| PRIMARY COOLING ZONE | | | | | | | | |
| 3A FAN FLOW | LBS/MIN | 11,722 | 14,672 | 11,722 | 16,101 | 13,200 | 11,722 | 14,669 |
| G/S (THRU BED) | LBS/LB | 0.5599 | 0.7308 | 0.6017 | 0.7565 | 0.5970 | 0.5568 | 0.7916 |
| INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | -0.2311 | -0.0848 | -0.2095 | -0.0139 | -0.0939 | -0.1114 | -0.1489 |
| U'BED | IN.H2O | 14.81 | 17.29 | 15.08 | 18.99 | 16.96 | 15.34 | 16.6 |
| KFACT | | 545 | 545 | 545 | 545 | 545 | 545 | 545 |
| KILN SECONDARY AIR | AVG | 2,285 | 2,157 | 2,334 | 2,191 | 2,302 | 2,245 | 2,170 |
| | LBS/MIN | 3,437 | 4,768 | 3,624 | 5,230 | 4,578 | 4,552 | 4,239 |
| | G/S | 0.2207 | 0.3062 | 0.2508 | 0.3132 | 0.2742 | 0.2924 | 0.2934 |
| | OUTLET | -0.40 | -0.40 | -0.40 | -0.40 | -0.40 | -0.40 | -0.40 |
| FIRING HOOD AIR | DEGF | 2,287 | 2,280 | 2,319 | 2,285 | 2,305 | 2,287 | 2,283 |
| | LBS/MIN | 2,481 | 2,833 | 2,512 | 3,009 | 2,777 | 2,720 | 2,713 |
| | G/S | 0.1593 | 0.1819 | 0.1739 | 0.1802 | 0.1663 | 0.1747 | 0.1878 |
| | OUTLET | -0.73 | -0.73 | -0.73 | -0.73 | -0.73 | -0.73 | -0.73 |
| WINDBOX LEAKAGE | LBS/MIN | 3,003 | 3,292 | 3,028 | 3,470 | 3,232 | 3,052 | 3,232 |
| GAP HEIGHT | INCHES | 3.62 | 3.62 | 3.62 | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | INCHES | 1.67 | 1.67 | 1.67 | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | | | | | |
| LOCATION (BETWEEN WBOXES) | | 7/8 | 7/8 | 7/8 | 7/8 | NONE | NONE | NONE |
| GAP HEIGHT | INCHES | 8 | 8 | 8 | 8 | | | |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | LBS/MIN | 198.5 | 78.3 | 297.6 | -97.3 | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | | | |
| 3B FAN FLOW | LBS/MIN | 13,500 | 13,500 | 17,001 | 10,000 | 13,500 | 17,001 | 10,000 |
| G/S (THRU BED) | LBS/MIN | 0.8567 | 0.8574 | 1.1659 | 0.5901 | 0.7989 | 1.0815 | 0.6825 |
| INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | 0.0247 | -0.0521 | 0.2822 | -0.2768 | -0.0342 | 0.0774 | -0.2953 |
| U'BED | IN.H2O | 12.18 | 11.02 | 13.61 | 9.22 | 12.57 | 14.01 | 8.45 |
| RECOUP B SIDE (WB 6) | AVG | 2,059 | 1,737 | 2,066 | 1,770 | 2,053 | 1,976 | 1,696 |
| | LBS/MIN | 2,534 | 2,969 | 2,580 | 3,056 | 2,777 | 2,611 | 2,860 |
| | OUTLET | -1.11 | -1.11 | -1.11 | -1.11 | -1.11 | -1.11 | -1.11 |
| RECOUP B SIDE (WB 9) | AVG | | | | | | | |
| | LBS/MIN | | | | | | | |
| | OUTLET | | | | | | | |
| RECOUP A SIDE (WB10) | AVG | 1,496 | 1,132 | 1,333 | 1,248 | 1,484 | 1,296 | 1,140 |
| | LBS/MIN | 3,108 | 3,300 | 3,678 | 2,720 | 3,019 | 3,379 | 2,768 |
| | OUTLET | -1.00 | -1.00 | -1.00 | -1.00 | -1.00 | -1.00 | -1.00 |
| COOLER VENT STACK | AVG | 734 | 542 | 521 | 718 | 747 | 527 | 606 |
| | LBS/MIN | 10,581 | 10,957 | 13,193 | 8,621 | 10,236 | 12,104 | 8,879 |
| | OUTLET | -0.88 | -0.88 | -0.88 | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | YES | YES | YES | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | DEGF | 397.4 | 293 | 217.4 | 478.4 | 444.2 | 266 | 357.8 |
| WINDBOX LEAKAGE | LBS/MIN | 159 | 149 | 157 | 148 | 162 | 160 | 140 |
| GAP HEIGHT | INCHES | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| O'BED LEAKAGE | LBS/MIN | (80) | (94) | (49) | (153) | (82) | (57) | (161) |
| GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | 25,302 | 28,266 | 28,771 | 26,254 | 26,782 | 28,780 | 24,830 |
| TOTAL AIR OUT | | 25,303 | 28,267 | 28,772 | 26,253 | 26,781 | 28,779 | 24,831 |

TABLE 11:
MINNTAC SECOND PARAMETRIC SERIES:
CURRENT COOLER - NO OVER BED WALL

| | | | 16/450/100/100 | 16/450/135/170 | 16/450/170/135 | 16/485/100/170 |
|-----------------------------------------|-----------------------------------|---------|----------------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | LTPH | | 450.00 | 450.00 | 450.00 | 485.00 |
| PRODUCTION FACTOR (1-NET FURNACE LOSS) | | | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | | 387.00 | 387.00 | 387.00 | 417.10 |
| GREENBALL MAGNETITE %WT | | | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | 3.86 | 3.86 | 3.86 | 3.86 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | | 16.00 | 16.00 | 16.00 | 16.00 |
| AVG PELLETT TEMP INTO COOLER | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | | |
| | 3A FAN FLOW | LBS/MIN | 10,000 | 13,500 | 17,001 | 10,001 |
| | G/S (THRU BED) | LBS/LB | 0.5007 | 0.7147 | 0.9375 | 0.4573 |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 |
| | O'BED | IN.H2O | -0.2821 | -0.0647 | 0.0324 | -0.1712 |
| | U'BED | IN.H2O | 12.543 | 16.01 | 18.278 | 13.79 |
| | KFACT | | 545 | 545 | 545 | 545 |
| BC 14 | KILN SECONDARY AIR | AVG | 2,328 | 2,097 | 1,959 | 2,293 |
| | | LBS/MIN | 3,222 | 5,684 | 6,444 | 4,601 |
| | | G/S | 0.2230 | 0.3934 | 0.4460 | 0.2955 |
| | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| BC 15 | FIRING HOOD AIR | AVG | 2,298 | 2,288 | 2,278 | 2,290 |
| | | LBS/MIN | 2,155 | 2,702 | 2,957 | 2,388 |
| | | G/S | 0.1492 | 0.1870 | 0.2047 | 0.1534 |
| | OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 | WINDBOX LEAKAGE | LBS/MIN | 2,766 | 3,174 | 3,456 | 2,880 |
| | GAP HEIGHT | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| | WINDBOX DAMPER POSITION | | CLOSED | CLOSED | CLOSED | CLOSED |
| | LEAK GAP ACROSS DAMPER | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| | OVERBED DIVIDING WALL: | | | | | |
| | LOCATION (BETWEEN WBOXES) | | NONE | NONE | NONE | NONE |
| | GAP HEIGHT | INCHES | NA | NA | NA | NA |
| | FLOW (- = 3A TO 3B; + = 3B TO 3A) | LBS/MIN | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | |
| | 3B FAN FLOW | LBS/MIN | 10,000 | 17,001 | 13,500 | 17,001 |
| | G/S (THRU BED) | LBS/MIN | 0.6823 | 1.1676 | 0.9258 | 1.0827 |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 |
| | O'BED | IN.H2O | -0.4456 | -0.1686 | -0.2893 | -0.1568 |
| | U'BED | IN.H2O | 10.018 | 12.3 | 9.665 | 14.07 |
| BC 11 | RECOUP B SIDE (WB 9) | AVG | 1,940 | 1,276 | 1,045 | 1,785 |
| | | LBS/MIN | 2,512 | 3,544 | 3,670 | 3,063 |
| | OUTLET | INH2O | -1.11 | -1.11 | -1.11 | -1.11 |
| BC 12 | RECOUP A SIDE (WB10) | AVG | 1,684 | 916 | 789 | 1,338 |
| | | LBS/MIN | 2,220 | 3,521 | 3,416 | 3,067 |
| | OUTLET | INH2O | -0.90 | -0.90 | -0.90 | -0.90 |
| BC 13 | COOLER VENT STACK | AVG | 905 | 344 | 352 | 552 |
| | | LBS/MIN | 7,180 | 11,829 | 10,565 | 10,931 |
| | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | -0.88 |
| | VENT STACK SEPARATION WALL | | YES | YES | YES | YES |
| | PELLET EXIT TEMP TOP-CENTER | DEGF | 628 | 183 | 198 | 322 |
| BC 17 | WINDBOX LEAKAGE | LBS/MIN | 142 | 131 | 123 | 142 |
| | GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 |
| BC 16 | O'BED LEAKAGE | LBS/MIN | (195) | (83) | (131) | (69) |
| | GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 |
| | TOTAL AIR IN | | 20,195 | 30,583 | 30,632 | 27,071 |
| | TOTAL AIR OUT | | 20,197 | 30,583 | 30,632 | 27,071 |

TABLE 11:
MINNTAC SECOND PARAMETRIC SERIES:
CURRENT COOLER - NO OVER BED WALL

2 OF 7

| | | | | 16/485/135/135 | 16/485/170/100 | 16/520/100/135 | 16/520/135/100 |
|-----------------------------------------|----------------------|---------|---------|----------------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | | LTPH | | 485.00 | 485.00 | 520 | 520 |
| PRODUCTION FACTOR (1-NET FURNACE LOSS) | | | | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | | LTPH | | 417.10 | 417.10 | 447.20 | 447.20 |
| GREENBALL MAGNETITE %WT | | | | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | 3.86 | 3.86 | 3.86 | 3.86 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | | %WT | | 16.00 | 16.00 | 16.00 | 16.00 |
| AVG PELLETT TEMP INTO COOLER | | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | | | |
| 3A FAN FLOW | | LBS/MIN | | 13,500 | 17,001 | 10,001 | 13,500 |
| G/S (THRU BED) | | LBS/LB | | 0.6615 | 0.8672 | 0.4275 | 0.6158 |
| INLET | | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | | IN.H2O | | -0.0956 | 0.0001 | -0.2154 | -0.1361 |
| U'BED | | IN.H2O | | 16.27 | 18.73 | 13.55 | 16.45 |
| KFACT | | | | 545 | 545 | 545 | 545 |
| BC 14 | KILN SECONDARY AIR | AVG | DEGF | 2,186 | 2,071 | 2,332 | 2,250 |
| | | | LBS/MIN | 5,267 | 6,006 | 4,075 | 4,767 |
| | | | G/S | 0.3382 | 0.3857 | 0.2441 | 0.2855 |
| BC 15 | FIRING HOOD AIR | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| | | | DEGF | 2,283 | 2,274 | 2,291 | 2,278 |
| | | | LBS/MIN | 2,597 | 2,867 | 2,301 | 2,535 |
| | | | G/S | 0.1668 | 0.1841 | 0.1378 | 0.1518 |
| | | | OUTLET | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 | WINDBOX LEAKAGE | | LBS/MIN | 3,199 | 3,497 | 2,863 | 3,219 |
| GAP HEIGHT | | | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL: | | | | | | | |
| LOCATION (BETWEEN WBOXES) | | | | NONE | NONE | NONE | NONE |
| GAP HEIGHT | | | INCHES | NA | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | | LBS/MIN | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | | |
| 3B FAN FLOW | | LBS/MIN | | 13,500 | 10,001 | 13,500 | 10,001 |
| G/S (THRU BED) | | LBS/MIN | | 0.8583 | 0.6342 | 0.7995 | 0.5906 |
| INLET | | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | | IN.H2O | | -0.2672 | -0.3923 | -0.2631 | -0.3833 |
| U'BED | | IN.H2O | | 11.25 | 8.3 | 13.3 | 9.91 |
| BC 11 | RECOUP B SIDE (WB 9) | AVG | DEGF | 1,516 | 1,287 | 1,992 | 1,738 |
| | | | LBS/MIN | 3,150 | 3,249 | 2,765 | 2,802 |
| | | | OUTLET | -1.11 | -1.11 | -1.11 | -1.11 |
| BC 12 | RECOUP A SIDE (WB10) | AVG | DEGF | 1,213 | 1,030 | 1,668 | 1,498 |
| | | | LBS/MIN | 2,981 | 2,855 | 2,618 | 2,490 |
| | | | OUTLET | -0.90 | -0.90 | -0.90 | -0.90 |
| BC 13 | COOLER VENT STACK | AVG | DEGF | 555 | 548 | 864 | 854 |
| | | | LBS/MIN | 9,785 | 8,642 | 8,824 | 7,740 |
| | | | OUTLET | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | | DEGF | 336 | 358 | 595 | 612 |
| BC 17 | WINDBOX LEAKAGE | | LBS/MIN | 135 | 125 | 151 | 141 |
| GAP HEIGHT | | | INCHES | 1 | 1 | 1 | 1 |
| BC 16 | O'BED LEAKAGE | | LBS/MIN | (113) | (240) | (99) | (192) |
| GAP HEIGHT | | | INCHES | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | | 27,113 | 27,241 | 23,599 | 23,692 |
| TOTAL AIR OUT | | | | 27,113 | 27,241 | 23,598 | 23,693 |

TABLE 11:
MINNTAC SECOND PARAMETRIC SERIES:
CURRENT COOLER - NO OVER BED WALL

| | | | | 16/520/170/170 | 22/450/100/170 | 22/450/135/135 | 22/450/170/100 | |
|-----------------------------------------|----------------------|---------|---------------------------|----------------|----------------|----------------|----------------|--------|
| GREEN BALL FEED RATE ON GRATE | | LTPH | | 520 | 450 | 450 | 450 | |
| PRODUCTION FACTOR (1-NET FURNACE LOSS) | | | | 0.86 | 0.86 | 0.86 | 0.86 | |
| PELLET FEED TO COOLER | | LTPH | | 447.20 | 387.00 | 387.00 | 387.00 | |
| GREENBALL MAGNETITE %WT | | | | 87.00 | 87.00 | 87.00 | 87.00 | |
| FE++ IN COOLER FEED | | | | 3.86 | 5.31 | 5.31 | 5.31 | |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | | %WT | | 16.00 | 22.00 | 22.00 | 22.00 | |
| AVG PELLET TEMP INTO COOLER | | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 | |
| PRIMARY COOLING ZONE | | | | | | | | |
| 3A FAN FLOW | | LBS/MIN | | 17,001 | 10,001 | 13,500 | 17,001 | |
| G/S (THRU BED) | | LBS/LB | | 0.8044 | 0.4942 | 0.7144 | 0.9367 | |
| INLET | | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 | |
| O'BED | | IN.H2O | | 0.1461 | -0.1804 | -0.1034 | -0.0134 | |
| U'BED | | IN.H2O | | 19.65 | 13.57 | 16.03 | 18.38 | |
| KFACT | | | | 545 | 545 | 545 | 545 | |
| BC 14 | KILN SECONDARY AIR | AVG | DEGF | 2,032 | 2,321 | 2,196 | 2,065 | |
| | | | LBS/MIN | 7,193 | 4,486 | 5,182 | 5,919 | |
| | | | G/S | 0.4308 | 0.3105 | 0.3587 | 0.4097 | |
| OUTLET | | INH2O | | -0.40 | -0.40 | -0.40 | -0.40 | |
| BC 15 | FIRING HOOD AIR | AVG | DEGF | 2,232 | 2,310 | 2,302 | 2,290 | |
| | | | LBS/MIN | 3,075 | 2,358 | 2,557 | 2,833 | |
| | | | G/S | 0.1842 | 0.1632 | 0.1770 | 0.1961 | |
| OUTLET | | INH2O | | -0.73 | -0.73 | -0.73 | -0.73 | |
| BC 18 | WINDBOX LEAKAGE | | LBS/MIN | 3,571 | 2,860 | 3,178 | 3,468 | |
| | | | GAP HEIGHT | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| | | | WINDBOX DAMPER POSITION | | CLOSED | CLOSED | CLOSED | CLOSED |
| | | | LEAK GAP ACROSS DAMPER | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| | | | OVERBED DIVIDING WALL: | | | | | |
| | | | LOCATION (BETWEEN WBOXES) | | NONE | NONE | NONE | NONE |
| | | | GAP HEIGHT | INCHES | NA | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | LBS/MIN | | NA | NA | NA | NA | |
| SECONDARY COOLING ZONE | | | | | | | | |
| 3B FAN FLOW | | LBS/MIN | | 17,001 | 17,001 | 13,500 | 10,001 | |
| G/S (THRU BED) | | LBS/MIN | | 1.0103 | 1.1671 | 0.9253 | 0.6838 | |
| INLET | | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 | |
| O'BED | | IN.H2O | | -0.062 | -0.1825 | -0.2921 | -0.4117 | |
| U'BED | | IN.H2O | | 12.55 | 13.53 | 10.73 | 7.915 | |
| BC 11 | RECOUP B SIDE (WB 9) | AVG | DEGF | 1,188 | 1,738 | 1,442 | 1,207 | |
| | | | LBS/MIN | 3,894 | 3,063 | 3,173 | 3,292 | |
| OUTLET | | INH2O | | -1.11 | -1.11 | -1.11 | -1.11 | |
| BC 12 | RECOUP A SIDE (WB10) | AVG | DEGF | 894 | 1,266 | 1,123 | 940 | |
| | | | LBS/MIN | 3,826 | 3,063 | 3,005 | 2,891 | |
| OUTLET | | INH2O | | -0.90 | -0.90 | -0.90 | -0.90 | |
| BC 13 | COOLER VENT STACK | AVG | DEGF | 375 | 479 | 485 | 480 | |
| | | | LBS/MIN | 12,387 | 11,089 | 9,893 | 8,740 | |
| | | | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES | |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | | 210 | 262 | 277 | 298 | |
| BC 17 | WINDBOX LEAKAGE | | LBS/MIN | 132 | 138 | 131 | 121 | |
| | | | GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 |
| BC 16 | O'BED LEAKAGE | | LBS/MIN | (76) | (76) | (119) | (263) | |
| | | | GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | | 34,077 | 27,077 | 27,119 | 27,264 | |
| TOTAL AIR OUT | | | | 34,078 | 27,077 | 27,119 | 27,262 | |

TABLE 11:

MINNTAC SECOND PARAMETRIC SERIES:
CURRENT COOLER - NO OVER BED WALL

| | | | | 22/485/100/135 | 22/485/135/100 | 22/485/170/170 | 22/520/100/100 |
|-----------------------------------------|----------------------|---------|---------|----------------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | | LTPH | | 485 | 485 | 485 | 520 |
| PRODUCTION FACTOR (1-NET FURNACE LOSS) | | | | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | | LTPH | | 417.10 | 417.10 | 417.10 | 447.20 |
| GREENBALL MAGNETITE %WT | | | | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | 5.31 | 5.31 | 5.31 | 5.31 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | | %WT | | 22.00 | 22.00 | 22.00 | 22.00 |
| AVG PELLETT TEMP INTO COOLER | | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | | | |
| 3A FAN FLOW | | LBS/MIN | | 10,001 | 13,500 | 17,001 | 10,001 |
| G/S (THRU BED) | | LBS/LB | | 0.4593 | 0.6613 | 0.8641 | 0.4288 |
| INLET | | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | | IN.H2O | | -0.2214 | -0.143 | 0.1317 | -0.2649 |
| U'BED | | IN.H2O | | 13.4 | 16.27 | 19.34 | 13.28 |
| KFACT | | | | 545 | 545 | 545 | 545 |
| BC 14 | KILN SECONDARY AIR | AVG | DEGF | 2,367 | 2,270 | 2,024 | 2,393 |
| | | | LBS/MIN | 3,981 | 4,687 | 7,103 | 3,412 |
| | | | G/S | 0.2556 | 0.3010 | 0.4562 | 0.2044 |
| | | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| BC 15 | FIRING HOOD AIR | | DEGF | 2,308 | 2,295 | 2,289 | 2,304 |
| | | | LBS/MIN | 2,280 | 2,524 | 3,039 | 2,199 |
| | | | G/S | 0.1464 | 0.1621 | 0.1952 | 0.1317 |
| | | OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 | WINDBOX LEAKAGE | | LBS/MIN | 2,848 | 3,203 | 3,544 | 2,842 |
| GAP HEIGHT | | | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL: | | | | | | | |
| LOCATION (BETWEEN WBOXES) | | | | NONE | NONE | NONE | NONE |
| GAP HEIGHT | | | INCHES | NA | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | | LBS/MIN | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | | |
| 3B FAN FLOW | | LBS/MIN | | 13,500 | 10,001 | 17,001 | 10,001 |
| G/S (THRU BED) | | LBS/MIN | | 0.8575 | 0.6335 | 1.0834 | 0.5896 |
| INLET | | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | | IN.H2O | | -0.2785 | -0.3997 | -0.0947 | -0.4019 |
| U'BED | | IN.H2O | | 12.83 | 9.47 | 12.08 | 11.5 |
| BC 11 | RECOUP B SIDE (WB 9) | AVG | DEGF | 1,979 | 1,690 | 1,109 | 2,161 |
| | | | LBS/MIN | 2,751 | 2,809 | 3,939 | 2,470 |
| | | OUTLET | INH2O | -1.11 | -1.11 | -1.11 | -1.11 |
| BC 12 | RECOUP A SIDE (WB10) | AVG | DEGF | 1,627 | 1,431 | 814 | 1,946 |
| | | | LBS/MIN | 2,617 | 2,495 | 3,871 | 2,190 |
| | | OUTLET | INH2O | -0.90 | -0.90 | -0.90 | -0.90 |
| BC 13 | COOLER VENT STACK | AVG | DEGF | 781 | 774 | 327 | 1,192 |
| | | | LBS/MIN | 8,977 | 7,833 | 12,453 | 6,893 |
| | | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | | DEGF | 507 | 529 | 176 | 919 |
| BC 17 | WINDBOX LEAKAGE | | LBS/MIN | 147 | 136 | 130 | 157 |
| GAP HEIGHT | | | INCHES | 1 | 1 | 1 | 1 |
| BC 16 | O'BED LEAKAGE | | LBS/MIN | (101) | (187) | (80) | (162) |
| GAP HEIGHT | | | INCHES | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | | 23,601 | 23,687 | 34,081 | 20,164 |
| TOTAL AIR OUT | | | | 23,600 | 23,688 | 34,079 | 20,162 |

TABLE 11:
MINNTAC SECOND PARAMETRIC SERIES:
CURRENT COOLER - NO OVER BED WALL

| | | | 22/520/135/170 | 22/520/170/135 | 28/450/100/135 | 28/450/135/100 | | |
|-----------------------------------------|-----------------------------------|---------|----------------|----------------|----------------|----------------|--------|--------|
| GREEN BALL FEED RATE ON GRATE | LTPH | | 520 | 520 | 450 | 450 | | |
| PRODUCTION FACTOR (1-NET FURNACE LOSS) | | | 0.86 | 0.86 | 0.86 | 0.86 | | |
| PELLET FEED TO COOLER | LTPH | | 447.20 | 447.20 | 387.00 | 387.00 | | |
| GREENBALL MAGNETITE %WT | | | 87.00 | 87.00 | 87.00 | 87.00 | | |
| FE++ IN COOLER FEED | | | 5.31 | 5.31 | 6.75 | 6.75 | | |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | | 22.00 | 22.00 | 28.00 | 28.00 | | |
| AVG PELLETT TEMP INTO COOLER | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 | | |
| PRIMARY COOLING ZONE | | | | | | | | |
| | 3A FAN FLOW | LBS/MIN | 13,500 | 17,001 | 10,001 | 13,500 | | |
| | G/S (THRU BED) | LBS/LB | 0.6123 | 0.8039 | 0.4962 | 0.7142 | | |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 | | |
| | O'BED | IN.H2O | -0.0189 | 0.0911 | -0.2281 | -0.1503 | | |
| | U'BED | IN.H2O | 17.14 | 19.73 | 13.22 | 16.04 | | |
| | KFACT | | 545 | 545 | 545 | 545 | | |
| BC 14 | KILN SECONDARY AIR | AVG | DEGF | 2,232 | 2,117 | 2,398 | 2,283 | |
| | | | LBS/MIN | 5,906 | 6,655 | 3,882 | 4,607 | |
| | | | G/S | LBS/MIN | 0.3537 | 0.3986 | 0.2687 | 0.3188 |
| | | | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| BC 15 | FIRING HOOD AIR | AVG | DEGF | 2,292 | 2,284 | 2,329 | 2,314 | |
| | | | LBS/MIN | 2,733 | 3,002 | 2,254 | 2,499 | |
| | | | G/S | LBS/LB | 0.1637 | 0.1798 | 0.1560 | 0.1730 |
| | | | OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 | WINDBOX LEAKAGE | | LBS/MIN | 3,277 | 3,579 | 2,831 | 3,182 | |
| | GAP HEIGHT | | INCHES | 3.62 | 3.62 | 3.62 | 3.62 | |
| | WINDBOX DAMPER POSITION | | | CLOSED | CLOSED | CLOSED | CLOSED | |
| | LEAK GAP ACROSS DAMPER | | INCHES | 1.67 | 1.67 | 1.67 | 1.67 | |
| | OVERBED DIVIDING WALL: | | | | | | | |
| | LOCATION (BETWEEN WBOXES) | | | NONE | NONE | NONE | NONE | |
| | GAP HEIGHT | | INCHES | NA | NA | NA | NA | |
| | FLOW (- = 3A TO 3B; + = 3B TO 3A) | | LBS/MIN | NA | NA | NA | NA | |
| SECONDARY COOLING ZONE | | | | | | | | |
| | 3B FAN FLOW | LBS/MIN | 17,001 | 13,500 | 13,500 | 10,001 | | |
| | G/S (THRU BED) | LBS/MIN | 1.0099 | 0.8007 | 0.9246 | 0.6831 | | |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 | | |
| | O'BED | IN.H2O | -0.07 | -0.2054 | -0.2985 | -0.4183 | | |
| | U'BED | IN.H2O | 13.89 | 10.91 | 12.27 | 9 | | |
| BC 11 | RECOUP B SIDE (WB 9) | AVG | DEGF | 1,583 | 1,331 | 1,946 | 1,624 | |
| | | | LBS/MIN | 3,411 | 3,506 | 2,745 | 2,825 | |
| | | | OUTLET | INH2O | -1.11 | -1.11 | -1.11 | |
| BC 12 | RECOUP A SIDE (WB10) | AVG | DEGF | 1,207 | 1,056 | 1,566 | 1,343 | |
| | | | LBS/MIN | 3,404 | 3,301 | 2,618 | 2,508 | |
| | | | OUTLET | INH2O | -0.90 | -0.90 | -0.90 | |
| BC 13 | COOLER VENT STACK | AVG | DEGF | 499 | 504 | 691 | 689 | |
| | | | LBS/MIN | 11,699 | 10,437 | 9,131 | 7,946 | |
| | | | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | |
| | VENT STACK SEPARATION WALL | | | YES | YES | YES | YES | |
| | PELLET EXIT TEMP TOP-CENTER | | DEGF | 288 | 307 | 417 | 446 | |
| BC 17 | WINDBOX LEAKAGE | | LBS/MIN | 140 | 133 | 142 | 131 | |
| | GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 | |
| BC 16 | O'BED LEAKAGE | | LBS/MIN | (68) | (111) | (105) | (198) | |
| | GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 | |
| | TOTAL AIR IN | | | 30,569 | 30,612 | 23,606 | 23,698 | |
| | TOTAL AIR OUT | | | 30,570 | 30,612 | 23,604 | 23,698 | |

TABLE 11:
MINNTAC SECOND PARAMETRIC SERIES:
CURRENT COOLER - NO OVER BED WALL

| | | | | 28/450/170/170 | 28/485/100/100 | 28/485/135/170 | 28/485/170/135 |
|-----------------------------------------|----------------------|-----------------------------------|---------|----------------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | | LTPH | | 450 | 485 | 485 | 485 |
| PRODUCTION FACTOR (1-NET FURNACE LOSS) | | | | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | | LTPH | | 387.00 | 417.10 | 417.10 | 417.10 |
| GREENBALL MAGNETITE %WT | | | | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | 6.75 | 6.75 | 6.75 | 6.75 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | | %WT | | 28.00 | 28.00 | 28.00 | 28.00 |
| AVG PELLETT TEMP INTO COOLER | | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | | | |
| 3A FAN FLOW | | LBS/MIN | | 17,001 | 10,001 | 13,500 | 17,001 |
| G/S (THRU BED) | | LBS/LB | | 0.9335 | 0.4604 | 0.6578 | 0.8636 |
| INLET | | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | | IN.H2O | | 0.1149 | -0.2681 | -0.0291 | 0.0781 |
| U'BED | | IN.H2O | | 18.95 | 13.18 | 16.92 | 19.41 |
| KFACT | | | | 545 | 545 | 545 | 545 |
| BC 14 | KILN SECONDARY AIR | AVG | DEGF | 2,004 | 2,428 | 2,242 | 2,112 |
| | | | LBS/MIN | 7,015 | 3,350 | 5,812 | 6,569 |
| | | G/S | LBS/MIN | 0.4855 | 0.2151 | 0.3732 | 0.4218 |
| BC 15 | FIRING HOOD AIR | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| | | | DEGF | 2,305 | 2,321 | 2,309 | 2,299 |
| | | | LBS/MIN | 2,999 | 2,184 | 2,704 | 2,969 |
| | | G/S | LBS/LB | 0.2076 | 0.1403 | 0.1737 | 0.1907 |
| | | OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 | WINDBOX LEAKAGE | | LBS/MIN | 3,514 | 2,831 | 3,257 | 3,554 |
| | | | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| | | WINDBOX DAMPER POSITION | | CLOSED | CLOSED | CLOSED | CLOSED |
| | | LEAK GAP ACROSS DAMPER | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| | | OVERBED DIVIDING WALL: | | | | | |
| | | LOCATION (BETWEEN WBOXES) | | NONE | NONE | NONE | NONE |
| | | GAP HEIGHT | INCHES | NA | NA | NA | NA |
| | | FLOW (- = 3A TO 3B; + = 3B TO 3A) | LBS/MIN | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | | |
| 3B FAN FLOW | | LBS/MIN | | 17,001 | 10,001 | 17,001 | 13,500 |
| G/S (THRU BED) | | LBS/MIN | | 1.1679 | 0.6325 | 1.0830 | 0.8587 |
| INLET | | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | | IN.H2O | | -0.1289 | -0.4116 | -0.1012 | -0.2324 |
| U'BED | | IN.H2O | | 11.6 | 11.06 | 13.32 | 10.45 |
| BC 11 | RECOUP B SIDE (WB 9) | AVG | DEGF | 1,016 | 2,155 | 1,514 | 1,253 |
| | | | LBS/MIN | 4,002 | 2,458 | 3,427 | 3,542 |
| | | OUTLET | INH2O | -1.11 | -1.11 | -1.11 | -1.11 |
| BC 12 | RECOUP A SIDE (WB10) | AVG | DEGF | 725 | 1,911 | 1,124 | 972 |
| | | | LBS/MIN | 3,928 | 2,186 | 3,429 | 3,331 |
| | | OUTLET | INH2O | -0.90 | -0.90 | -0.90 | -0.90 |
| BC 13 | COOLER VENT STACK | AVG | DEGF | 283 | 1,104 | 437 | 445 |
| | | | LBS/MIN | 12,502 | 7,005 | 11,808 | 10,526 |
| | | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | -0.88 |
| | | VENT STACK SEPARATION WALL | | YES | YES | YES | YES |
| | | PELLET EXIT TEMP TOP-CENTER | DEGF | 147 | 813 | 239 | 259 |
| BC 17 | WINDBOX LEAKAGE | | LBS/MIN | 127 | 152 | 136 | 129 |
| | | GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 |
| BC 16 | O'BED LEAKAGE | | LBS/MIN | (85) | (165) | (73) | (118) |
| | | | INCHES | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | | 34,086 | 20,166 | 30,573 | 30,618 |
| TOTAL AIR OUT | | | | 34,087 | 20,166 | 30,573 | 30,619 |

TABLE 11:
MINNTAC SECOND PARAMETRIC SERIES:
CURRENT COOLER - NO OVER BED WALL

| | | | | 28/520/100/170 | 28/520/135/135 | 28/520/170/100 |
|-----------------------------------------|----------------------|---------|---------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | | LTPH | | 520 | 520 | 520 |
| PRODUCTION FACTOR (1-NET FURNACE LOSS) | | | | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | | LTPH | | 447.20 | 447.20 | 447.20 |
| GREENBALL MAGNETITE %WT | | | | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | | 6.75 | 6.75 | 6.75 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | | %WT | | 28.00 | 28.00 | 28.00 |
| AVG PELLET TEMP INTO COOLER | | DEGF | | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | | |
| 3A FAN FLOW | | LBS/MIN | | 10,001 | 13,500 | 17,001 |
| G/S (THRU BED) | | LBS/LB | | 0.4224 | 0.6123 | 0.8034 |
| INLET | | DEGF | | 39.2 | 39.2 | 39.2 |
| O'BED | | IN.H2O | | -0.1486 | -0.068 | 0.0344 |
| U'BED | | IN.H2O | | 14.53 | 17.12 | 19.8 |
| KFACT | | | | 545 | 545 | 545 |
| BC 14 | KILN SECONDARY AIR | AVG | DEGF | 2,403 | 2,305 | 2,196 |
| | | | LBS/MIN | 4,738 | 5,382 | 6,107 |
| | | | G/S | 0.2838 | 0.3224 | 0.3658 |
| | | OUTLET | INH2O | -0.40 | -0.40 | -0.40 |
| BC 15 | FIRING HOOD AIR | | DEGF | 2,314 | 2,304 | 2,292 |
| | | | LBS/MIN | 2,433 | 2,637 | 2,930 |
| | | | G/S | 0.1457 | 0.1579 | 0.1755 |
| | | OUTLET | INH2O | -0.73 | -0.73 | -0.73 |
| BC 18 | WINDBOX LEAKAGE | | LBS/MIN | 2,948 | 3,277 | 3,587 |
| GAP HEIGHT | | | INCHES | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | | INCHES | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL: | | | | | | |
| LOCATION (BETWEEN WBOXES) | | | | NONE | NONE | NONE |
| GAP HEIGHT | | | INCHES | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | | LBS/MIN | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | |
| 3B FAN FLOW | | LBS/MIN | | 17,001 | 13,500 | 10,001 |
| G/S (THRU BED) | | LBS/MIN | | 1.0093 | 0.8001 | 0.5911 |
| INLET | | DEGF | | 39.2 | 39.2 | 39.2 |
| O'BED | | IN.H2O | | -0.0958 | -0.2112 | -0.3486 |
| U'BED | | IN.H2O | | 15.32 | 12.29 | 9.07 |
| BC 11 | RECOUP B SIDE (WB 9) | AVG | DEGF | 1,999 | 1,742 | 1,496 |
| | | | LBS/MIN | 3,002 | 3,065 | 3,143 |
| | | OUTLET | INH2O | -1.11 | -1.11 | -1.11 |
| BC 12 | RECOUP A SIDE (WB10) | AVG | DEGF | 1,547 | 1,430 | 1,232 |
| | | | LBS/MIN | 3,012 | 2,921 | 2,789 |
| | | OUTLET | INH2O | -0.90 | -0.90 | -0.90 |
| BC 13 | COOLER VENT STACK | AVG | DEGF | 690 | 689 | 679 |
| | | | LBS/MIN | 10,781 | 9,674 | 8,515 |
| | | OUTLET | INH2O | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | | DEGF | 417 | 437 | 460 |
| BC 17 | WINDBOX LEAKAGE | | LBS/MIN | 150 | 143 | 132 |
| GAP HEIGHT | | | INCHES | 1 | 1 | 1 |
| BC 16 | O'BED LEAKAGE | | LBS/MIN | (62) | (100) | (203) |
| GAP HEIGHT | | | INCHES | 1 | 1 | 1 |
| TOTAL AIR IN | | | | 27,063 | 27,100 | 27,205 |
| TOTAL AIR OUT | | | | 27,063 | 27,099 | 27,204 |

TABLE 12:
MINNTAC THIRD PARAMETRIC SERIES:
COOLER WITH OVER BED DIVIDING WALL
BETWEEN WIND BOXES 6 AND 7

| | | | 16/450/100/100 | 16/450/135/170 | 16/450/170/135 | 16/485/100/170 |
|-----------------------------------|---------|---------|----------------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | LTPH | | 450.00 | 450.00 | 450.00 | 485.00 |
| PRODUCTION FACTOR | | | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | | 387.00 | 387.00 | 387.00 | 417.10 |
| GREENBALL MAGNETITE %WT | | | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | 3.86 | 3.86 | 3.86 | 3.86 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | | 16.00 | 16.00 | 16.00 | 16.00 |
| AVG PELLETT TEMP INTO COOLER | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | | |
| 3A FAN FLOW | LBS/MIN | | 10,000 | 13,500 | 17,001 | 10,001 |
| G/S (THRU BED) | LBS/LB | | 0.5008 | 0.7149 | 0.9375 | 0.4573 |
| INLET | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | | -0.2781 | -0.1039 | 0.059 | -0.2297 |
| U'BED | IN.H2O | | 12.550 | 16.01 | 18.3 | 13.81 |
| KFACT | | | 545 | 545 | 545 | 545 |
| BC 14 KILN SECONDARY AIR | AVG | DEGF | 2,326 | 2,142 | 1,947 | 2,321 |
| | | LBS/MIN | 3,281 | 5,239 | 6,669 | 3,905 |
| | G/S | LBS/MIN | 0.2271 | 0.3626 | 0.4616 | 0.2508 |
| | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| BC 15 FIRING HOOD AIR | | DEGF | 2,299 | 2,287 | 2,278 | 2,291 |
| | | LBS/MIN | 2,162 | 2,579 | 2,925 | 2,282 |
| | G/S | LBS/LB | 0.1496 | 0.1785 | 0.2025 | 0.1466 |
| | OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 WINDBOX LEAKAGE | | LBS/MIN | 2,765 | 3,171 | 3,456 | 2,880 |
| GAP HEIGHT | | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | | | |
| LOCATION (BETWEEN WBOXES) | | | NONE | NONE | NONE | NONE |
| GAP HEIGHT | | INCHES | NA | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | LBS/MIN | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | |
| 3B FAN FLOW | LBS/MIN | | 10,000 | 17,001 | 13,500 | 17,001 |
| G/S (THRU BED) | LBS/MIN | | 0.6823 | 1.1676 | 0.9259 | 1.0826 |
| INLET | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | | -0.4520 | -0.1021 | -0.3067 | -0.0485 |
| U'BED | IN.H2O | | 10.010 | 12.36 | 9.65 | 14.16 |
| BC 11 RECOUP B SIDE (WB 9) | AVG | DEGF | 1,935 | 1,326 | 1,028 | 1,844 |
| | | LBS/MIN | 2,497 | 3,658 | 3,630 | 3,247 |
| | OUTLET | INH2O | -1.11 | -1.11 | -1.11 | -1.11 |
| BC 12 RECOUP A SIDE (WB10) | AVG | DEGF | 1,673 | 977 | 770 | 1,455 |
| | | LBS/MIN | 2,207 | 3,621 | 3,383 | 3,214 |
| | OUTLET | INH2O | -0.90 | -0.90 | -0.90 | -0.90 |
| BC 13 COOLER VENT STACK | AVG | DEGF | 901 | 363 | 347 | 585 |
| | | LBS/MIN | 7,143 | 12,180 | 10,446 | 11,396 |
| | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | 628 | 183 | 199 | 322 |
| BC 17 WINDBOX LEAKAGE | | LBS/MIN | 141 | 131 | 123 | 142 |
| GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 |
| BC 16 O'BED LEAKAGE | | LBS/MIN | (196) | (79) | (133) | (65) |
| GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | 20,196 | 30,579 | 30,634 | 27,067 |
| TOTAL AIR OUT | | | 20,195 | 30,578 | 30,633 | 27,066 |

TABLE 12:
MINNTAC THIRD PARAMETRIC SERIES:
COOLER WITH OVER BED DIVIDING WALL
BETWEEN WIND BOXES 6 AND 7

2 OF 7

| | | 16/485/135/135 | 16/485/170/100 | 16/520/100/135 | 16/520/135/100 |
|-----------------------------------|---------|----------------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | LTPH | 485.00 | 485.00 | 520.00 | 520.00 |
| PRODUCTION FACTOR | | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | 417.12 | 417.12 | 447.20 | 447.20 |
| GREENBALL MAGNETITE %WT | | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | 3.86 | 3.86 | 3.86 | 3.86 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | 16.00 | 16.00 | 16.00 | 16.00 |
| AVG PELLETT TEMP INTO COOLER | DEGF | 2,250 | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | |
| 3A FAN FLOW | LBS/MIN | 13,500 | 17,001 | 10,001 | 13,500 |
| G/S (THRU BED) | LBS/LB | 0.6616 | 0.8671 | 0.4275 | 0.6159 |
| INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | -0.1087 | 0.0583 | -0.2492 | -0.1204 |
| U'BED | IN.H2O | 16.27 | 18.78 | 13.57 | 16.46 |
| KFACT | | 545 | 545 | 545 | 545 |
| BC 14 KILN SECONDARY AIR | AVG | 2,200 | 2,028 | 2,343 | 2,243 |
| | LBS/MIN | 5,087 | 6,540 | 3,649 | 4,931 |
| | G/S | 0.3267 | 0.4199 | 0.2186 | 0.2953 |
| OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| BC 15 FIRING HOOD AIR | DEGF | 2,284 | 2,275 | 2,288 | 2,280 |
| | LBS/MIN | 2,568 | 2,924 | 2,241 | 2,557 |
| | G/S | 0.1649 | 0.1878 | 0.1342 | 0.1532 |
| OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 WINDBOX LEAKAGE | LBS/MIN | 3,198 | 3,498 | 2,863 | 3,218 |
| GAP HEIGHT | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | | |
| LOCATION (BETWEEN WBOXES) | | NONE | NONE | NONE | NONE |
| GAP HEIGHT | INCHES | NA | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | LBS/MIN | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | |
| 3B FAN FLOW | LBS/MIN | 13,500 | 10,001 | 13,500 | 10,001 |
| G/S (THRU BED) | LBS/MIN | 0.8583 | 0.6342 | 0.7995 | 0.5906 |
| INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | -0.2442 | -0.4395 | -0.2026 | -0.4018 |
| U'BED | IN.H2O | 11.27 | 8.26 | 13.35 | 9.89 |
| BC 11 RECOUP B SIDE (WB 9) | AVG | 1,534 | 1,225 | 2,019 | 1,721 |
| | LBS/MIN | 3,195 | 3,124 | 2,880 | 2,758 |
| | OUTLET | -1.11 | -1.11 | -1.11 | -1.11 |
| BC 12 RECOUP A SIDE (WB10) | AVG | 1,233 | 977 | 1,731 | 1,478 |
| | LBS/MIN | 3,022 | 2,747 | 2,719 | 2,453 |
| | OUTLET | -0.90 | -0.90 | -0.90 | -0.90 |
| BC 13 COOLER VENT STACK | AVG | 563 | 528 | 888 | 847 |
| | LBS/MIN | 9,907 | 8,299 | 9,092 | 7,623 |
| | OUTLET | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | DEGF | 336 | 356 | 595 | 612 |
| BC 17 WINDBOX LEAKAGE | LBS/MIN | 135 | 125 | 152 | 141 |
| GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 |
| BC 16 O'BED LEAKAGE | LBS/MIN | (111) | (255) | (94) | (182) |
| GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | 27,111 | 27,256 | 23,595 | 23,682 |
| TOTAL AIR OUT | | 27,111 | 27,255 | 23,595 | 23,681 |

TABLE 12: 3 OF 7
 MINNTAC THIRD PARAMETRIC SERIES:
 COOLER WITH OVER BED DIVIDING WALL
 BETWEEN WIND BOXES 6 AND 7

| | | 16/520/170/170 | 22/450/100/170 | 22/450/135/135 | 22/450/170/100 | | | |
|----------------------------------|-----------------------------------|----------------|----------------|----------------|----------------|---------|--------|--------|
| GREEN BALL FEED RATE ON GRATE | LTPH | 520.00 | 450.00 | 450.00 | 450.00 | | | |
| PRODUCTION FACTOR | | 0.86 | 0.86 | 0.86 | 0.86 | | | |
| PELLET FEED TO COOLER | LTPH | 447.20 | 387.00 | 387.00 | 387.00 | | | |
| GREENBALL MAGNETITE %WT | | 87.00 | 87.00 | 87.00 | 87.00 | | | |
| FE++ IN COOLER FEED | | 3.86 | 5.31 | 5.31 | 5.31 | | | |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | 16.00 | 22.00 | 22.00 | 22.00 | | | |
| AVG PELLETT TEMP INTO COOLER | DEGF | 2,250 | 2,250 | 2,250 | 2,250 | | | |
| PRIMARY COOLING ZONE | | | | | | | | |
| | 3A FAN FLOW | LBS/MIN | 17,001 | 10,001 | 13,500 | 17,001 | | |
| | G/S (THRU BED) | LBS/LB | 0.8046 | 0.4942 | 0.7145 | 0.9366 | | |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 | | |
| | O'BED | IN.H2O | 0.1085 | -0.2344 | -0.1129 | 0.0505 | | |
| | U'BED | IN.H2O | 19.65 | 13.59 | 16.03 | 18.41 | | |
| | KFACT | | 545 | 545 | 545 | 545 | | |
| BC 14 | KILN SECONDARY AIR | AVG | DEGF | 2,058 | 2,352 | 2,206 | 2,010 | |
| | | | LBS/MIN | 6,870 | 3,830 | 5,045 | 6,509 | |
| | | | G/S | LBS/MIN | 0.4115 | 0.2651 | 0.3492 | 0.4505 |
| | | | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| BC 15 | FIRING HOOD AIR | | DEGF | 2,272 | 2,312 | 2,302 | 2,292 | |
| | | | LBS/MIN | 3,030 | 2,260 | 2,547 | 2,895 | |
| | | | G/S | LBS/LB | 0.1815 | 0.1564 | 0.1763 | 0.2004 |
| | | | OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 | WINDBOX LEAKAGE | | LBS/MIN | 3,568 | 2,860 | 3,177 | 3,489 | |
| | GAP HEIGHT | | INCHES | 3.62 | 3.62 | 3.62 | 3.62 | |
| | WINDBOX DAMPER POSITION | | | CLOSED | CLOSED | CLOSED | CLOSED | |
| | LEAK GAP ACROSS DAMPER | | INCHES | 1.67 | 1.67 | 1.67 | 1.67 | |
| | OVERBED DIVIDING WALL | | | | | | | |
| | LOCATION (BETWEEN WBOXES) | | | NONE | NONE | NONE | NONE | |
| | GAP HEIGHT | | INCHES | NA | NA | NA | NA | |
| | FLOW (- = 3A TO 3B; + = 3B TO 3A) | | LBS/MIN | NA | NA | NA | NA | |
| SECONDARY COOLING ZONE | | | | | | | | |
| | 3B FAN FLOW | LBS/MIN | 17,001 | 17,001 | 13,500 | 10,001 | | |
| | G/S (THRU BED) | LBS/MIN | 1.0103 | 1.1671 | 0.9253 | 0.6838 | | |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 | | |
| | O'BED | IN.H2O | -0.0197 | -0.0825 | -0.2762 | -0.4618 | | |
| | U'BED | IN.H2O | 12.59 | 13.6 | 10.76 | 7.87 | | |
| BC 11 | RECOUP B SIDE (WB 9) | AVG | DEGF | 1,218 | 1,801 | 1,455 | 1,135 | |
| | | | LBS/MIN | 3,969 | 3,232 | 3,204 | 3,159 | |
| | | | OUTLET | INH2O | -1.11 | -1.11 | -1.11 | |
| BC 12 | RECOUP A SIDE (WB10) | AVG | DEGF | 922 | 1,384 | 1,138 | 881 | |
| | | | LBS/MIN | 3,895 | 3,215 | 3,034 | 2,773 | |
| | | | OUTLET | INH2O | -0.90 | -0.90 | -0.90 | |
| BC 13 | COOLER VENT STACK | AVG | DEGF | 384 | 511 | 491 | 459 | |
| | | | LBS/MIN | 12,610 | 11,535 | 9,982 | 8,352 | |
| | | | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | |
| | VENT STACK SEPARATION WALL | | | YES | YES | YES | YES | |
| | PELLET EXIT TEMP TOP-CENTER | | DEGF | 208 | 262 | 277 | 298 | |
| BC 17 | WINDBOX LEAKAGE | | LBS/MIN | 133 | 138 | 131 | 121 | |
| | GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 | |
| BC 16 | O'BED LEAKAGE | | LBS/MIN | (73) | (70) | (118) | (276) | |
| | GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 | |
| | TOTAL AIR IN | | | 34,074 | 27,071 | 27,118 | 27,277 | |
| | TOTAL AIR OUT | | | 34,074 | 27,070 | 27,119 | 27,278 | |

TABLE 12:
MINNTAC THIRD PARAMETRIC SERIES:
COOLER WITH OVER BED DIVIDING WALL
BETWEEN WIND BOXES 6 AND 7

| | | | 22/485/100/135 | 22/485/135/100 | 22/485/170/170 | 22/520/100/100 |
|-----------------------------------|---------|---------|----------------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | LTPH | | 485.00 | 485.00 | 485.00 | 520.00 |
| PRODUCTION FACTOR | | | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | | 417.10 | 417.10 | 417.10 | 447.20 |
| GREENBALL MAGNETITE %WT | | | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | 5.31 | 5.31 | 5.31 | 5.31 |
| FE3O4 IN FEED (FE3O4=FE++/1.2412) | %WT | | 22.00 | 22.00 | 22.00 | 22.00 |
| AVG PELLETT TEMP INTO COOLER | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | | |
| 3A FAN FLOW | LBS/MIN | | 10,001 | 13,500 | 17,001 | 10,001 |
| G/S (THRU BED) | LBS/LB | | 0.4594 | 0.6614 | 0.8642 | 0.4289 |
| INLET | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | | -0.2526 | -0.1228 | 0.1005 | -0.2684 |
| U'BED | IN.H2O | | 13.41 | 16.28 | 19.33 | 13.29 |
| KFACT | | | 545 | 545 | 545 | 545 |
| BC 14 KILN SECONDARY AIR | AVG | DEGF | 2,379 | 2,258 | 2,049 | 2,394 |
| | | LBS/MIN | 3,584 | 4,898 | 6,831 | 3,363 |
| | | G/S | 0.2302 | 0.3145 | 0.4387 | 0.2014 |
| | OUTLET | IN.H2O | -0.40 | -0.40 | -0.40 | -0.40 |
| BC 15 FIRING HOOD AIR | | DEGF | 2,308 | 2,296 | 2,288 | 2,303 |
| | | LBS/MIN | 2,224 | 2,541 | 3,002 | 2,194 |
| | | G/S | 0.1428 | 0.1632 | 0.1928 | 0.1314 |
| | OUTLET | IN.H2O | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 WINDBOX LEAKAGE | | LBS/MIN | 2,847 | 3,202 | 3,543 | 2,839 |
| GAP HEIGHT | | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | | | |
| LOCATION (BETWEEN WBOXES) | | | NONE | NONE | NONE | NONE |
| GAP HEIGHT | | INCHES | NA | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | LBS/MIN | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | |
| 3B FAN FLOW | LBS/MIN | | 13,500 | 10,001 | 17,001 | 10,001 |
| G/S (THRU BED) | LBS/MIN | | 0.8607 | 0.6335 | 1.0834 | 0.5896 |
| INLET | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | | -0.2228 | -0.4211 | -0.05982 | -0.3958 |
| U'BED | IN.H2O | | 12.88 | 9.45 | 12.11 | 11.5 |
| BC 11 RECOUP B SIDE (WB 9) | AVG | DEGF | 2,007 | 1,666 | 1,134 | 2,165 |
| | | LBS/MIN | 2,855 | 2,758 | 4,001 | 2,483 |
| | OUTLET | IN.H2O | -1.11 | -1.11 | -1.11 | -1.11 |
| BC 12 RECOUP A SIDE (WB10) | AVG | DEGF | 1,891 | 1,402 | 836 | 1,951 |
| | | LBS/MIN | 2,707 | 2,453 | 3,929 | 2,201 |
| | OUTLET | IN.H2O | -0.90 | -0.90 | -0.90 | -0.90 |
| BC 13 COOLER VENT STACK | AVG | DEGF | 804 | 764 | 336 | 1,195 |
| | | LBS/MIN | 9,231 | 7,703 | 12,644 | 6,923 |
| | OUTLET | IN.H2O | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | 505 | 529 | 176 | 921 |
| BC 17 WINDBOX LEAKAGE | | LBS/MIN | 97 | 136 | 130 | 157 |
| GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 |
| BC 16 O'BED LEAKAGE | | LBS/MIN | (276) | (190) | (78) | (162) |
| GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | 23,777 | 23,691 | 34,079 | 20,163 |
| TOTAL AIR OUT | | | 23,544 | 23,691 | 34,079 | 20,161 |

TABLE 12:
MINNTAC THIRD PARAMETRIC SERIES:
COOLER WITH OVER BED DIVIDING WALL
BETWEEN WIND BOXES 6 AND 7

| | | | 22/520/135/170 | 22/520/170/135 | 28/450/100/135 | 28/450/135/100 |
|----------------------------------|-----------------------------------|---------|----------------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | LTPH | | 520.00 | 520.00 | 450.00 | 450.00 |
| PRODUCTION FACTOR | | | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | | 447.20 | 447.20 | 387.00 | 387.00 |
| GREENBALL MAGNETITE %WT | | | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | 5.31 | 5.31 | 5.31 | 5.31 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | | 22.00 | 22.00 | 22.00 | 22.00 |
| AVG PELLET TEMP INTO COOLER | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | | |
| | 3A FAN FLOW | LBS/MIN | 13,500 | 17,001 | 10,001 | 13,500 |
| | G/S (THRU BED) | LBS/LB | 0.6125 | 0.8040 | 0.4963 | 0.7142 |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 |
| | O'BED | IN.H2O | -0.0816 | 0.0944 | -0.256 | -0.1262 |
| | U'BED | IN.H2O | 17.14 | 19.73 | 13.22 | 16.05 |
| | KFACT | | 545 | 545 | 545 | 545 |
| BC 14 KILN SECONDARY AIR | AVG | DEGF | 2,267 | 2,117 | 2,412 | 2,266 |
| | | LBS/MIN | 5,301 | 6,688 | 3,522 | 4,863 |
| | G/S | LBS/MIN | 0.3175 | 0.4006 | 0.2438 | 0.3366 |
| | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| | | DEGF | 2,291 | 2,284 | 2,328 | 2,314 |
| | | LBS/MIN | 2,639 | 3,007 | 2,205 | 2,522 |
| BC 15 FIRING HOOD AIR | G/S | LBS/LB | 0.1581 | 0.1801 | 0.1526 | 0.1745 |
| | OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 WINDBOX LEAKAGE | | LBS/MIN | 3,274 | 3,577 | 2,830 | 3,180 |
| | GAP HEIGHT | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| | WINDBOX DAMPER POSITION | | CLOSED | CLOSED | CLOSED | CLOSED |
| | LEAK GAP ACROSS DAMPER | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| | OVERBED DIVIDING WALL | | | | | |
| | LOCATION (BETWEEN WBOXES) | | NONE | NONE | NONE | NONE |
| | GAP HEIGHT | INCHES | NA | NA | NA | NA |
| | FLOW (- = 3A TO 3B; + = 3B TO 3A) | LBS/MIN | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | |
| | 3B FAN FLOW | LBS/MIN | 17,001 | 13,500 | 13,500 | 10,001 |
| | G/S (THRU BED) | LBS/MIN | 1.0099 | 0.8006 | 0.9246 | 0.6831 |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 | 39.2 |
| | O'BED | IN.H2O | 0.0228 | -0.2089 | -0.249 | -0.4441 |
| | U'BED | IN.H2O | 13.97 | 10.9 | 12.31 | 8.98 |
| BC 11 RECOUP B SIDE (WB 9) | AVG | DEGF | 1,636 | 1,326 | 1,978 | 1,593 |
| | | LBS/MIN | 3,563 | 3,501 | 2,839 | 2,764 |
| | OUTLET | INH2O | -1.11 | -1.11 | -1.11 | -1.11 |
| BC 12 RECOUP A SIDE (WB10) | AVG | DEGF | 1,287 | 1,040 | 1,628 | 1,313 |
| | | LBS/MIN | 3,532 | 3,304 | 2,698 | 2,455 |
| | OUTLET | INH2O | -0.90 | -0.90 | -0.90 | -0.90 |
| BC 13 COOLER VENT STACK | AVG | DEGF | 524 | 503 | 713 | 672 |
| | | LBS/MIN | 12,112 | 10,404 | 9,364 | 7,786 |
| | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | -0.88 |
| | VENT STACK SEPARATION WALL | | YES | YES | YES | YES |
| | PELLET EXIT TEMP TOP-CENTER | DEGF | 286 | 307 | 419 | 448 |
| BC 17 WINDBOX LEAKAGE | | LBS/MIN | 141 | 133 | 142 | 131 |
| | GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 |
| BC 16 O'BED LEAKAGE | | LBS/MIN | (63) | (112) | (101) | (203) |
| | GAP HEIGHT | INCHES | 1 | 1 | 1 | 1 |
| | TOTAL AIR IN | | 30,563 | 30,612 | 23,602 | 23,703 |
| | TOTAL AIR OUT | | 30,563 | 30,613 | 23,600 | 23,702 |

TABLE 12:
MINNTAC THIRD PARAMETRIC SERIES:
COOLER WITH OVER BED DIVIDING WALL
BETWEEN WIND BOXES 6 AND 7

6 OF 7

| | | | 28/450/170/170 | 28/485/100/100 | 28/485/135/170 | 28/485/170/135 |
|-----------------------------------|---------|---------|----------------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | LTPH | | 450.00 | 485.00 | 485.00 | 485.00 |
| PRODUCTION FACTOR | | | 0.86 | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | | 387.00 | 417.10 | 417.10 | 417.10 |
| GREENBALL MAGNETITE %WT | | | 87.00 | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | 5.31 | 5.31 | 5.31 | 5.31 |
| FE3O4 IN FEED (FE3O4=FE++/.2412) | %WT | | 22.00 | 22.00 | 22.00 | 22.00 |
| AVG PELLETT TEMP INTO COOLER | DEGF | | 2,250 | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | | |
| 3A FAN FLOW | LBS/MIN | | 17,001 | 10,001 | 13,500 | 17,001 |
| G/S (THRU BED) | LBS/LB | | 0.9337 | 0.4605 | 0.6579 | 0.8636 |
| INLET | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | | 0.0907 | -0.2697 | -0.0858 | 0.0871 |
| U'BED | IN.H2O | | 18.95 | 13.19 | 16.92 | 19.42 |
| KFACT | | | 545 | 545 | 545 | 545 |
| BC 14 KILN SECONDARY AIR | AVG | DEGF | 2,027 | 2,429 | 2,279 | 2,106 |
| | | LBS/MIN | 6,794 | 3,326 | 5,254 | 6,652 |
| | G/S | LBS/MIN | 0.4702 | 0.2136 | 0.3374 | 0.4272 |
| BC 15 FIRING HOOD AIR | OUTLET | INH2O | -0.40 | -0.40 | -0.40 | -0.40 |
| | | DEGF | 2,079 | 2,321 | 2,307 | 2,299 |
| | | LBS/MIN | 3,233 | 2,182 | 2,620 | 2,981 |
| | G/S | LBS/LB | 0.2238 | 0.1401 | 0.1682 | 0.1914 |
| | OUTLET | INH2O | -0.73 | -0.73 | -0.73 | -0.73 |
| BC 18 WINDBOX LEAKAGE | | LBS/MIN | 3,511 | 2,830 | 3,256 | 3,552 |
| GAP HEIGHT | | INCHES | 3.62 | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | CLOSED | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | INCHES | 1.67 | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | | | |
| LOCATION (BETWEEN WBOXES) | | | NONE | NONE | NONE | NONE |
| GAP HEIGHT | | INCHES | NA | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | LBS/MIN | NA | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | | |
| 3B FAN FLOW | LBS/MIN | | 17,001 | 10,001 | 17,001 | 13,500 |
| G/S (THRU BED) | LBS/MIN | | 1.1679 | 0.6325 | 1.0830 | 0.8587 |
| INLET | DEGF | | 39.2 | 39.2 | 39.2 | 39.2 |
| O'BED | IN.H2O | | -0.1018 | -0.4089 | -0.018 | -0.2439 |
| U'BED | IN.H2O | | 11.62 | 11.07 | 13.403 | 10.44 |
| BC 11 RECOUP B SIDE (WB 9) | AVG | DEGF | 1,038 | 2,157 | 1,569 | 1,246 |
| | | LBS/MIN | 4,052 | 2,463 | 3,563 | 3,517 |
| | OUTLET | INH2O | -1.11 | -1.11 | -1.11 | -1.11 |
| BC 12 RECOUP A SIDE (WB10) | AVG | DEGF | 742 | 1,915 | 1,200 | 965 |
| | | LBS/MIN | 3,977 | 2,191 | 3,544 | 3,309 |
| | OUTLET | INH2O | -0.90 | -0.90 | -0.90 | -0.90 |
| BC 13 COOLER VENT STACK | AVG | DEGF | 289 | 1,105 | 460 | 437 |
| | | LBS/MIN | 12,654 | 7,020 | 12,197 | 10,479 |
| | OUTLET | INH2O | -0.88 | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | YES | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | 147 | 811 | 239 | 257 |
| BC 17 WINDBOX LEAKAGE | | LBS/MIN | 127 | 152 | 137 | 129 |
| GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 |
| BC 16 O'BED LEAKAGE | | LBS/MIN | (83) | (164) | (68) | (120) |
| GAP HEIGHT | | INCHES | 1 | 1 | 1 | 1 |
| TOTAL AIR IN | | | 34,084 | 20,165 | 30,568 | 30,620 |
| TOTAL AIR OUT | | | 34,349 | 20,164 | 30,570 | 30,619 |

TABLE 12:
MINNTAC THIRD PARAMETRIC SERIES:
COOLER WITH OVER BED DIVIDING WALL
BETWEEN WIND BOXES 6 AND 7

7 OF 7

| | | | 28/520/100/170 | 28/520/135/135 | 28/520/170/100 |
|-----------------------------------|----------------|---------|----------------|----------------|----------------|
| GREEN BALL FEED RATE ON GRATE | LTPH | | 520.00 | 520.00 | 520.00 |
| PRODUCTION FACTOR | | | 0.86 | 0.86 | 0.86 |
| PELLET FEED TO COOLER | LTPH | | 447.20 | 447.20 | 447.20 |
| GREENBALL MAGNETITE %WT | | | 87.00 | 87.00 | 87.00 |
| FE++ IN COOLER FEED | | | 5.31 | 5.31 | 5.31 |
| FE3O4 IN FEED (FE3O4=FE++/2412) | %WT | | 22.00 | 22.00 | 22.00 |
| AVG PELLET TEMP INTO COOLER | DEGF | | 2,250 | 2,250 | 2,250 |
| PRIMARY COOLING ZONE | | | | | |
| | 3A FAN FLOW | LBS/MIN | 10,001 | 13,500 | 17,001 |
| | G/S (THRU BED) | LBS/LB | 0.4225 | 0.6124 | 0.8034 |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 |
| | O'BED | IN.H2O | -0.2165 | -0.0924 | 0.0836 |
| | U'BED | IN.H2O | 14.54 | 17.12 | 19.82 |
| | KFACT | | 545 | 545 | 545 |
| BC 14 KILN SECONDARY AIR | AVG | DEGF | 2,418 | 2,318 | 2,169 |
| | | LBS/MIN | 3,977 | 5,111 | 6,532 |
| | G/S | LBS/MIN | 0.2382 | 0.3061 | 0.3912 |
| | OUTLET | INH2O | -0.40 | -0.40 | -0.40 |
| BC 15 FIRING HOOD AIR | | DEGF | 2,311 | 2,302 | 2,294 |
| | | LBS/MIN | 2,313 | 2,606 | 2,975 |
| | G/S | LBS/LB | 0.1385 | 0.1561 | 0.1782 |
| | OUTLET | INH2O | -0.73 | -0.73 | -0.73 |
| BC 18 WINDBOX LEAKAGE | | LBS/MIN | 2,946 | 3,276 | 3,588 |
| GAP HEIGHT | | INCHES | 3.62 | 3.62 | 3.62 |
| WINDBOX DAMPER POSITION | | | CLOSED | CLOSED | CLOSED |
| LEAK GAP ACROSS DAMPER | | INCHES | 1.67 | 1.67 | 1.67 |
| OVERBED DIVIDING WALL | | | | | |
| LOCATION (BETWEEN WBOXES) | | | NONE | NONE | NONE |
| GAP HEIGHT | | INCHES | NA | NA | NA |
| FLOW (- = 3A TO 3B; + = 3B TO 3A) | | LBS/MIN | NA | NA | NA |
| SECONDARY COOLING ZONE | | | | | |
| | 3B FAN FLOW | LBS/MIN | 17,001 | 13,500 | 10,001 |
| | G/S (THRU BED) | LBS/MIN | 1.0093 | 0.8000 | 0.5911 |
| | INLET | DEGF | 39.2 | 39.2 | 39.2 |
| | O'BED | IN.H2O | 0.033 | -0.175 | -0.3906 |
| | U'BED | IN.H2O | 15.43 | 12.33 | 9.032 |
| BC 11 RECOUP B SIDE (WB 9) | AVG | DEGF | 2,059 | 1,766 | 1,447 |
| | | LBS/MIN | 3,208 | 3,134 | 3,039 |
| | OUTLET | INH2O | -1.11 | -1.11 | -1.11 |
| BC 12 RECOUP A SIDE (WB10) | AVG | DEGF | 1,674 | 1,462 | 1,185 |
| | | LBS/MIN | 3,180 | 2,981 | 2,702 |
| | OUTLET | INH2O | -0.90 | -0.90 | -0.90 |
| BC 13 COOLER VENT STACK | AVG | DEGF | 728 | 703 | 661 |
| | | LBS/MIN | 11,280 | 9,848 | 8,246 |
| | OUTLET | INH2O | -0.88 | -0.88 | -0.88 |
| VENT STACK SEPARATION WALL | | | YES | YES | YES |
| PELLET EXIT TEMP TOP-CENTER | | DEGF | 417 | 437 | 511 |
| BC 17 WINDBOX LEAKAGE | | LBS/MIN | 150 | 143 | 132 |
| GAP HEIGHT | | INCHES | 1 | 1 | 1 |
| BC 16 O'BED LEAKAGE | | LBS/MIN | (55) | (97) | (213) |
| GAP HEIGHT | | INCHES | 1 | 1 | 1 |
| TOTAL AIR IN | | | 27,056 | 27,097 | 27,214 |
| TOTAL AIR OUT | | | 27,055 | 27,099 | 27,214 |

TABLE 13
CURRENT COOLER - NO OVERBED WALL
MEDUSA/CFD OPERATING WINDOW - OPTIMIZATION SERIES


| 3A FAN FLOW LBS/MIN | 3B FAN FLOW LBS/MIN | OPTIMIZE FACTOR | OPTIMIZED GREEN BALL FEED, LTPH | 3A O'BED PRESS. IN H2O | 3B O'BED PRESS. IN. H2O | DD2 OBED TEMP DEG F | DD2DD2 FLOW LBS/MIN | TOTAL PREHEAT FLOW LBS/MIN | KILN SOLIDS DISCH. MAG. %WT | AVE RECOUP TEMP AT COOLER DEG F | TOTAL RECOUP FLOW LBS/MIN | FUEL BTU/LT | COOLER FLOW TO KILN LBS/MIN |
|---------------------|---------------------|-----------------|---------------------------------|------------------------|-------------------------|---------------------|---------------------|----------------------------|-----------------------------|---------------------------------|---------------------------|-------------|-----------------------------|
| 10,500 | 13,800 | 11.214 | 445.6 | -0.22 | -0.31 | 1,080 | 8,655 | 11,856 | 16.6 | 1,517 | 5,841 | 619,876 | 6,491 |
| 10,500 | 14,800 | 11.300 | 452.5 | -0.20 | -0.26 | 1,080 | 8,828 | 12,044 | 16.8 | 1,503 | 6,016 | 610,478 | 6,683 |
| 10,500 | 15,800 | 11.400 | 460.5 | -0.18 | -0.22 | 1,082 | 8,995 | 12,234 | 17.0 | 1,495 | 6,184 | 599,813 | 6,874 |
| 10,500 | 16,800 | 11.500 | 468.7 | -0.16 | -0.17 | 1,084 | 9,161 | 12,426 | 17.2 | 1,487 | 6,351 | 589,427 | 7,066 |
| 11,000 | 13,300 | 11.205 | 444.9 | -0.21 | -0.33 | 1,059 | 8,651 | 11,983 | 16.8 | 1,487 | 5,837 | 620,872 | 6,621 |
| 11,000 | 14,800 | 11.316 | 453.8 | -0.18 | -0.26 | 1,053 | 8,920 | 12,264 | 16.8 | 1,460 | 6,108 | 608,751 | 6,906 |
| 11,000 | 16,300 | 11.494 | 468.2 | -0.15 | -0.18 | 1,063 | 9,154 | 12,556 | 17.4 | 1,459 | 6,344 | 590,042 | 7,195 |
| 11,000 | 17,000 | 11.564 | 473.9 | -0.14 | -0.15 | 1,064 | 9,270 | 12,689 | 17.6 | 1,454 | 6,461 | 582,921 | 7,329 |
| 12,000 | 12,500 | 11.218 | 446.0 | -0.18 | -0.35 | 1,019 | 8,671 | 12,279 | 17.1 | 1,429 | 5,857 | 619,434 | 6,918 |
| 12,000 | 14,000 | 11.353 | 456.8 | -0.15 | -0.28 | 1,018 | 8,927 | 12,564 | 17.4 | 1,412 | 6,116 | 604,790 | 7,204 |
| 12,000 | 15,500 | 11.492 | 468.0 | -0.12 | -0.21 | 1,019 | 9,180 | 12,852 | 17.8 | 1,397 | 6,369 | 590,248 | 7,490 |
| 12,000 | 17,000 | 11.610 | 477.7 | -0.09 | -0.14 | 1,014 | 9,442 | 13,135 | 18.0 | 1,375 | 6,634 | 578,311 | 7,774 |
| 13,000 | 11,800 | 11.264 | 449.6 | -0.15 | -0.37 | 984 | 8,696 | 12,597 | 17.7 | 1,380 | 5,882 | 614,385 | 7,236 |
| 13,000 | 13,000 | 11.355 | 456.9 | -0.13 | -0.32 | 980 | 8,909 | 12,823 | 17.8 | 1,360 | 6,097 | 604,577 | 7,463 |
| 13,000 | 14,200 | 11.446 | 464.3 | -0.10 | -0.26 | 975 | 9,120 | 13,050 | 18.0 | 1,341 | 6,310 | 595,002 | 7,690 |
| 13,000 | 15,200 | 11.537 | 471.7 | -0.08 | -0.21 | 974 | 9,290 | 13,241 | 18.2 | 1,330 | 6,480 | 585,652 | 7,881 |
| 13,000 | 17,000 | 11.637 | 479.9 | -0.05 | -0.13 | 957 | 9,621 | 13,577 | 18.5 | 1,291 | 6,813 | 575,630 | 8,217 |
| 14,000 | 10,800 | 11.220 | 446.1 | -0.13 | -0.41 | 935 | 8,699 | 12,850 | 17.8 | 1,311 | 5,886 | 619,213 | 7,492 |
| 14,000 | 11,800 | 11.314 | 453.6 | -0.11 | -0.36 | 936 | 8,868 | 13,041 | 18.0 | 1,301 | 6,055 | 608,966 | 7,682 |
| 14,000 | 12,800 | 11.367 | 457.9 | -0.09 | -0.32 | 926 | 9,054 | 13,227 | 18.1 | 1,278 | 6,243 | 603,301 | 7,869 |
| 14,000 | 13,800 | 11.491 | 467.9 | -0.07 | -0.27 | 933 | 9,207 | 13,423 | 18.6 | 1,279 | 6,397 | 590,351 | 8,062 |
| 15,000 | 10,100 | 11.255 | 446.9 | -0.09 | -0.43 | 898 | 8,730 | 13,167 | 18.3 | 1,258 | 5,916 | 615,368 | 7,808 |
| 15,000 | 10,800 | 11.292 | 451.9 | -0.08 | -0.40 | 891 | 8,861 | 13,296 | 18.3 | 1,241 | 6,048 | 611,342 | 7,940 |
| 15,000 | 11,500 | 11.332 | 455.1 | -0.07 | -0.37 | 885 | 8,989 | 13,428 | 18.4 | 1,226 | 6,178 | 607,033 | 8,070 |

TABLE 14
COOLER WITH OVERBED WALL
MEDUSA/CFD OPERATING WINDOW - OPTIMZATION SERIES

| 3A FAN FLOW LBS/MIN | 3B FAN FLOW LBS/MIN | OPTIMIZE FACTOR | OPTIMIZED GREEN BALL FEED, LTPH | 3A O'BED PRESS. IN H2O | 3B O'BED PRESS. IN. H2O | DD2 OBED TEMP DEG F | DD2DD2 FLOW LBS/MIN | TOTAL PREHEAT FLOW LBS/MIN | KILN SOLIDS DISCH. MAG. %WT | AVE RECOUP TEMP AT COOLER DEG F | TOTAL RECOUP FLOW LBS/MIN | FUEL BTU/LT | COOLER FLOW TO KILN LBS/MIN |
|---------------------|---------------------|-----------------|---------------------------------|------------------------|-------------------------|---------------------|---------------------|----------------------------|-----------------------------|---------------------------------|---------------------------|-------------|-----------------------------|
| 10,500 | 13,800 | 11.031 | 431.2 | -0.25 | -0.28 | 1,093 | 8,649 | 11,344 | 15.9 | 1,481 | 5,835 | 640,613 | 5,968 |
| 10,500 | 14,800 | 11.137 | 439.5 | -0.24 | -0.22 | 1,106 | 8,910 | 11,430 | 16.0 | 1,476 | 6,099 | 628,477 | 6,056 |
| 10,500 | 15,800 | 11.220 | 446.1 | -0.24 | -0.15 | 1,113 | 9,175 | 11,513 | 16.1 | 1,464 | 6,365 | 619,213 | 6,140 |
| 10,500 | 16,800 | 11.287 | 451.5 | -0.23 | -0.09 | 1,116 | 9,441 | 11,595 | 16.1 | 1,448 | 6,633 | 611,883 | 6,223 |
| 11,000 | 13,300 | 11.068 | 434.1 | -0.23 | -0.31 | 1,071 | 8,600 | 11,578 | 16.3 | 1,456 | 5,786 | 636,337 | 6,200 |
| 11,000 | 14,800 | 11.186 | 443.4 | -0.22 | -0.21 | 1,081 | 8,998 | 11,705 | 16.3 | 1,436 | 6,187 | 622,983 | 6,334 |
| 11,000 | 16,300 | 11.292 | 451.9 | -0.21 | -0.12 | 1,087 | 9,397 | 11,829 | 16.4 | 1,414 | 6,588 | 611,342 | 6,549 |
| 11,000 | 17,000 | 11.342 | 455.9 | -0.20 | -0.08 | 1,090 | 9,582 | 11,887 | 16.4 | 1,404 | 6,775 | 605,963 | 6,518 |
| 12,000 | 12,500 | 11.149 | 440.5 | -0.18 | -0.34 | 1,027 | 8,557 | 12,069 | 17.0 | 1,400 | 5,743 | 627,125 | 6,704 |
| 12,000 | 14,000 | 11.270 | 450.1 | -0.17 | -0.25 | 1,038 | 8,953 | 12,197 | 17.1 | 1,383 | 6,142 | 613,731 | 6,830 |
| 12,000 | 15,500 | 11.348 | 456.4 | -0.16 | -0.16 | 1,038 | 9,356 | 12,318 | 17.1 | 1,352 | 6,547 | 605,323 | 6,952 |
| 12,000 | 17,000 | 11.424 | 462.5 | -0.15 | -0.07 | 1,036 | 9,758 | 12,441 | 17.1 | 1,322 | 6,952 | 597,296 | 7,074 |
| 13,000 | 11,800 | 11.201 | 444.6 | -0.14 | -0.38 | 976 | 8,545 | 12,562 | 17.5 | 1,332 | 5,731 | 621,315 | 7,203 |
| 13,000 | 13,000 | 11.275 | 450.5 | -0.13 | -0.31 | 980 | 8,866 | 12,661 | 17.5 | 1,311 | 6,054 | 613,186 | 7,301 |
| 13,000 | 14,200 | 11.378 | 458.8 | -0.12 | -0.23 | 988 | 9,182 | 12,767 | 17.7 | 1,300 | 6,371 | 602,135 | 7,404 |
| 13,000 | 15,200 | 11.408 | 461.2 | -0.12 | -0.17 | 982 | 9,452 | 12,845 | 17.7 | 1,273 | 6,644 | 598,972 | 7,483 |
| 13,000 | 17,000 | 11.475 | 466.6 | -0.10 | -0.07 | 973 | 9,937 | 12,991 | 17.8 | 1,231 | 7,132 | 591,998 | 7,626 |
| 14,000 | 10,800 | 11.273 | 450.3 | -0.09 | -0.43 | 932 | 8,449 | 13,040 | 18.1 | 1,281 | 5,634 | 613,404 | 7,682 |
| 14,000 | 11,800 | 11.311 | 453.4 | -0.09 | -0.37 | 930 | 8,718 | 13,119 | 18.1 | 1,256 | 5,905 | 609,289 | 7,762 |
| 14,000 | 12,800 | 11.350 | 456.5 | -0.08 | -0.31 | 927 | 8,988 | 13,199 | 18.1 | 1,232 | 6,177 | 605,109 | 7,841 |
| 14,000 | 13,800 | 11.455 | 465.0 | -0.07 | -0.25 | 938 | 9,248 | 13,291 | 18.4 | 1,230 | 6,439 | 594,067 | 7,929 |
| 15,000 | 10,100 | 11.295 | 452.1 | -0.05 | -0.47 | 874 | 8,442 | 13,530 | 18.4 | 1,202 | 5,627 | 611,017 | 8,178 |
| 15,000 | 10,800 | 11.328 | 454.7 | -0.05 | -0.43 | 874 | 8,630 | 13,587 | 18.4 | 1,188 | 5,816 | 607,462 | 8,234 |
| 15,000 | 11,500 | 11.398 | 460.4 | -0.04 | -0.38 | 881 | 8,812 | 13,652 | 18.7 | 1,185 | 5,999 | 600,024 | 8,295 |

Figure 1
Minntac Cooler

View 1



View 2




FIGURE 2

MINNTAC LINE 6
PLAN VIEW WITH HIGH TEMP HEAT RECOUP





FIGURE 3
Line 6 Cooler
Plan View



Notes:

Mean Diameter = 56'0"
Bed width = 96'

Drawing Name - 6cooler
Disk #65
May 12, 1997
Ray Potts

FIGURE 4
LINE 6 FEED TO COOLER






FIGURE 5
KILN DISCHG TEMP VS CFD PELLET TEMP




- PLANT 15' TO DISCHG
- CFD BC-1
- △ CFD BC-2
- × CFD BC-4
- ⊠ CFD BC-5
- ⊞ CFD BC-6
- ▲ CFD BC-3

FIGURE 6
PRIMARY COOLING OVER BED PRESSURE



- PELLET PLANT □ CFD BC-1 ▲ CFD BC-3
- ⊗ CFD BC-5 ⊠ CFD BC-6 △ CFD BC-2
- ⊗ CFD BC-4

FIGURE 7
PLANT PRI OBED PRESS VS CFD PREDICTION



- PLANT
- CFD BC-3 AND BC-4
- ⊗ CFD BC-5
- ⊗ CFD BC-6
- ⊗— BC-5 (Linear Fit)
- ⊗— BC-6 (Linear Fit)

FIGURE 8
PRIMARY COOLING UNDER BED PRESSURE




FIGURE 9
KILN SECONDARY AIR TEMPERATURE




FIGURE 10
PARALLEL FLOW DUCT THERMOCOUPLE PLANE
TEMPERATURE PROFILE





FIGURE 11
SECONDARY COOLING OVER BED PRESSURE



- PELLET PLANT □ CFD BC-1 △ CFD BC-2 × CFD BC-4
- ⊗ CFD BC-5 ⊠ CFD BC-6 ▲ CFD BC-3

FIGURE 12
SECONDARY COOLING UNDERBED PRESSURE




FIGURE 13
RECOUP A DUCT - TEMPERATURE




FIGURE 14
RECOUP B DUCT - TEMPERATURE




FIGURE 15 RECOUP A DUCT

THERMOCOUPLE PLANE
TEMPERATURE PROFILE




FIGURE 16 RECOUP B DUCT

THERMOCOUPLE PLANE
TEMPERATURE PROFILE




FIGURE 17 RECOUP A DUCT

VELOCITY PROFILE IN THERMOCOUPLE PLANE

from Parametric Series
450 WLTPH, 22% Mag,
13,500 lb/Min 3A, 13,500 lbs/min 3B






FIGURE 18
AVE RECOUP TEMP AND DD2 OBED TEMP




PLANT AVE RECOUP TC'S TEMP
 PLANT DD2 FURNACE OBED TEMP
x CFD BC-5
 x CFD BC-6

FIGURE 19
RECOUP DUCT A FLOW




- PLANT THERMOCOUPLE □ CFD BC-1 △ CFD BC-2 × CFD BC-4
- ⊗ CFD BC-5 ⊠ CFD BC-6 ▲ CFD BC-3

FIGURE 20 RECOUP B DUCT FLOW



- | | | | |
|--------------------|----------|----------|----------|
| PLANT THERMOCOUPLE | CFD BC-1 | CFD BC-2 | CFD BC-4 |
| CFD BC-5 | CFD BC-6 | CFD BC-3 | |

FIGURE 21 COOLER VENT STACK FLOW



- PLANT THERMOCOUPLE □ CFD BC-1 △ CFD BC-2 × CFD BC-4
- ⊠ CFD BC-5 ⊞ CFD BC-6 ▲ CFD BC-3

FIGURE 22

COOLER VENT STACK TEMP




FIGURE 23
3A FLOW VS 3A WINDBOX PRESSURE




FIGURE 24
3B FLOW VS 3B WINDBOX PRESSURE




FIGURE 25
STACK FLOW VS 3B FAN FLOW





FIGURE 26
KILN SECONDARY AIR TEMP VS 3A FAN FLOW



- PLANT
- CFD BC-3 AND BC-4
- ⊠ CFD DATA BC-5
- ⊠ CFD BC-6
- PLANT DATA (Linear Fit)
- BC-5 (Linear Fit)

FIGURE 27
RECOUP A DUCT TEMP VS 3A FAN FLOW




FIGURE 28
RECOUP B DUCT TEMP VS 3A FAN FLOW




FIGURE 29
RECOUP A DUCT TEMP VS 3B FAN FLOW




FIGURE 30
RECOUP B DUCT TEMP VS 3B FAN FLOW





FIGURE 31
PLANT 3A FLOW VS 3B FLOW



● PLANT MEASURED FLOW

FIGURE 32
3A OVERBED PRESSURE VS 3A FLOW





FIGURE 33
3B OVERBED PRESSURE VS 3B FLOW



- PLANT DATA
- CFD BC-3 AND BC-4
- ⊗ CFD BC-5
- ⊗ CFD BC-6
- PLANT DATA (Linear Fit)
- ⊗— BC-5 (Linear Fit)

FIGURE 34
PHEAT OBED PRESS VS 3A OBED PRESSURE





FIGURE 35
KILN FLOW VS 3A FLOW



- PLANT PHEAT FLOW
- CFD KILN FLOW BC-3 AND BC-4
- ⊗ CFD KILN FLOW BC-5
- ⊗ CFD KILN FLOW BC-6
- PLANT DATA (Linear Fit)
- BC-5 (Linear Fit)

FIGURE 36
DD1 O'BED TARGET TEMP COMPARISON




FIGURE 37
DD2 O'BED TARGET TEMP COMPARISON





FIGURE 38
PREHEAT FAN INLET TEMP COMPARISON




● PLANT AVG PHEAT FAN

△ LOW LEAK - MEDUSA OPT FEED RATE


⊠ HIGH LEAK MEDUSA OPT FEED RATE

FIGURE 39
KILN SOLIDS EXIT TEMP COMPARISON



● PLANT DD1 OBED TEMP DEG K ▲ LOW LEAK MEDUSA OPT FEED RATE
 □ HIGH LEAK MEDUSA OPT FEED RATE

FIGURE 40
PLANT FEED VS MEDUSA OPTIMUM FEED RATE



● PLANT FEED RATE TO GRATE

△ LOW LEAK - MEDUSA OPT FEED RATE

□ HIGH LEAK - MEDUSA OPT FEED RATE

CFX




FIGURE 41
Cooler Layout

- A. Kiln Discharge
- B. Screed Wall
- C. 3A Fan Inlet
- D. Parallel Flow Duct
- E. Under Bed Damper
- F. Recoup B Duct
- G. Recoup A Duct
- H. Cooler Vent Stack
- I. Baffle Wall
- J. Auxiliary Vent Stack
- K. 3B Fan Inlet
- L. Pellet Dump
- M. Firing Hood Section
- Over Bed and Under Bed Pressure Sensors

FIGURE 42
3A OBED PRESS AND PELLET EXIT TEMP




FIGURE 43
PELLET EXIT TEMP VS TOTAL COOLER FLOW




FIGURE 44
3A OBED PRESSURE VS TOTAL COOLER FLOW






FIGURE 45
RECOUP TEMPERATURE VS 3B FAN FLOW



-



FIGURE 46
RECOUP TEMP VS TOTAL COOLER FLOW



—■— 3A 10,000 REC B —●— 3A 13,500 REC B —▲— 3A 17,000 REC B
 —□— 3A 10,000 REC A —○— 3A 13,500 REC A —△— 3A 17,000 REC A

FIGURE 47
RECOUP FLOW VS 3B FAN FLOW




FIGURE 48
RECOUP FLOW VS TOTAL COOLER FLOW




FIGURE 50

Second Parametric Series: Current Cooler Baseline
Vent Stack Temperature Vs Pellet Exit Temperature




FIGURE 51

Current Cooler Operating Window 485 WLTPH Feed to Grate

High fan flow limited by maximum 3A overbed pressure of -0.05 in. H₂O
 Low fan flow limited by pellet exit temperature of 500 °F or Vent stack temperature of 765 °F




FIGURE 52

Current Cooler Operating Window 520 WLTPH Feed to Grate

High fan flow limited by maximum 3A overbed pressure of -0.05 in.H₂O
 Low fan flow limited by pellet exit temperature of 500 °F or Vent stack Temperature of 765 °F




FIGURE 53

Third Parametric Series: Cooler with Over Bed Dividing Wall
Offset One Wind Box - Linear Regression Model

Parameter Estimates

| | 3A OB PRS INH2O | T KILN LBS/MIN | A KILN TEMP F | T REC LBS/MIN | A REC TEMP F | PELL EXT TMP F | VENT STK TMP F |
|------------|-----------------|----------------|---------------|---------------|--------------|----------------|----------------|
| Intercept | -0.9513313 | -1447.9381 | 2254.21845 | 735.940851 | 1512.44831 | 376.762343 | 628.633335 |
| % MAG | 0.00073129 | 2.10479884 | 5.08006602 | -5.5628741 | 8.65558261 | 2.28543812 | 3.35103766 |
| FEED LTPH | 0.0002687 | 1.43599092 | 0.74806073 | -1.4220514 | 3.4012627 | 2.27466569 | 2.67839069 |
| 3A LBS/MIN | 0.00004742 | 0.54851581 | -0.0326434 | 0.19004634 | -0.1106692 | -0.0384242 | -0.0553459 |
| 3B LBS/MIN | 0.00000541 | 0.07561741 | -0.0033407 | 0.27576812 | -0.030434 | -0.045602 | -0.0469163 |

Prediction Profile





FIGURE 54

Third Parametric Series: Cooler with Over Bed Dividing Wall
Vent Stack vs Pellet Exit Temperature



Linear Fit

VENT STK TMP F = 157.107 + 1.17132 PELL EXT TMP F

| Summary of Fit | |
|----------------------------|----------|
| RSquare | 0.968304 |
| RSquare Adj | 0.967036 |
| Root Mean Square Error | 42.00501 |
| Mean of Response | 620.8022 |
| Observations (or Sum Wgts) | 27 |

| Analysis of Variance | | | | |
|----------------------|----|----------------|-------------|----------|
| Source | DF | Sum of Squares | Mean Square | F Ratio |
| Model | 1 | 1347569.2 | 1347569 | 783.7461 |
| Error | 25 | 44110.5 | 1764 | Prob>F |
| C Total | 26 | 1391679.8 | | <.0001 |

| Parameter Estimates | | | | |
|---------------------|-----------|-----------|---------|---------|
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 157.10653 | 18.62455 | 8.44 | <.0001 |
| PELL EXT TMP F | 1.1713211 | 0.042384 | 27.64 | <.0001 |

FIGURE 55
 Cooler with Over Bed Dividing Wall Operating Window
 One Wind Box Offset
 485 WLTPH Feed to Grate

High flow limited by maximum 3A overbed pressure of -0.05 in.H₂O.
 Low fan flow limited by pellet exit temperature, or vent stack temperature and minimum 3A overbed pressure of -0.2 in. H₂O.




FIGURE 56

Cooler with Over Bed Dividing Wall 520 WLTPH Feed to Grate

High fan flow limited by maximum 3A overbed pressure of -0.05 in H₂O.
 Low fan flow limited by pellet exit temperature, or vent stack temperature and low 3A overbed pressure of -0.2 in H₂O.






FIGURE 57
PHEAT FAN TEMP VS OPTIMIZED FEED RATE



- CURRENT COOLER — CURRENT COOLER - LINEAR FIT
- COOLER WITH OVER BED WALL — COOLER WITH WALL- LINEAR FIT

FIGURE 58
KILN DISCH TEMP VS OPTIMIZED FEED RATE




■ CURRENT COOLER

— CURRENT COOLER - LINEAR FIT

● COOLER WITH WALL

— COOLER WITH WALL - LINEAR FIT

FIGURE 59
SIMULATION DEVIATION FROM TARGET VALUE



- CURRENT COOLER PREHEAT FAN TEMP ● CURRENT COOLER KILN SOL DISCH TEMP
- COOLER W/WALL PHEAT FAN TEMP ○ COOLER W/WALL KILN SOL DISCHG TEMP

FIGURE 60

Current Cooler: 485 WLTPH Operating Window
 MEDUSA/CFD: Surface Responses




FIGURE 61

Cooler with Over Bed Dividing Wall: 485 WLTPH Operating Window MEDUSA/CFD: Surface Response





FIGURE 62
Current Cooler: 485 WLTPH Operating Window

A. Feed Rate and Fuel Prediction Profiles using Cooler Fan as Control Variables



B. Feed Rate and Fuel Prediction Profiles using Preheat Fan and Recoup Flow as Control Variables





FIGURE 63
Cooler with Over Bed Dividing Wall: 485 WLTPH Operating Window

A. Feed Rate and Fuel Prediction Profiles using Cooler Fan Control Variables



B. Feed Rate and Fuel Prediction Profiles using Preheat Fan Flow and Total Recoup Flow





FIGURE 64

Current Cooler: MEDUSA/CFD



Cooler with Over Bed Dividing Wall: MEDUSA/CFD




FIGURE 65


Current Cooler: MEDUSA/CFD

Response: LTPH


| Summary of Fit | |
|----------------------------|----------|
| RSquare | 0.980362 |
| RSquare Adj | 0.978491 |
| Root Mean Square Error | 1.563294 |
| Mean of Response | 459.1785 |
| Observations (or Sum Wgts) | 24 |

| Parameter Estimates | | | | |
|---------------------|-----------|-----------|---------|---------|
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 290.72799 | 6.208174 | 46.83 | <.0001 |
| 3a flow | 0.0057919 | 0.000297 | 19.49 | <.0001 |
| 3b flow | 0.0068937 | 0.000215 | 32.08 | <.0001 |


| Effect Test | | | | | |
|-------------|-------|----|----------------|----------|--------|
| Source | Nparm | DF | Sum of Squares | F Ratio | Prob>F |
| 3a flow | 1 | 1 | 928.4944 | 379.9251 | <.0001 |
| 3b flow | 1 | 1 | 2514.8024 | 1029.017 | <.0001 |



| Analysis of Variance | | | | |
|----------------------|----|----------------|-------------|----------|
| Source | DF | Sum of Squares | Mean Square | F Ratio |
| Model | 2 | 2561.9975 | 1281.00 | 524.1642 |
| Error | 21 | 51.3217 | 2.44 | Prob>F |
| C Total | 23 | 2613.3191 | | <.0001 |



| Effect Test | | | |
|----------------|----------|----|--------|
| Sum of Squares | F Ratio | DF | Prob>F |
| 928.49445 | 379.9251 | 1 | <.0001 |



| Effect Test | | | |
|----------------|----------|----|--------|
| Sum of Squares | F Ratio | DF | Prob>F |
| 2514.8024 | 1029.017 | 1 | <.0001 |


Cooler with Dividing Wall: MEDUSA/CFD

Response: LTPH


| Summary of Fit | |
|----------------------------|----------|
| RSquare | 0.965855 |
| RSquare Adj | 0.962603 |
| Root Mean Square Error | 1.78702 |
| Mean of Response | 451.5498 |
| Observations (or Sum Wgts) | 24 |

| Parameter Estimates | | | | |
|---------------------|-----------|-----------|---------|---------|
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 280.57454 | 7.09664 | 39.54 | <.0001 |
| 3a flow | 0.0081023 | 0.00034 | 23.85 | <.0001 |
| 3b flow | 0.0050021 | 0.000246 | 20.36 | <.0001 |


| Effect Test | | | | | |
|-------------|-------|----|----------------|----------|--------|
| Source | Nparm | DF | Sum of Squares | F Ratio | Prob>F |
| 3a flow | 1 | 1 | 1817.0172 | 568.9839 | <.0001 |
| 3b flow | 1 | 1 | 1324.0680 | 414.6203 | <.0001 |



| Analysis of Variance | | | | |
|----------------------|----|----------------|-------------|----------|
| Source | DF | Sum of Squares | Mean Square | F Ratio |
| Model | 2 | 1896.9950 | 948.496 | 297.0142 |
| Error | 21 | 67.0823 | 3.193 | Prob>F |
| C Total | 23 | 1964.0573 | | <.0001 |




| Effect Test | | | |
|----------------|----------|----|--------|
| Sum of Squares | F Ratio | DF | Prob>F |
| 1817.0172 | 568.9839 | 1 | <.0001 |



| Effect Test | | | |
|----------------|----------|----|--------|
| Sum of Squares | F Ratio | DF | Prob>F |
| 1324.0680 | 414.6203 | 1 | <.0001 |

FIGURE 66

Current Cooler: MEDUSA/CFD:



Cooler with Over Bed Dividing Wall:




FIGURE 67




Current Cooler: Medusa/CFD

Response: LTPH

| Summary of Fit | |
|----------------------------|----------|
| RSquare | 0.97018 |
| RSquare Adj | 0.96734 |
| Root Mean Square Error | 1.926373 |
| Mean of Response | 459.1785 |
| Observations (or Sum Wgts) | 24 |

| Parameter Estimates | | | | |
|---------------------|-----------|-----------|---------|---------|
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 228.41838 | 11.28088 | 20.25 | <.0001 |
| PHEAT FLOW | -0.002319 | 0.000964 | -2.40 | 0.0255 |
| COOL REC FLOW | 0.0421045 | 0.001821 | 23.12 | <.0001 |

| Effect Test | | | | | |
|---------------|-------|----|----------------|----------|--------|
| Source | Nparm | DF | Sum of Squares | F Ratio | Prob>F |
| PHEAT FLOW | 1 | 1 | 21.4565 | 5.7820 | 0.0255 |
| COOL REC FLOW | 1 | 1 | 1983.3013 | 534.4511 | <.0001 |



Cooler with Over Bed Dividing Wall:

Response: LTPH

| Summary of Fit | |
|----------------------------|----------|
| RSquare | 0.965038 |
| RSquare Adj | 0.961709 |
| Root Mean Square Error | 1.80827 |
| Mean of Response | 451.5498 |
| Observations (or Sum Wgts) | 24 |

| Parameter Estimates | | | | |
|---------------------|-----------|-----------|---------|---------|
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 233.67881 | 9.058812 | 25.80 | <.0001 |
| PHEAT FLOW | 0.009683 | 0.000513 | 18.87 | <.0001 |
| COOL REC FLOW | 0.0156338 | 0.00089 | 17.57 | <.0001 |

| Effect Test | | | | | |
|---------------|-------|----|----------------|----------|--------|
| Source | Nparm | DF | Sum of Squares | F Ratio | Prob>F |
| PHEAT FLOW | 1 | 1 | 1163.8167 | 355.9248 | <.0001 |
| COOL REC FLOW | 1 | 1 | 1009.0269 | 308.5861 | <.0001 |






FIGURE 68

Current Cooler: MEDUSA/CFD:

Response: PHEAT FLOW



| Summary of Fit | |
|----------------------------|----------|
| RSquare | 0.684068 |
| RSquare Adj | 0.648799 |
| Root Mean Square Error | 294.6391 |
| Mean of Response | 12775.08 |
| Observations (or Sum Wgts) | 24 |

Lack of Fit

| Parameter Estimates | | | | |
|---------------------|-----------|-----------|---------|---------|
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 9500.0833 | 500.2426 | 18.99 | <.0001 |
| 3a flow | 0.262 | 0.039729 | 6.59 | <.0001 |

Effect Test

| Source | Nparm | DF | Sum of Squares | F Ratio | Prob>F |
|---------|-------|----|----------------|---------|--------|
| 3a flow | 1 | 1 | 3775420.0 | 43.4895 | <.0001 |



Cooler with Over Bed Dividing Wall: MEDUSA/CFD:

Response: PHEAT FLOW

| Summary of Fit | |
|----------------------------|----------|
| RSquare | 0.971361 |
| RSquare Adj | 0.97008 |
| Root Mean Square Error | 128.509 |
| Mean of Response | 12484.58 |
| Observations (or Sum Wgts) | 24 |

Lack of Fit

| Parameter Estimates | | | | |
|---------------------|-----------|-----------|---------|---------|
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 6547.7652 | 218.1845 | 30.01 | <.0001 |
| 3a flow | 0.4733455 | 0.017328 | 27.32 | <.0001 |

Effect Test

| Source | Nparm | DF | Sum of Squares | F Ratio | Prob>F |
|---------|-------|----|----------------|----------|--------|
| 3a flow | 1 | 1 | 12323078 | 748.1947 | <.0001 |





FIGURE 69


Current Cooler: MEDUSA/CFD:

Response: PHEAT FLOW


| Summary of Fit | |
|----------------------------|----------|
| RSquare | 0.999979 |
| RSquare Adj | 0.999977 |
| Root Mean Square Error | 2.390289 |
| Mean of Response | 12775.08 |
| Observations (or Sum Wgts) | 24 |

| Parameter Estimates | | | | |
|---------------------|-----------|-----------|---------|---------|
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 4538.9592 | 9.492347 | 478.17 | <.0001 |
| 3a flow | 0.4471355 | 0.000454 | 984.14 | <.0001 |
| 3b flow | 0.1896711 | 0.000329 | 578.15 | <.0001 |


| Effect Test | | | | | |
|-------------|-------|----|----------------|----------|--------|
| Source | Nparm | DF | Sum of Squares | F Ratio | Prob>F |
| 3a flow | 1 | 1 | 5533741.1 | 968541.2 | <.0001 |
| 3b flow | 1 | 1 | 1909747.9 | 334253 | <.0001 |



| Analysis of Variance | | | | |
|----------------------|----|----------------|-------------|----------|
| Source | DF | Sum of Squares | Mean Square | F Ratio |
| Model | 2 | 5685167.9 | 2842584 | 497522.3 |
| Error | 21 | 120.0 | 6 | Prob>F |
| C Total | 23 | 5685287.8 | | <.0001 |




| Effect Test | | | | |
|----------------|----------|----|--------|--|
| Sum of Squares | F Ratio | DF | Prob>F | |
| 5533741.1 | 968541.2 | 1 | <.0001 | |



| Effect Test | | | | |
|----------------|---------|----|--------|--|
| Sum of Squares | F Ratio | DF | Prob>F | |
| 1909747.9 | 334253 | 1 | <.0001 | |

FIGURE 70
Estimated Feed to Grate Before and After Data Deletion

Test 1 Unedited



Test 1 Edited





FIGURE 71
Estimated Feed to Grate Before and After Data Deletion

Test 2 Unedited



Test 2 Edited





FIGURE 72
Estimated Feed to Grate Before and After Data Deletion

Test 3 Unedited



Test 3 Edited




FIGURE 73
Estimated Feed to Grate Before and After Data Deletion

Test 4 Unedited

Test 4 Edited






FIGURE 74
Estimated Feed to Grate Before and After Data Deletion

Test 5 Unedited



Test 5 Edited




FIGURE 77
Estimated Feed to Grate Before and After Data Deletion

Test 9 Unedited

Test 9 Edited





FIGURE 78

Plant Validation Tests
Tests 1-6 Feb 7-19, 2000 - 48 hrs/test
Tests 7-9 Mar 3-6, 2000 - 24 hrs/test
5 Test Regions




FIGURE 79

Plant Data:

Correlation Between Primary Cooling Over Bed Pressure and Firing Hood Pressure





FIGURE 80

Plant Data: Primary Cooling Over Bed Pressure Statistics by Test



Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|----------|----------|--------------|
| TEST 1 | 206 | 0.000000 | 0.000000 | 0.00000 |
| TEST 2 | 179 | 0.000000 | 0.000000 | 0.00000 |
| TEST 3 | 224 | -0.00938 | 0.029213 | 0.00195 |
| TEST 4 | 173 | -0.06532 | 0.047734 | 0.00363 |
| TEST 5 | 58 | -0.01207 | 0.032861 | 0.00431 |
| TEST 6 | 154 | 0.000000 | 0.000000 | 0.00000 |
| TEST 7 | 142 | 0.006761 | 0.015599 | 0.00131 |
| TEST 8 | 134 | 0.021791 | 0.011880 | 0.00103 |
| TEST 9 | 125 | 0.009840 | 0.012762 | 0.00114 |

FIGURE 81
Plant Data: Test 1 - Unedited




FIGURE 82
Plant Data: Test 2 - Unedited




FIGURE 83
Plant Data: Test 3 - Unedited




FIGURE 84
Plant Data: Test 4 - Unedited




FIGURE 85
Plant Data: Test 5 - Unedited




FIGURE 86
Plant Data: Test 7 - No Editing






FIGURE 87
Plant Data: Test 1 - Unedited
Process Fan Damper Cycles - 70 min averages




+ — 1A/B DMPR 70 Min Ave
× — 2A DMPR 70 Min Ave
□ — 3A DMPR 70 Min Ave
◇ — 3B DMPR 70 Min Ave

FIGURE 88
Plant Data: Test 2 - Unedited
Process Fan Damper Cycles




+ — 1A/B DMPR 70 Min Ave
x — 2A DMPR 70 Min Ave
□ — 3A DMPR 70 Min Ave
◇ — 3B DMPR 70 Min Ave

Figure 89
Plant Data: Test 3 - Unedited
Process Fan Damper Cycles




+ — 1A/B DMPR 70 Min Ave
x — 2A DMPR 70 Min Ave
□ — 3A DMPR 70 Min Ave
◇ — 3B DMPR 70 Min Ave

FIGURE 90
Plant Data: Test 4 - Unedited
Process Fan Damper Cycles




+ — 1A/B DMPR 70 Min Ave
x — 2A DMPR 70 Min Ave
□ — 3A DMPR 70 Min Ave
◇ — 3B DMPR 70 Min Ave

FIGURE 91
Plant Data: Test 5 - Unedited
Process Fan Damper Cycles



+ — 1A/B DMPR 70 Min Ave
X — 2A DMPR 70 Min Ave
□ — 3A DMPR 70 Min Ave
◇ — 3B DMPR 70 Min Ave

FIGURE 92
Test 7 No Editing
Process Fan Damper Cycles



+ — 1A/B DMPR 70 Min Ave
x — 2A DMPR 70 Min Ave
□ — 3A DMPR 70 Min Ave
◇ — 3B DMPR 70 Min Ave

FIGURE 93

Process Fan Power vs Percent Damper Open

Plant Data: Test 1- Unedited








FIGURE 94
Plant Data: Test 1 - Unedited
Process Fan Power - Relative Deviation from Mean



+ — 1A/B AMP 70 M AVE REL DEV MEAN
x — 2A AMP 70 M AVE REL DEV MEAN
□ — 3A AMP 70 M AVE REL DEV MEAN
◇ — 3B AMP 70 M AVE REL DEV MEAN

FIGURE 95

Plant Data: Test 1 - Unedited

Net Fan Power Relative Deviation from Mean and Recoup A Duct Flow Relative Deviation from Mean




FIGURE 96

Plant Data: Test 2 - Unedited

Net Fan Power Relative Deviation from Mean and Recoup A Duct Flow Relative Deviation from Mean




FIGURE 97

Plant Data: Test 3 - Unedited

Net Fan Power Relative Deviation from Mean and Recoup A Duct Flow Relative Deviation from Mean




FIGURE 98

Plant Data: Test 4 - Unedited

Net Fan Power Relative Deviation from Mean and Recoup A Duct Flow Relative Deviation from Mean




FIGURE 99

Plant Data: Test 5 - Unedited

Net Fan Power Relative Deviation from Mean and Recoup A Duct Flow Relative Deviation from Mean




FIGURE 100

Plant Data: Test 7 - Unedited

Net Fan Power Relative Deviation from Mean and Recoup A Duct Flow Relative Deviation from Mean




FIGURE 101

Plant Data: Test 1 - Unedited

Recoup A Duct Flow Rel. Dev. from Mean and Average Recoup Temperature (Both Ducts) Rel. Dev. from Mean




FIGURE 102

Plant Data: Test 2 - Unedited

Recoup A Duct Flow Rel. Dev. from Mean and Average Recoup Temperature (Both Ducts) Rel. Dev. from Mean




FIGURE 103

Plant Data: Test 3 - Unedited

Recoup A Duct Flow Rel. Dev. from Mean and Average Recoup Temperature (Both Ducts) Rel. Dev. from Mean




FIGURE 104

Plant Data: Test 4 - Unedited

Recoup A Duct Flow Rel. Dev. from Mean and Average Recoup Temperature (Both Ducts) Rel. Dev. from Mean




FIGURE 105

Plant Data: Test 5 - Unedited

Recoup A Duct Flow Rel. Dev. from Mean and Average Recoup Temperature (Both Ducts) Rel. Dev. from Mean




FIGURE 106

Plant Data: Test 7 - Unedited

Recoup A Duct Flow Rel. Dev. from Mean and Average Recoup Temperature (Both Ducts) Rel. Dev. from Mean




FIGURE 107

Plant Data: Test 1 - Unedited

Kiln Secondary Air, Average Recoup, and Vent Stack Temperature Relative Deviation from Mean




FIGURE 108

Plant Data: Test 2 - Unedited

Kiln Secondary Air, Average Recoup, and Vent Stack Temperature Relative Deviation from Mean




FIGURE 109

Plant Data: Test 3 - Unedited

Kiln Secondary Air, Average Recoup, and Vent Stack Temperature Relative Deviation from Mean




FIGURE 110

Plant Data: Test 4 - Unedited

Kiln Secondary Air, Average Recoup, and Vent Stack Temperature Relative Deviation from Mean




FIGURE 111

Plant Data: Test 5 - Unedited

Kiln Secondary Air, Average Recoup, and Vent Stack Temperature Relative Deviation from Mean




FIGURE 112

Plant Data: Test 7 - Unedited

Kiln Secondary Air, Average Recoup, and Vent Stack Temperature Relative Deviation from Mean






FIGURE 113

Plant Data: Test 1-9 Edited Composite Estimated Line 6 Roll Feeder Returns and Line 6 Feed to Grate



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 73.9209 | 5.92328 | 0.4127 |
| TEST 2 | 179 | 70.7067 | 5.41186 | 0.4045 |
| TEST 3 | 224 | 69.8040 | 7.97971 | 0.5332 |
| TEST 4 | 173 | 64.0324 | 4.06511 | 0.3091 |
| TEST 5 | 58 | 69.5069 | 8.45919 | 1.1107 |
| TEST 6 | 154 | 55.7146 | 5.93166 | 0.4780 |
| TEST 7 | 142 | 53.7209 | 5.80800 | 0.4874 |
| TEST 8 | 134 | 46.9514 | 5.15960 | 0.4457 |
| TEST 9 | 125 | 49.8272 | 4.15631 | 0.3718 |



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 469.308 | 5.5837 | 0.3890 |
| TEST 2 | 179 | 472.964 | 5.8450 | 0.4369 |
| TEST 3 | 224 | 470.490 | 9.5197 | 0.6361 |
| TEST 4 | 173 | 475.698 | 6.1862 | 0.4703 |
| TEST 5 | 58 | 471.826 | 10.8552 | 1.4254 |
| TEST 6 | 154 | 483.778 | 6.8784 | 0.5543 |
| TEST 7 | 142 | 503.990 | 4.7581 | 0.3993 |
| TEST 8 | 134 | 504.556 | 7.4950 | 0.6475 |
| TEST 9 | 125 | 504.253 | 5.2644 | 0.4726 |

FIGURE 114
Plant Data: Test 1-9 Edited Composite
DD1 Overbed Temperature and DD2 Overbed Temperature



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 646.017 | 5.2430 | 0.3653 |
| TEST 2 | 179 | 653.650 | 4.2149 | 0.3150 |
| TEST 3 | 224 | 652.494 | 6.9067 | 0.4615 |
| TEST 4 | 173 | 684.217 | 23.4025 | 1.7793 |
| TEST 5 | 58 | 692.516 | 21.9736 | 2.8653 |
| TEST 6 | 154 | 651.389 | 7.0619 | 0.5691 |
| TEST 7 | 142 | 649.085 | 6.2370 | 0.5234 |
| TEST 8 | 134 | 654.873 | 4.4997 | 0.3887 |
| TEST 9 | 125 | 655.608 | 5.5633 | 0.4976 |



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 962.75 | 33.1697 | 2.311 |
| TEST 2 | 179 | 1044.35 | 27.9847 | 2.092 |
| TEST 3 | 224 | 1009.73 | 39.4599 | 2.637 |
| TEST 4 | 173 | 1118.15 | 26.3102 | 2.000 |
| TEST 5 | 58 | 1104.89 | 88.4127 | 11.609 |
| TEST 6 | 154 | 1022.36 | 27.3763 | 2.206 |
| TEST 7 | 142 | 1111.86 | 31.2951 | 2.626 |
| TEST 8 | 134 | 1129.62 | 27.9166 | 2.412 |
| TEST 9 | 125 | 1224.37 | 31.3131 | 2.801 |

FIGURE 115
Plant Data: Test 1-9 Edited Composite
DD1 Overbed Pressure and DD2 Overbed Pressure



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|----------|----------|--------------|
| TEST 1 | 208 | -0.59854 | 0.114542 | 0.00798 |
| TEST 2 | 179 | -0.52737 | 0.196541 | 0.01469 |
| TEST 3 | 224 | -0.52088 | 0.197420 | 0.01319 |
| TEST 4 | 173 | -0.1341 | 0.422539 | 0.03213 |
| TEST 5 | 58 | -0.51552 | 0.169418 | 0.02225 |
| TEST 6 | 154 | -0.58701 | 0.151550 | 0.01221 |
| TEST 7 | 142 | -0.63803 | 0.038449 | 0.00323 |
| TEST 8 | 134 | -0.60246 | 0.140356 | 0.01212 |
| TEST 9 | 125 | -0.62856 | 0.079613 | 0.00712 |



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|----------|----------|--------------|
| TEST 1 | 208 | -1.23786 | 0.058629 | 0.00408 |
| TEST 2 | 179 | -1.21620 | 0.064608 | 0.00483 |
| TEST 3 | 224 | -1.39196 | 0.129253 | 0.00864 |
| TEST 4 | 173 | -1.47803 | 0.111453 | 0.00847 |
| TEST 5 | 58 | -1.48278 | 0.121595 | 0.01597 |
| TEST 6 | 154 | -1.24481 | 0.066708 | 0.00538 |
| TEST 7 | 142 | -1.24817 | 0.047440 | 0.00398 |
| TEST 8 | 134 | -1.24037 | 0.057601 | 0.00498 |
| TEST 9 | 125 | -1.24384 | 0.046763 | 0.00418 |

FIGURE 116
Plant Data: Test 1-9 Edited Composite
Preheat Fan Damper Controlling Thermocouples



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 960.159 | 13.9817 | 0.9519 |
| TEST 2 | 179 | 964.732 | 14.2398 | 1.0643 |
| TEST 3 | 224 | 965.180 | 17.7619 | 1.1868 |
| TEST 4 | 173 | 956.408 | 20.1314 | 1.5308 |
| TEST 5 | 58 | 964.016 | 15.5442 | 2.0411 |
| TEST 6 | 154 | 949.660 | 14.0279 | 1.1304 |
| TEST 7 | 142 | 955.162 | 21.5455 | 1.8081 |
| TEST 8 | 134 | 965.239 | 14.7466 | 1.2739 |
| TEST 9 | 125 | 963.720 | 16.7946 | 1.5022 |



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 970.215 | 13.8116 | 0.9623 |
| TEST 2 | 179 | 980.137 | 13.4515 | 1.0054 |
| TEST 3 | 224 | 978.956 | 18.9839 | 1.1348 |
| TEST 4 | 173 | 977.052 | 13.9485 | 1.0605 |
| TEST 5 | 58 | 977.117 | 16.7051 | 2.1935 |
| TEST 6 | 154 | 962.021 | 17.2184 | 1.3875 |
| TEST 7 | 142 | 962.944 | 12.7451 | 1.0695 |
| TEST 8 | 134 | 965.575 | 13.6725 | 1.1811 |
| TEST 9 | 125 | 963.264 | 16.1536 | 1.4448 |

FIGURE 117
Plant Data: Test 1-9 Edited Composite
Recoup A Duct Flow and Thermocouple Temperature



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 2766.80 | 77.129 | 5.374 |
| TEST 2 | 179 | 2474.06 | 110.143 | 8.232 |
| TEST 3 | 224 | 2377.27 | 102.904 | 6.876 |
| TEST 4 | 173 | 2297.72 | 67.845 | 5.188 |
| TEST 5 | 58 | 2470.04 | 107.852 | 14.162 |
| TEST 6 | 154 | 2842.34 | 89.980 | 7.251 |
| TEST 7 | 142 | 2687.48 | 70.864 | 5.947 |
| TEST 8 | 134 | 2678.79 | 85.012 | 7.344 |
| TEST 9 | 125 | 2643.46 | 64.822 | 5.798 |



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 1250.12 | 44.002 | 3.066 |
| TEST 2 | 179 | 1226.86 | 49.237 | 3.680 |
| TEST 3 | 224 | 1241.27 | 47.848 | 3.197 |
| TEST 4 | 173 | 1466.15 | 52.099 | 3.961 |
| TEST 5 | 58 | 1360.51 | 173.627 | 22.798 |
| TEST 6 | 154 | 1226.45 | 60.463 | 4.872 |
| TEST 7 | 142 | 1394.46 | 45.573 | 3.824 |
| TEST 8 | 134 | 1388.69 | 57.426 | 4.961 |
| TEST 9 | 125 | 1474.59 | 49.200 | 4.401 |

FIGURE 118
Plant Data: Test 1-9 Edited Composite
Average Recoup Temp and Total Preheat Flow



Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 1308.72 | 41.273 | 2.878 |
| TEST 2 | 179 | 1331.72 | 44.628 | 3.338 |
| TEST 3 | 224 | 1320.87 | 38.122 | 2.547 |
| TEST 4 | 173 | 1535.54 | 42.834 | 3.257 |
| TEST 5 | 58 | 1484.00 | 156.842 | 20.568 |
| TEST 6 | 154 | 1321.47 | 53.528 | 4.313 |
| TEST 7 | 142 | 1484.94 | 41.732 | 3.502 |
| TEST 8 | 134 | 1493.28 | 44.409 | 3.838 |
| TEST 9 | 125 | 1569.48 | 42.013 | 3.758 |




Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 18424.5 | 348.145 | 24.256 |
| TEST 2 | 179 | 18689.2 | 363.008 | 27.133 |
| TEST 3 | 224 | 19070.0 | 408.528 | 27.296 |
| TEST 4 | 173 | 19741.6 | 530.285 | 40.317 |
| TEST 5 | 58 | 19446.5 | 340.182 | 44.668 |
| TEST 6 | 154 | 18931.9 | 483.805 | 37.374 |
| TEST 7 | 142 | 18516.1 | 293.417 | 24.623 |
| TEST 8 | 134 | 18425.0 | 383.861 | 33.161 |
| TEST 9 | 125 | 18486.8 | 374.779 | 33.521 |


FIGURE 119

Plant Data: Test 1-9 Edited Composite Waste Gas Fan (2A) Flow and Primary Cooling Fan (3A) Flow



Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 25440.5 | 1435.69 | 100.03 |
| TEST 2 | 179 | 25976.6 | 1624.59 | 121.43 |
| TEST 3 | 224 | 26011.1 | 1996.91 | 133.42 |
| TEST 4 | 173 | 25730.8 | 1544.26 | 117.41 |
| TEST 5 | 58 | 26157.7 | 1510.40 | 198.33 |
| TEST 6 | 154 | 26098.8 | 1523.49 | 122.77 |
| TEST 7 | 142 | 25011.1 | 1491.70 | 124.34 |
| TEST 8 | 134 | 24870.4 | 1563.93 | 135.10 |
| TEST 9 | 125 | 24810.7 | 1444.64 | 129.21 |




Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 13618.7 | 461.852 | 32.179 |
| TEST 2 | 179 | 13033.7 | 465.078 | 34.762 |
| TEST 3 | 224 | 14035.2 | 203.320 | 13.585 |
| TEST 4 | 173 | 11701.9 | 324.108 | 24.641 |
| TEST 5 | 58 | 11620.8 | 310.654 | 40.791 |
| TEST 6 | 154 | 13328.8 | 599.247 | 48.289 |
| TEST 7 | 142 | 13058.4 | 429.524 | 36.045 |
| TEST 8 | 134 | 13683.3 | 843.108 | 72.833 |
| TEST 9 | 125 | 12835.2 | 676.216 | 60.483 |

FIGURE 120


Plant Data: Test 1-9 Edited Composite

Secondary Cooling Fan (3B) Correction Factor and Cooler Fan Inlet Temperature



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|----------|--------------|
| TEST 1 | 206 | 1.33000 | 0 | 0 |
| TEST 2 | 179 | 1.25000 | 0 | 0 |
| TEST 3 | 224 | 1.19000 | 0 | 0 |
| TEST 4 | 173 | 1.28000 | 0 | 0 |
| TEST 5 | 58 | 1.24000 | 0 | 0 |
| TEST 6 | 154 | 1.26000 | 8.512e-8 | 6.86e-9 |
| TEST 7 | 142 | 1.30000 | 0 | 0 |
| TEST 8 | 134 | 1.31000 | 0 | 0 |
| TEST 9 | 125 | 1.26000 | 3.706e-8 | 3.32e-9 |



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 19.7374 | 10.2001 | 0.71068 |
| TEST 2 | 179 | 11.5704 | 5.7356 | 0.42870 |
| TEST 3 | 224 | 3.2402 | 8.8992 | 0.59460 |
| TEST 4 | 173 | 7.8358 | 5.8442 | 0.44433 |
| TEST 5 | 58 | 9.5845 | 4.0206 | 0.52792 |
| TEST 6 | 154 | 14.7091 | 8.5464 | 0.68869 |
| TEST 7 | 142 | 42.5282 | 9.5707 | 0.80316 |
| TEST 8 | 134 | 44.8119 | 8.9223 | 0.77077 |
| TEST 9 | 125 | 48.8000 | 9.2012 | 0.82208 |

FIGURE 121
Plant Data: Test 1-9 Edited Composite
Secondary Cooling Fan (3B) Uncorrected and Corrected Flow



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 10571.0 | 214.978 | 14.978 |
| TEST 2 | 179 | 12123.9 | 232.118 | 17.349 |
| TEST 3 | 224 | 8481.0 | 289.931 | 19.372 |
| TEST 4 | 173 | 10919.9 | 269.656 | 20.502 |
| TEST 5 | 58 | 12511.9 | 163.769 | 21.504 |
| TEST 6 | 154 | 11847.7 | 184.280 | 14.850 |
| TEST 7 | 142 | 11523.6 | 352.500 | 29.581 |
| TEST 8 | 134 | 11379.2 | 190.683 | 16.472 |
| TEST 9 | 125 | 12208.3 | 187.443 | 16.765 |



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 14059.5 | 285.919 | 19.921 |
| TEST 2 | 179 | 15154.9 | 290.147 | 21.687 |
| TEST 3 | 224 | 10092.4 | 345.018 | 23.052 |
| TEST 4 | 173 | 13977.5 | 345.159 | 28.242 |
| TEST 5 | 58 | 15514.8 | 203.073 | 26.665 |
| TEST 6 | 154 | 14928.1 | 232.193 | 18.711 |
| TEST 7 | 142 | 14980.7 | 458.250 | 38.456 |
| TEST 8 | 134 | 14906.8 | 249.794 | 21.579 |
| TEST 9 | 125 | 15382.5 | 236.178 | 21.124 |

FIGURE 122
Plant Data: Test 1-9 Edited Composite
Waste Gas Fan (2A) and Average Preheat Fan (1A/B) Amps



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 362.989 | 13.6664 | 0.9522 |
| TEST 2 | 179 | 374.059 | 13.4738 | 1.0071 |
| TEST 3 | 224 | 380.375 | 11.6554 | 0.7788 |
| TEST 4 | 173 | 378.894 | 6.7397 | 0.5124 |
| TEST 5 | 58 | 378.450 | 12.4175 | 1.6305 |
| TEST 6 | 154 | 369.245 | 15.6343 | 1.2598 |
| TEST 7 | 142 | 354.831 | 12.0295 | 1.0095 |
| TEST 8 | 134 | 351.015 | 15.7260 | 1.3585 |
| TEST 9 | 125 | 343.792 | 13.3007 | 1.1896 |



Means and Std Deviations


| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 141.172 | 1.99842 | 0.13924 |
| TEST 2 | 179 | 143.826 | 2.80542 | 0.20969 |
| TEST 3 | 224 | 145.122 | 3.66312 | 0.24475 |
| TEST 4 | 173 | 148.858 | 6.83311 | 0.51951 |
| TEST 5 | 58 | 140.478 | 5.10136 | 0.66984 |
| TEST 6 | 154 | 143.812 | 2.78699 | 0.22458 |
| TEST 7 | 142 | 139.743 | 2.19666 | 0.18434 |
| TEST 8 | 134 | 139.888 | 2.45535 | 0.21211 |
| TEST 9 | 125 | 139.036 | 2.05781 | 0.18406 |

FIGURE 123
Plant Data: Test 1-9 Edited Composite
Primary Cooling Fan (3A) and Secondary Cooling Fan (3B) Amps



Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 121.846 | 2.83309 | 0.19739 |
| TEST 2 | 179 | 120.139 | 2.68726 | 0.20086 |
| TEST 3 | 224 | 126.924 | 0.46945 | 0.03137 |
| TEST 4 | 173 | 110.586 | 1.44160 | 0.10960 |
| TEST 5 | 58 | 110.772 | 0.58333 | 0.07680 |
| TEST 6 | 154 | 120.921 | 2.06233 | 0.16619 |
| TEST 7 | 142 | 115.190 | 2.62809 | 0.22054 |
| TEST 8 | 134 | 115.978 | 3.88842 | 0.33591 |
| TEST 9 | 125 | 110.240 | 3.33215 | 0.29804 |




Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 116.637 | 2.80957 | 0.19575 |
| TEST 2 | 179 | 125.253 | 1.69736 | 0.12687 |
| TEST 3 | 224 | 109.008 | 1.87447 | 0.12524 |
| TEST 4 | 173 | 119.320 | 1.29972 | 0.09882 |
| TEST 5 | 58 | 128.053 | 0.54747 | 0.07189 |
| TEST 6 | 154 | 123.236 | 1.57819 | 0.12717 |
| TEST 7 | 142 | 119.176 | 2.66392 | 0.22355 |
| TEST 8 | 134 | 117.799 | 1.16193 | 0.10038 |
| TEST 9 | 125 | 124.250 | 1.63501 | 0.14031 |

FIGURE 124


Plant Data: Test 1-9 Edited Composite Cooler Vent Stack Flow and Thermocouple Temperature



Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 10890.6 | 653.62 | 45.54 |
| TEST 2 | 179 | 8710.3 | 1051.27 | 78.58 |
| TEST 3 | 224 | 10357.0 | 702.52 | 46.94 |
| TEST 4 | 173 | 11363.9 | 625.56 | 47.56 |
| TEST 5 | 58 | 9185.5 | 968.32 | 127.15 |
| TEST 6 | 154 | 10997.2 | 813.75 | 65.57 |
| TEST 7 | 142 | 11745.1 | 366.39 | 30.75 |
| TEST 8 | 134 | 11351.8 | 679.19 | 58.67 |
| TEST 9 | 125 | 12179.8 | 863.58 | 77.24 |

VENT STACK TMP By Column 1





Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|---------|---------|--------------|
| TEST 1 | 206 | 691.124 | 30.4233 | 2.120 |
| TEST 2 | 179 | 604.971 | 29.2598 | 2.187 |
| TEST 3 | 224 | 723.954 | 35.1280 | 2.347 |
| TEST 4 | 173 | 765.403 | 35.2013 | 2.676 |
| TEST 5 | 58 | 643.569 | 98.7663 | 12.969 |
| TEST 6 | 154 | 630.785 | 37.5023 | 3.022 |
| TEST 7 | 142 | 694.394 | 29.0482 | 2.438 |
| TEST 8 | 134 | 708.291 | 29.5706 | 2.555 |
| TEST 9 | 125 | 747.728 | 38.8725 | 3.477 |

FIGURE 125

Waste Gas Fan Amps vs Damper Position

Waste Gas Fan Amps vs Preheat Fan Amps



Polynomial Fit degree=2

$$2A \text{ AMPS} = 241.372 + 3.21127 \text{ 2A DMPR \% OPN} - 0.01794 \text{ 2A DMPR \% OPN}^2$$

Polynomial Fit degree=2

$$2A \text{ AMPS} = -4854.3 + 69.2842 \text{ AVE 1A/B AMPS} - 0.2289 \text{ AVE 1A/B AMPS}^2$$

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.92076 |
| RSquare Adj | 0.920646 |
| Root Mean Square Error | 4.992376 |
| Mean of Response | 366.8064 |
| Observations (or Sum Wgts) | 1395 |

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.560684 |
| RSquare Adj | 0.560052 |
| Root Mean Square Error | 11.75501 |
| Mean of Response | 366.8064 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | 241.37226 | 2.023423 | 119.29 | 0.0000 |
| 2A DMPR % OPN | 3.2112699 | 0.064053 | 50.13 | 0.0000 |
| 2A DMPR % OPN^2 | -0.017944 | 0.000459 | -39.10 | <.0001 |

Analysis of Variance

Parameter Estimates


| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | -4854.291 | 227.8074 | -21.31 | <.0001 |
| AVE 1A/B AMPS | 69.28415 | 3.128982 | 22.14 | <.0001 |
| AVE 1A/B AMPS^2 | -0.228896 | 0.010735 | -21.32 | <.0001 |

FIGURE 126

Waste Gas Fan Flows vs Damper Position

Waste Gas Fan Flow vs Amps

2A FLOW By 2A DMPR % OPN



Linear Fit

Linear Fit

$$2A \text{ FLOW} = 24066.2 + 22.6845 \text{ 2A DMPR \% OPN}$$

Summary of Fit


| | |
|----------------------------|----------|
| RSquare | 0.093596 |
| RSquare Adj | 0.092945 |
| Root Mean Square Error | 1592.281 |
| Mean of Response | 25584.48 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|---------------|-----------|-----------|---------|---------|
| Intercept | 24066.175 | 133.5808 | 180.16 | 0.0000 |
| 2A DMPR % OPN | 22.68448 | 1.891413 | 11.99 | <.0001 |

2A FLOW By 2A AMPS



Linear Fit

Linear Fit

$$2A \text{ FLOW} = 11730.6 + 37.769 \text{ 2A AMPS}$$

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.160292 |
| RSquare Adj | 0.159689 |
| Root Mean Square Error | 1532.579 |
| Mean of Response | 25584.48 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates


| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | 11730.563 | 850.5736 | 13.79 | <.0001 |
| 2A AMPS | 37.76903 | 2.316163 | 16.31 | <.0001 |

FIGURE 127

DD1 Wind Box Pressure vs Waste Gas Fan Damper

DD1 Wind Box Pressure vs Waste Gas Fan Amps

DD1 UBED PRESS By 2A DMPR % OPN



— Polynomial Fit degree=2

Polynomial Fit degree=2

$$\text{DD1 UBED PRESS} = -3.353 \hat{+} 0.16761 \text{ 2A DMPR \% OPN} + 0.00091 \text{ 2A DMPR \% OPN}^2$$

Summary of Fit


| | |
|----------------------------|----------|
| RSquare | 0.72204 |
| RSquare Adj | 0.721641 |
| Root Mean Square Error | 0.597606 |
| Mean of Response | -10.0283 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | -3.353023 | 0.242211 | -13.84 | <.0001 |
| 2A DMPR % OPN | -0.167612 | 0.007667 | -21.86 | <.0001 |
| 2A DMPR % OPN^2 | 0.0009109 | 0.000055 | 16.58 | <.0001 |

DD1 UBED PRESS By 2A AMPS



— Polynomial Fit degree=2

Polynomial Fit degree=2

$$\text{DD1 UBED PRESS} = 62.8015 \hat{+} 0.34897 \text{ 2A AMPS} + 0.00041 \text{ 2A AMPS}^2$$

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.662716 |
| RSquare Adj | 0.662231 |
| Root Mean Square Error | 0.658296 |
| Mean of Response | -10.0283 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance


Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | 62.801486 | 8.018029 | 7.83 | <.0001 |
| 2A AMPS | -0.348972 | 0.044188 | -7.90 | <.0001 |
| 2A AMPS^2 | 0.0004091 | 0.000061 | 6.73 | <.0001 |

FIGURE 128

DD1 Overbed Temp vs Ave Preheat Fan Temp

DD2 Overbed Temp vs Average Recoup Thermocouple Temp



— Linear Fit

Linear Fit

DD1 OBED TMP = -37.311 + 1.0311 AVG 1A/B TMP


Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.946782 |
| RSquare Adj | 0.946744 |
| Root Mean Square Error | 3.94792 |
| Mean of Response | 657.3226 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|--------------|-----------|-----------|---------|---------|
| Intercept | -37.31052 | 4.413768 | -8.45 | <.0001 |
| AVG 1A/B TMP | 1.0311009 | 0.00655 | 157.42 | 0.0000 |



— Polynomial Fit degree=2

Polynomial Fit degree=2

DD2 OBED TMP = 997.042 + 0.56759 AVG REC TMP + 0.00044 AVG REC TMP^2

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.810464 |
| RSquare Adj | 0.810192 |
| Root Mean Square Error | 36.09706 |
| Mean of Response | 1067.176 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates


| Term | Estimate | Std Error | t Ratio | Prob> t |
|---------------|-----------|-----------|---------|---------|
| Intercept | 997.04189 | 96.17582 | 10.37 | <.0001 |
| AVG REC TMP | -0.567595 | 0.137241 | -4.14 | <.0001 |
| AVG REC TMP^2 | 0.0004355 | 0.000049 | 8.92 | <.0001 |

FIGURE 129

DD1 Overbed Pressure vs Waste Gas Fan Amps

DD1 Overbed Pressure vs Average Preheat Fan Amps

DD1 OBED PRESS By 2A AMPS



— Polynomial Fit degree=2

Polynomial Fit degree=2

$$\text{DD1 OBED PRESS} = 8.7406 \hat{u} 0.05695 \text{ 2A AMPS} + 0.00009 \text{ 2A AMPS}^2$$

Summary of Fit


| | |
|----------------------------|----------|
| RSquare | 0.168915 |
| RSquare Adj | 0.167721 |
| Root Mean Square Error | 0.23158 |
| Mean of Response | -0.52172 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | 8.740596 | 2.819931 | 3.10 | 0.0020 |
| 2A AMPS | -0.056948 | 0.015545 | -3.66 | 0.0003 |
| 2A AMPS^2 | 0.0000862 | 0.000021 | 4.03 | <.0001 |

DD1 OBED PRESS By AVE 1A/B AMPS



— Polynomial Fit degree=2

Polynomial Fit degree=2

$$\text{DD1 OBED PRESS} = 47.8969 \hat{u} 0.70986 \text{ AVE 1A/B AMPS} + 0.00259 \text{ AVE 1A/B AMPS}^2$$

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.739039 |
| RSquare Adj | 0.738664 |
| Root Mean Square Error | 0.129767 |
| Mean of Response | -0.52172 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance



Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | 47.896937 | 2.514841 | 19.05 | <.0001 |
| AVE 1A/B AMPS | -0.709863 | 0.034542 | -20.55 | <.0001 |
| AVE 1A/B AMPS^2 | 0.0025943 | 0.000119 | 21.89 | <.0001 |

FIGURE 130

DD1 Overbed Pressure vs Wind Box Pressure

DD2 Overbed Pressure vs Wind Box Pressure



Polynomial Fit degree=2

$$DD1\ OBED\ PRESS = 4.15512 + 1.07511\ DD1\ UBED\ PRESS + 0.05994\ DD1\ UBED\ PRESS^2$$

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.425926 |
| RSquare Adj | 0.425101 |
| Root Mean Square Error | 0.192469 |
| Mean of Response | -0.52172 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

| | | | | | |
|--------|----------------|------|-------------|-------|----------|
| Source | Sum of Squares | df | Mean Square | F | Prob > F |
| Model | 0.3011 | 2 | 0.1505 | 15.48 | <.0001 |
| Error | 0.3989 | 1393 | 0.2863 | | |
| Total | 0.7000 | 1395 | | | |

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|------------------|-----------|-----------|---------|---------|
| Intercept | 4.1551242 | 0.344911 | 12.05 | <.0001 |
| DD1 UBED PRESS | 1.0751124 | 0.06943 | 15.48 | <.0001 |
| DD1 UBED PRESS^2 | 0.0599389 | 0.003465 | 17.30 | <.0001 |

Polynomial Fit degree=2

$$DD2\ OBED\ PRESS = 1.19359 + 0.45846\ DD1\ UBED\ PRESS + 0.02063\ DD1\ UBED\ PRESS^2$$

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.221529 |
| RSquare Adj | 0.220411 |
| Root Mean Square Error | 0.113275 |
| Mean of Response | -1.30239 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

| | | | | | |
|--------|----------------|------|-------------|------|----------|
| Source | Sum of Squares | df | Mean Square | F | Prob > F |
| Model | 0.0301 | 2 | 0.0150 | 5.88 | <.0001 |
| Error | 0.1089 | 1393 | 0.0778 | | |
| Total | 0.1390 | 1395 | | | |


Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|------------------|-----------|-----------|---------|---------|
| Intercept | 1.1935875 | 0.202993 | 5.88 | <.0001 |
| DD1 UBED PRESS | 0.4584617 | 0.040862 | 11.22 | <.0001 |
| DD1 UBED PRESS^2 | 0.0206346 | 0.002039 | 10.12 | <.0001 |

FIGURE 131

Recoup A Duct Flow vs Thermocouple Temperature

Recoup A Duct Flow vs Preheat Fan Amps



— Linear Fit

Linear Fit

$$\text{REC A FLOW} = 3255.19 - 0.51281 \text{ REC A TMP}$$


Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.084996 |
| RSquare Adj | 0.084339 |
| Root Mean Square Error | 194.431 |
| Mean of Response | 2576.936 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | 3255.1855 | 59.85139 | 54.39 | 0.0000 |
| REC A TMP | -0.512808 | 0.045081 | -11.38 | <.0001 |



— Polynomial Fit degree=2

Polynomial Fit degree=2

$$\text{REC A FLOW} = -2.31e4 + 367.884 \text{ AVE 1A/B AMPS} - 1.31498 \text{ AVE 1A/B AMPS}^2$$

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.147556 |
| RSquare Adj | 0.146331 |
| Root Mean Square Error | 187.734 |
| Mean of Response | 2576.936 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates


| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | -23117.32 | 3638.211 | -6.35 | <.0001 |
| AVE 1A/B AMPS | 367.88409 | 49.97159 | 7.36 | <.0001 |
| AVE 1A/B AMPS^2 | -1.31498 | 0.17144 | -7.67 | <.0001 |

FIGURE 132

Preheat Fan Amps vs Damper Position

Total Preheat Flow vs Average Preheat Fan Amps

AVE 1A/B AMPS By AVE PH DMPR % OPN



— Polynomial Fit degree=2

Polynomial Fit degree=2

$$\text{AVE 1A/B AMPS} = 135.882 + 0.08283 \text{ AVE PH DMPR \% OPN} + 0.00475 \text{ AVE PH DMPR \% OPN}^2$$

Summary of Fit


| | |
|----------------------------|----------|
| RSquare | 0.720911 |
| RSquare Adj | 0.72051 |
| Root Mean Square Error | 2.343318 |
| Mean of Response | 142.6542 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|---------------------|-----------|-----------|---------|---------|
| Intercept | 135.88183 | 1.38951 | 97.79 | 0.0000 |
| AVE PH DMPR % OPN | -0.082831 | 0.054618 | -1.52 | 0.1296 |
| AVE PH DMPR % OPN^2 | 0.0047507 | 0.000521 | 9.12 | <.0001 |

TOT PH FLOW By AVE 1A/B AMPS



— Linear Fit

Linear Fit

$$\text{TOT PH FLOW} = 5838.79 + 91.1302 \text{ AVE 1A/B AMPS}$$

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.463373 |
| RSquare Adj | 0.462988 |
| Root Mean Square Error | 434.8474 |
| Mean of Response | 18838.91 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance



Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|---------------|-----------|-----------|---------|---------|
| Intercept | 5838.7943 | 375.0175 | 15.57 | <.0001 |
| AVE 1A/B AMPS | 91.130228 | 2.627589 | 34.68 | <.0001 |

FIGURE 133

Preheat Overbed Pressure vs Average Damper Position

Preheat Overbed Pressure vs Average Amps



Linear Fit

PH OBED PRESS = 0.04769 + 0.01142 AVE PH DMPR % OPN

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.589975 |
| RSquare Adj | 0.589681 |
| Root Mean Square Error | 0.086102 |
| Mean of Response | -0.48224 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-------------------|-----------|-----------|---------|---------|
| Intercept | 0.0476862 | 0.012059 | 3.95 | <.0001 |
| AVE PH DMPR % OPN | -0.011421 | 0.000255 | -44.77 | <.0001 |

Linear Fit

PH OBED PRESS = 2.37675 + 0.02004 AVE 1A/B AMPS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.436769 |
| RSquare Adj | 0.436364 |
| Root Mean Square Error | 0.100914 |
| Mean of Response | -0.48224 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance


Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|---------------|-----------|-----------|---------|---------|
| Intercept | 2.3767526 | 0.087029 | 27.31 | <.0001 |
| AVE 1A/B AMPS | -0.020041 | 0.00061 | -32.87 | <.0001 |

FIGURE 134

Preheat Overbed Pressure vs Wind Box Pressure

Preheat Wind Box Pressure vs Average Amps



Linear Fit

PH OBED PRESS = 0.11502 + 0.06218 PH UBED PRESS


Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.391368 |
| RSquare Adj | 0.390931 |
| Root Mean Square Error | 0.104902 |
| Mean of Response | -0.48224 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|---------------|-----------|-----------|---------|---------|
| Intercept | 0.1150173 | 0.020152 | 5.71 | <.0001 |
| PH UBED PRESS | 0.062177 | 0.002077 | 29.93 | <.0001 |



Linear Fit

PH UBED PRESS = 27.8831 - 0.26279 AVE 1A/B AMPS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.74183 |
| RSquare Adj | 0.741644 |
| Root Mean Square Error | 0.68742 |
| Mean of Response | -9.6057 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance



Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|---------------|-----------|-----------|---------|---------|
| Intercept | 27.883109 | 0.592839 | 47.03 | <.0001 |
| AVE 1A/B AMPS | -0.262795 | 0.004154 | -63.27 | 0.0000 |

FIGURE 135

Total Preheat Fan Flow vs Wind Box Pressure

Firing Hood Pressure vs Preheat Overbed Pressure



Linear Fit

TOT PH FLOW = 15701.2 - 326.65 PH UBED PRESS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.554243 |
| RSquare Adj | 0.553923 |
| Root Mean Square Error | 396.3237 |
| Mean of Response | 18838.91 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|---------------|-----------|-----------|---------|---------|
| Intercept | 15701.21 | 76.1367 | 206.22 | 0.0000 |
| PH UBED PRESS | -326.6495 | 7.848844 | -41.62 | <.0001 |

Linear Fit

FIRING HD PRESS = 0.25286 + 0.71675 PH OBED PRESS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.716965 |
| RSquare Adj | 0.716762 |
| Root Mean Square Error | 0.060554 |
| Mean of Response | -0.09278 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance



Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|---------------|-----------|-----------|---------|---------|
| Intercept | 0.2528597 | 0.00604 | 41.86 | <.0001 |
| PH OBED PRESS | 0.7167459 | 0.012066 | 59.40 | 0.0000 |

FIGURE 136

Primary Cooling Fan Flow vs Average Preheat Fan Amps

Primary Cooling Fan Flow vs Firing Hood Pressure



Polynomial Fit degree=2

3A FLOW = -227097 + 3306.13 AVE 1A/B AMPS + 11.3599 AVE 1A/B AMPS^2

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.13796 |
| RSquare Adj | 0.136721 |
| Root Mean Square Error | 834.7431 |
| Mean of Response | 13136.69 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | -227098.7 | 18176.99 | -14.04 | <.0001 |
| AVE 1A/B AMPS | 3306.1258 | 222.1944 | 14.88 | <.0001 |
| AVE 1A/B AMPS^2 | -11.35989 | 0.762295 | -14.90 | <.0001 |

Linear Fit

3A FLOW = 13494.9 + 3860.71 FIRING HD PRESS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.239063 |
| RSquare Adj | 0.238516 |
| Root Mean Square Error | 783.9848 |
| Mean of Response | 13136.69 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance



Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | 13494.891 | 27.0884 | 498.18 | 0.0000 |
| FIRING HD PRESS | 3860.7064 | 184.5482 | 20.92 | <.0001 |

FIGURE 137

Net Flow to Kiln vs Firing Hood Pressure

Net Flow to Kiln vs Average Preheat Fan Amps



Linear Fit
 NET FLOW TO KILN = 11814.5 + 8693.54 FIRING HD PRESS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.265066 |
| RSquare Adj | 0.264538 |
| Root Mean Square Error | 1647.654 |
| Mean of Response | 11007.94 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | 11814.536 | 56.93005 | 207.53 | 0.0000 |
| FIRING HD PRESS | 8693.5353 | 387.8539 | 22.41 | <.0001 |

Linear Fit
 NET FLOW TO KILN = 16749.3 - 40.2467 AVE 1A/B AMPS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.008622 |
| RSquare Adj | 0.00791 |
| Root Mean Square Error | 1913.645 |
| Mean of Response | 11007.94 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance


Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|---------------|-----------|-----------|---------|---------|
| Intercept | 16749.304 | 1650.35 | 10.15 | <.0001 |
| AVE 1A/B AMPS | -40.24673 | 11.56331 | -3.48 | 0.0005 |

FIGURE 138

Kiln Exit Gas Temperature vs Net Flow to Kiln

Kiln Solids Discharge Temperature vs Net Flow to Kiln



Linear Fit

KILN EXIT TMP = 2201.67 + 0.00742 NET FLOW TO KILN


Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.15505 |
| RSquare Adj | 0.154444 |
| Root Mean Square Error | 33.27373 |
| Mean of Response | 2283.304 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|------------------|-----------|-----------|---------|---------|
| Intercept | 2201.6666 | 5.183242 | 424.77 | 0.0000 |
| NET FLOW TO KILN | 0.0074162 | 0.000464 | 15.99 | <.0001 |



Linear Fit

KLN SOL DSCHG TMP = 2263.03 + 0.00164 NET FLOW TO KILN

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.022441 |
| RSquare Adj | 0.02174 |
| Root Mean Square Error | 20.78812 |
| Mean of Response | 2281.051 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance


Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|------------------|-----------|-----------|---------|---------|
| Intercept | 2263.0286 | 3.235171 | 699.51 | 0.0000 |
| NET FLOW TO KILN | 0.0016372 | 0.00029 | 5.65 | <.0001 |

FIGURE 139

Primary Cooling Fan Flow vs Amps

Secondary Cooling Fan Flow (Uncorrected) vs Fan Amps



Linear Fit

3A FLOW = -635.77 + 116.516 3A AMPS


Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.640282 |
| RSquare Adj | 0.640024 |
| Root Mean Square Error | 539.0319 |
| Mean of Response | 13136.69 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | -635.7743 | 276.9633 | -2.30 | 0.0219 |
| 3A AMPS | 116.51626 | 2.33995 | 49.79 | <.0001 |



Polynomial Fit degree=2

Polynomial Fit degree=2

3B FLOW = -100608 + 1688.72 3B AMPS + 6.2946 3B AMPS^2

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.925534 |
| RSquare Adj | 0.925427 |
| Root Mean Square Error | 347.212 |
| Mean of Response | 11020.89 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance


Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | -100607.5 | 3578.386 | -28.12 | <.0001 |
| 3B AMPS | 1688.7161 | 60.91654 | 27.72 | <.0001 |
| 3B AMPS^2 | -6.294596 | 0.258776 | -24.32 | <.0001 |

FIGURE 140

Secondary Cooling Fan Correction Factor vs Amps

Secondary Cooling Fan Flow (Corrected) vs Amps



Polynomial Fit degree=2

$$3B \text{ FLOW CORRECTION} = -11.79 + 0.22047 \text{ 3B AMPS} + 0.00093 \text{ 3B AMPS}^2$$


Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.648438 |
| RSquare Adj | 0.647933 |
| Root Mean Square Error | 0.026029 |
| Mean of Response | 1.268337 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | -11.78987 | 0.268255 | -43.95 | <.0001 |
| 3B AMPS | 0.2204747 | 0.004567 | 48.28 | <.0001 |
| 3B AMPS^2 | -0.000928 | 0.000019 | -47.86 | <.0001 |



Polynomial Fit degree=2

$$\text{CORR 3B FLOW} = -257283 + 4340.33 \text{ 3B AMPS} - 17.2769 \text{ 3B AMPS}^2$$

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.895304 |
| RSquare Adj | 0.895153 |
| Root Mean Square Error | 584.7051 |
| Mean of Response | 14002.97 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates


| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | -257282.7 | 6026.003 | -42.70 | <.0001 |
| 3B AMPS | 4340.3258 | 102.5835 | 42.31 | <.0001 |
| 3B AMPS^2 | -17.27685 | 0.435779 | -39.65 | <.0001 |

FIGURE 141

Recoup A Duct Flow vs Total Cooling Flow

Recoup A Duct Temperature vs Total Cooling Flow

REC A FLOW By 3A+3B CORR FLOW



— Linear Fit

Linear Fit

REC A FLOW = 289.634 + 0.08428 3A+3B CORR FLOW

Summary of Fit


| | |
|----------------------------|----------|
| RSquare | 0.484203 |
| RSquare Adj | 0.483833 |
| Root Mean Square Error | 145.98 |
| Mean of Response | 2576.936 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | 289.63376 | 63.37254 | 4.57 | <.0001 |
| 3A+3B CORR FLOW | 0.084279 | 0.002331 | 36.16 | <.0001 |

REC A TMP By 3A+3B CORR FLOW



— Polynomial Fit degree=2

Polynomial Fit degree=2

REC A TMP = -8255.9 + 0.7242 3A+3B CORR FLOW + 0.00001 3A+3B CORR FLOW^2

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.097138 |
| RSquare Adj | 0.095841 |
| Root Mean Square Error | 109.8413 |
| Mean of Response | 1322.618 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance



Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-------------------|-----------|-----------|---------|---------|
| Intercept | -8255.883 | 783.5539 | -10.54 | <.0001 |
| 3A+3B CORR FLOW | 0.7241981 | 0.059184 | 12.24 | <.0001 |
| 3A+3B CORR FLOW^2 | -0.000014 | 0.000001 | -12.24 | <.0001 |

FIGURE 142

Ave. Recoup Temp (Both Ducts) vs Tot. Cooling Flow

Vent Stack Thermocouple Temperature vs Stack Flow



Polynomial Fit degree=2
 Polynomial Fit degree=2
 AVG REC TMP = -6708.8 + 0.60858 3A+3B CORR FLOW + 0.00001 3A+3B CORR FLOW^2

Linear Fit
 Linear Fit
 VENT STACK TMP = 304.089 + 0.0362 COOL VENT STACK FLOW

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.075938 |
| RSquare Adj | 0.074611 |
| Root Mean Square Error | 109.0164 |
| Mean of Response | 1408.647 |
| Observations (or Sum Wgts) | 1395 |

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.514862 |
| RSquare Adj | 0.514514 |
| Root Mean Square Error | 44.46658 |
| Mean of Response | 692.9882 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-------------------|-----------|-----------|---------|---------|
| Intercept | -6708.82 | 777.6693 | -8.63 | <.0001 |
| 3A+3B CORR FLOW | 0.6085798 | 0.05874 | 10.36 | <.0001 |
| 3A+3B CORR FLOW^2 | -0.000011 | 0.000001 | -10.28 | <.0001 |

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|----------------------|-----------|-----------|---------|---------|
| Intercept | 304.08888 | 10.18392 | 29.86 | <.0001 |
| COOL VENT STACK FLOW | 0.0362018 | 0.000942 | 38.45 | <.0001 |

FIGURE 143
Plant Data: Edited Test Composite
Model Summary of Fit and Parameter Estimates - CFD Model Control Variable Criteria

| 3A OBED PRS | | | | |
|-----------------------------|-----------|-----------|---------|---------|
| Summary of Fit | | | | |
| RSquare | | 0.37169 | | |
| RSquare Adj | | 0.370335 | | |
| Root Mean Square Error | | 0.026095 | | |
| Mean of Response | | -0.00644 | | |
| Observations (or Sum Wgts) | | 1395 | | |
| Analysis of Variance | | | | |
| Parameter Estimates | | | | |
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | -0.532785 | 0.02304 | -23.12 | <.0001 |
| EST L6 GRATE FD | 0.0003556 | 0.00005 | 7.09 | <.0001 |
| 3A FLOW | 0.0000208 | 8.727e-7 | 23.85 | <.0001 |
| CORR 3B FLOW | 0.0000058 | 4.813e-7 | 12.07 | <.0001 |
| Effect Test | | | | |

| NET FLOW TO KILN | | | | |
|-----------------------------|-----------|-----------|---------|---------|
| Summary of Fit | | | | |
| RSquare | | 0.662688 | | |
| RSquare Adj | | 0.661961 | | |
| Root Mean Square Error | | 1117.042 | | |
| Mean of Response | | 11007.94 | | |
| Observations (or Sum Wgts) | | 1395 | | |
| Analysis of Variance | | | | |
| Parameter Estimates | | | | |
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 7878.4019 | 986.2414 | 7.99 | <.0001 |
| EST L6 GRATE FD | -52.80419 | 2.147685 | -24.59 | <.0001 |
| 3A FLOW | 1.0347812 | 0.037357 | 27.70 | <.0001 |
| CORR 3B FLOW | 1.0722316 | 0.020601 | 52.05 | 0.0000 |
| Effect Test | | | | |

| FIRING HD PRESS | | | | |
|-----------------------------|-----------|-----------|---------|---------|
| Summary of Fit | | | | |
| RSquare | | 0.588248 | | |
| RSquare Adj | | 0.58736 | | |
| Root Mean Square Error | | 0.073089 | | |
| Mean of Response | | -0.09278 | | |
| Observations (or Sum Wgts) | | 1395 | | |
| Analysis of Variance | | | | |
| Parameter Estimates | | | | |
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | -1.322894 | 0.064531 | -20.50 | <.0001 |
| EST L6 GRATE FD | -0.001441 | 0.000141 | -10.25 | <.0001 |
| 3A FLOW | 0.0000983 | 0.000002 | 40.21 | <.0001 |
| CORR 3B FLOW | 0.0000453 | 0.000001 | 33.60 | <.0001 |
| Effect Test | | | | |

| KLN SEC TMP | | | | |
|-----------------------------|-----------|-----------|---------|---------|
| Summary of Fit | | | | |
| RSquare | | 0.475318 | | |
| RSquare Adj | | 0.474186 | | |
| Root Mean Square Error | | 25.95944 | | |
| Mean of Response | | 2053.691 | | |
| Observations (or Sum Wgts) | | 1395 | | |
| Analysis of Variance | | | | |
| Parameter Estimates | | | | |
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 1425.6423 | 22.9197 | 62.20 | 0.0000 |
| EST L6 GRATE FD | 1.2465568 | 0.049911 | 24.98 | <.0001 |
| 3A FLOW | -0.002597 | 0.000868 | -2.99 | 0.0028 |
| CORR 3B FLOW | 0.0043338 | 0.000479 | 9.05 | <.0001 |
| Effect Test | | | | |

FIGURE 144

Plant Data: Edited Test Composite

Model Summary of Fit and Parameter Estimates - CFD Model Control Variable Criteria




FIGURE 145

Plant Data: Edited Test Composite

Model Summary of Fit and Parameter Estimates and Prediction Profiles - CFD Criteria

VENT STACK TMP

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.412731 |
| RSquare Adj | 0.411465 |
| Root Mean Square Error | 48.95887 |
| Mean of Response | 692.9682 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | 468,36784 | 43,226 | 10.84 | <.0001 |
| EST L6 GRATE FD | 2.1132406 | 0.094131 | 22.45 | <.0001 |
| 3A FLOW | -0.032773 | 0.001637 | -20.02 | <.0001 |
| CORR 3B FLOW | -0.026032 | 0.000903 | -28.83 | <.0001 |

Effect Test




FIGURE 146
 Plant Data: Edited Test Composite
 Model Prediction Profiles - CFD Model Control Variable Criteria




FIGURE 147
Plant Data Model
Current Cooler (No Overbed Wall) Operating Window
485 WLTPH Feed to Grate

High flow limited by 3A overbed pressure of +0.01 in.H₂O.
 Low flow limited by Vent Stack temperature of 765 °F.




FIGURE 148
Plant Data Test Distribution in Operating Window
Plant Model




FIGURE 149
Current Cooler - Plant Data Model
Feed to Grate and Fuel Consumption Response Surfaces




FIGURE 150
CFD Model: No Cooler Wall - Parametric Series
Primary and Secondary Cooling Overbed Pressure Prediction Profiles




FIGURE 151
CFD Model: Cooler with Wall - Parametric Series
Primary and Secondary Cooling Overbed Pressure Prediction Profiles




FIGURE 152
Plant Data: Test Composite
Firing Hood, Primary, and Secondary Cooling Overbed Pressure Prediction Profiles

FIRING HD PRESS

Summary of Fit


| | |
|----------------------------|----------|
| RSquare | 0.586248 |
| RSquare Adj | 0.58736 |
| Root Mean Square Error | 0.073069 |
| Mean of Response | -0.09278 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | -1.322894 | 0.084531 | -20.50 | <.0001 |
| EST L6 GRATE FD | -0.001441 | 0.000141 | -10.25 | <.0001 |
| 3A FLOW | 0.0000963 | 0.000002 | 40.21 | <.0001 |
| CORR 3B FLOW | 0.0000453 | 0.000001 | 33.60 | <.0001 |

Effect Test



3A OBED PRS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.37169 |
| RSquare Adj | 0.370335 |
| Root Mean Square Error | 0.026095 |
| Mean of Response | -0.00644 |
| Observations (or Sum Wgts) | 1395 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | -0.532785 | 0.02304 | -23.12 | <.0001 |
| EST L6 GRATE FD | 0.0003556 | 0.00005 | 7.09 | <.0001 |
| 3A FLOW | 0.0000208 | 6.727e-7 | 23.85 | <.0001 |
| CORR 3B FLOW | 0.0000058 | 4.813e-7 | 12.07 | <.0001 |

Effect Test

3B OBED PRESS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.722137 |
| RSquare Adj | 0.721538 |
| Root Mean Square Error | 0.054365 |
| Mean of Response | -0.46601 |
| Observations (or Sum Wgts) | 1395 |


Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------------|-----------|-----------|---------|---------|
| Intercept | -1.937781 | 0.047999 | -40.37 | <.0001 |
| EST L6 GRATE FD | 0.0001018 | 0.000105 | 0.97 | 0.3302 |
| 3A FLOW | 0.0000533 | 0.000002 | 29.32 | <.0001 |
| CORR 3B FLOW | 0.0000516 | 0.000001 | 51.45 | 0.0000 |


Effect Test

FIGURE 153
Plant Data: Test Composite
Firing Hood and Primary Cooling Overbed Pressure



Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|----------|----------|--------------|
| TEST 1 | 206 | -0.0068 | 0.025229 | 0.00176 |
| TEST 2 | 179 | 0.000000 | 0.000000 | 0.00000 |
| TEST 3 | 224 | -0.15759 | 0.066532 | 0.00445 |
| TEST 4 | 173 | -0.31272 | 0.082547 | 0.00628 |
| TEST 5 | 58 | -0.19138 | 0.086419 | 0.01135 |
| TEST 6 | 154 | -0.02468 | 0.043253 | 0.00349 |
| TEST 7 | 142 | -0.03035 | 0.003654 | 0.00031 |
| TEST 8 | 134 | -0.03433 | 0.029974 | 0.00259 |
| TEST 9 | 125 | -0.11856 | 0.037903 | 0.00339 |



Means and Std Deviations

| Level | Number | Mean | Std Dev | Std Err Mean |
|--------|--------|----------|----------|--------------|
| TEST 1 | 206 | 0.000000 | 0.000000 | 0.00000 |
| TEST 2 | 179 | 0.000000 | 0.000000 | 0.00000 |
| TEST 3 | 224 | -0.00938 | 0.029213 | 0.00195 |
| TEST 4 | 173 | -0.06532 | 0.047734 | 0.00363 |
| TEST 5 | 58 | -0.01207 | 0.032861 | 0.00431 |
| TEST 6 | 154 | 0.000000 | 0.000000 | 0.00000 |
| TEST 7 | 142 | 0.006761 | 0.015599 | 0.00131 |
| TEST 8 | 134 | 0.021791 | 0.011880 | 0.00103 |
| TEST 9 | 125 | 0.009840 | 0.012762 | 0.00114 |

FIGURE 154
Plant Data: Test Composite
Secondary Cooling Overbed Pressure




FIGURE 155

Plant Data: Current Cooler - Test Composite Summary of Fit and Parameter Estimates - MEDUSA/CFD Model Criteria

| 3A OBED PRS | | | | |
|----------------------------|-----------|-----------|---------|---------|
| Summary of Fit | | | | |
| RSquare | | 0.348998 | | |
| RSquare Adj | | 0.348063 | | |
| Root Mean Square Error | | 0.026553 | | |
| Mean of Response | | -0.00644 | | |
| Observations (or Sum Wgts) | | 1395 | | |
| Analysis of Variance | | | | |
| Parameter Estimates | | | | |
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | -0.405452 | 0.014678 | -27.62 | <.0001 |
| 3A FLOW | 0.0000224 | 8.582e-7 | 26.10 | <.0001 |
| CORR 3B FLOW | 0.0000075 | 4.27e-7 | 17.51 | <.0001 |
| Effect Test | | | | |

| EST L6 GRATE FD | | | | |
|----------------------------|-----------|-----------|---------|---------|
| Summary of Fit | | | | |
| RSquare | | 0.241318 | | |
| RSquare Adj | | 0.240228 | | |
| Root Mean Square Error | | 13.94053 | | |
| Mean of Response | | 482.5088 | | |
| Observations (or Sum Wgts) | | 1395 | | |
| Analysis of Variance | | | | |
| Parameter Estimates | | | | |
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 358.06405 | 7.706227 | 46.46 | <.0001 |
| 3A FLOW | 0.0044671 | 0.000451 | 9.91 | <.0001 |
| CORR 3B FLOW | 0.0046963 | 0.000224 | 20.95 | <.0001 |
| Effect Test | | | | |

| 3B OBED PRESS | | | | |
|----------------------------|-----------|-----------|---------|---------|
| Summary of Fit | | | | |
| RSquare | | 0.721947 | | |
| RSquare Adj | | 0.721548 | | |
| Root Mean Square Error | | 0.054364 | | |
| Mean of Response | | -0.46601 | | |
| Observations (or Sum Wgts) | | 1395 | | |
| Analysis of Variance | | | | |
| Parameter Estimates | | | | |
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | -1.901323 | 0.030052 | -63.27 | 0.0000 |
| 3A FLOW | 0.0000538 | 0.000002 | 30.60 | <.0001 |
| CORR 3B FLOW | 0.0000521 | 8.742e-7 | 59.55 | 0.0000 |
| Effect Test | | | | |

| Fuel mbtu/ton | | | | |
|----------------------------|-----------|-----------|---------|---------|
| Summary of Fit | | | | |
| RSquare | | 0.181776 | | |
| RSquare Adj | | 0.180601 | | |
| Root Mean Square Error | | 29.58433 | | |
| Mean of Response | | 606.4433 | | |
| Observations (or Sum Wgts) | | 1395 | | |
| Analysis of Variance | | | | |
| Parameter Estimates | | | | |
| Term | Estimate | Std Error | t Ratio | Prob> t |
| Intercept | 887.50958 | 16.35401 | 54.27 | 0.0000 |
| 3A FLOW | -0.013939 | 0.000956 | -14.58 | <.0001 |
| CORR 3B FLOW | -0.006995 | 0.000476 | -14.70 | <.0001 |
| Effect Test | | | | |

FIGURE 156

Plant Data: Current Cooler Test Composite

1. Optimized Conditions

2. Low 3B Flow Condition

3. High 3A Flow/Low 3B Flow Condition






FIGURE 157
MEDUSA/CFD Model: Current Cooler - No Wall
Parameter Estimates

3A OBED PRESS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.999756 |
| RSquare Adj | 0.999732 |
| Root Mean Square Error | 0.000807 |
| Mean of Response | -0.13212 |
| Observations (or Sum Wgts) | 24 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | -0.958272 | 0.003206 | -298.9 | <.0001 |
| 3a flow | 0.0000445 | 1.534e-7 | 290.03 | <.0001 |
| 3b flow | 0.0000194 | 1.11e-7 | 174.55 | <.0001 |

Effect Test

LTPH

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.980362 |
| RSquare Adj | 0.978491 |
| Root Mean Square Error | 1.563294 |
| Mean of Response | 459.1785 |
| Observations (or Sum Wgts) | 24 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | 290.72799 | 6.208174 | 46.83 | <.0001 |
| 3a flow | 0.0057919 | 0.000297 | 19.49 | <.0001 |
| 3b flow | 0.0068937 | 0.000215 | 32.08 | <.0001 |

Effect Test

3B OBED PRESS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.999709 |
| RSquare Adj | 0.999681 |
| Root Mean Square Error | 0.001588 |
| Mean of Response | -0.27929 |
| Observations (or Sum Wgts) | 24 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | -1.092092 | 0.006308 | -173.1 | <.0001 |
| 3a flow | 0.0000123 | 3.019e-7 | 40.58 | <.0001 |
| 3b flow | 0.0000473 | 2.184e-7 | 216.81 | <.0001 |

Effect Test

FUEL MBTU/LT

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.978622 |
| RSquare Adj | 0.976586 |
| Root Mean Square Error | 2120.93 |
| Mean of Response | 601907.4 |
| Observations (or Sum Wgts) | 24 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | 821027.55 | 8422.664 | 97.48 | <.0001 |
| 3a flow | -7.54379 | 0.40314 | -18.71 | <.0001 |
| 3b flow | -8.958573 | 0.291559 | -30.73 | <.0001 |

Effect Test

FIGURE 158

MEDUSA/CFD Model: Current Cooler - No Wall -Desirability Profiles

1. Optimized Conditions

2. Low 3B Flow Condition

3. High 3B Low 3A Condition






FIGURE 159
MEDUSA/CFD: Cooler with Wall
Summary of Fit and Parameter Estimates

3A OBED PRESS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.999946 |
| RSquare Adj | 0.999941 |
| Root Mean Square Error | 0.000521 |
| Mean of Response | -0.14926 |
| Observations (or Sum Wgts) | 24 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | -0.869853 | 0.002071 | -420.1 | <.0001 |
| 3a flow | 0.0000501 | 9.911e-8 | 505.10 | <.0001 |
| 3b flow | 0.0000068 | 7.168e-8 | 94.95 | <.0001 |

Effect Test

3B OBED PRESS

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.9997 |
| RSquare Adj | 0.999671 |
| Root Mean Square Error | 0.002201 |
| Mean of Response | -0.25297 |
| Observations (or Sum Wgts) | 24 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | -1.194471 | 0.008741 | -136.7 | <.0001 |
| 3a flow | 0.0000078 | 4.184e-7 | 18.58 | <.0001 |
| 3b flow | 0.0000606 | 3.026e-7 | 200.28 | <.0001 |

Effect Test

LTPH

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.965855 |
| RSquare Adj | 0.962603 |
| Root Mean Square Error | 1.78702 |
| Mean of Response | 451.5498 |
| Observations (or Sum Wgts) | 24 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | 280.57454 | 7.09664 | 39.54 | <.0001 |
| 3a flow | 0.0081023 | 0.00034 | 23.85 | <.0001 |
| 3b flow | 0.0050021 | 0.000246 | 20.36 | <.0001 |

Effect Test

FUEL MBTU/LT

Summary of Fit

| | |
|----------------------------|----------|
| RSquare | 0.959964 |
| RSquare Adj | 0.956151 |
| Root Mean Square Error | 2649.923 |
| Mean of Response | 612010.9 |
| Observations (or Sum Wgts) | 24 |

Analysis of Variance

Parameter Estimates

| Term | Estimate | Std Error | t Ratio | Prob> t |
|-----------|-----------|-----------|---------|---------|
| Intercept | 845264.31 | 10523.41 | 80.32 | <.0001 |
| 3a flow | -11.07309 | 0.50369 | -21.98 | <.0001 |
| 3b flow | -6.806684 | 0.364278 | -18.69 | <.0001 |

Effect Test

FIGURE 160

MEDUSA/CFD Model: Cooler with Wall -Desirability Profiles

1. Optimized with Baseline Set Points

2. Optimized with Narrowed 3B Set Point Range






FIGURE 161
PRIMARY COOLING OVERBED PRESSURES



- PLANT DATA - FIRING HOOD PRESSURE
PLANT DATA - 3A O'BED PRESSURE
- CFD BASELINE: NO WALL 3A O'BED PRESS
CFD WALL 1 WB OFFSET 3A O'BED PRESS
- CFD WALL 2 WB OFFSET 3A O'BED PRESS

FIGURE 162
KILN SECONDARY AIR TEMPERATURE




FIGURE 163
COOLER FLOW TO KILN






FIGURE 164
TOTAL RECOUP FLOW



- PLANT DATA
- CFD BASELINE: NO WALL
- ▲ CFD DIV WALL 1 WBOX OFFSET
- ✕ CFD DIV WALL 2 WBOX OFFSET

FIGURE 165
AVERAGE RECOUP TEMPERATURE



- PLANT DATA
- CFD BASELINE: NO WALL
- ▲ CFD DIV WALL 1 WBOX OFFSET
- ⋈ CFD DIV WALL 2 WBOX OFFSET

FIGURE 166
COOLER VENT STACK TEMPERATURE




FIGURE 167
PREDICTED GREEN BALL FEED TO GRATE





FIGURE 168
PREDICTED FLOW TO KILN




■ PLANT DATA

● CFD BASELINE: NO WALL

▲ CFD DIV. WALL 1 WBOX OFFSET

FIGURE 169
PREDICTED FUEL CONSUMPTION



APPENDIX I

LISTING OF MINNTAC DATA COLLECTION PARAMETERS

| | | |
|---------------------------------------|--------------------|------------|
| 1. Time | | |
| 2. Green Ball Feed Rate | WLTPH | Line 6 |
| 3. Green Ball Feed Rate | WLTPH | Line 7 |
| 4. Roll Feeder Recycle | WLTPH | Line 6 & 7 |
| 5. Grate Speed | In/min | |
| 6. Bed Depth | In. | |
| 7. Line 6 - Drum 1 Green Ball Rate | WLTPH | |
| 8. Line 6 - Drum 2 Green Ball Rate | WLTPH | |
| 9. Line 6 - Drum 3 Green Ball Rate | WLTPH | |
| 10. Line 6 - Drum 4 Green Ball Rate | WLTPH | |
| 12. Line 6 - Drum 5 Green Ball Rate | WLTPH | |
| 13. Bentonite Total Rate | Lbs/hr | |
| 14. Drying Zone 1 O'Bed Pressure | InH ₂ O | |
| 15. Drying Zone 1 O'Bed Temperature | °F | |
| 16. Drying Zone 1 & 2 U'Bed Pressure | InH ₂ O | |
| 17. Drying Zone 2 O'Bed Pressure | InH ₂ O | |
| 18. Drying Zone 2 O'Bed Temperature | °F | |
| 19. Grate Burners Gas | SMCFH | |
| 20. Kiln Exit Gas Temperature | °F | |
| 21. Preheat O'Bed Pressure | InH ₂ O | |
| 22. Preheat U'Bed Pressure | InH ₂ O | |
| 23. Preheat Wind Box Temps A side - 1 | °F | |
| 24. Preheat Wind Box Temps A side - 2 | °F | |
| 25. Preheat Wind Box Temps A side - 3 | °F | |
| 26. Preheat Wind Box Temps A side - 4 | °F | |
| 27. Preheat Wind Box Temps A side - 5 | °F | |
| 28. Preheat Wind Box Temps A side - 6 | °F | |
| 29. Preheat Wind Box Temps A side - 7 | °F | |
| 30. Preheat Wind Box Temps B side - 1 | °F | |
| 31. Preheat Wind Box Temps B side - 2 | °F | |
| 32. Preheat Wind Box Temps B side - 3 | °F | |
| 33. Preheat Wind Box Temps B side - 4 | °F | |
| 34. Preheat Wind Box Temps B side - 5 | °F | |
| 35. Preheat Wind Box Temps B side - 6 | °F | |
| 36. Preheat Wind Box Temps B side - 7 | °F | |
| 37. Preheat 1A Fan Power | Amps | |
| 38. Preheat 1A Fan Outlet Temperature | °F | |
| 39. Preheat 1A Fan Damper | % Open | |
| 40. Preheat 1A Fan Tempering Damper | % Open | |
| 41. Preheat 1A Fan Mass Flow | Lbs/min | |
| 42. Preheat 1B Fan Power | Amps | |
| 43. Preheat 1B Fan Outlet Temperature | °F | |
| 44. Preheat 1B Fan Damper | % Open | |

| | | |
|---------------------------------------------|--------------------|--------------|
| 45. Preheat 1B Fan Tempering Damper | % Open | |
| 46. Preheat 1B Fan Mass Flow | Lbs/min | |
| 47. Recoup A Duct Temperature | °F | |
| 48. Recoup A Duct Auxiliary Damper | % Open | |
| 49. Recoup A Duct Mass Flow | Lbs/min | |
| 50. Recoup B Duct Temperature | °F | |
| 51. Recoup B Duct Auxiliary Damper | % Open | |
| 52. Recoup B Duct Mass Flow | Lbs/min | |
| 53. Waste Gas Fan Power | Amps | |
| 54. Waste Gas Fan Inlet Temperature | °F | |
| 55. Waste Gas Fan Damper | % Open | |
| 56. Waste Gas Stack Temperature | °F | |
| 57. Kiln Speed | Rev/hr | |
| 58. Kiln Burning Zone Temperature | °F | |
| 59. Kiln Solids Discharge Temperature | °F | 15' from end |
| 60. Kiln Spyrometer Temperature - 1 | °F | |
| 61. Kiln Spyrometer Temperature - 2 | °F | |
| 62. Kiln Spyrometer Temperature - 3 | °F | |
| 63. Kiln Spyrometer Temperature - 4 | °F | |
| 64. Kiln Spyrometer Temperature - 5 | °F | |
| 65. Kiln Spyrometer Temperature - 6 | °F | |
| 66. Kiln Secondary Air Temperature | °F | |
| 67. Kiln Gas Flow | ACF/hr | |
| 68. Kiln Gas Temperature | °F | |
| 69. Kiln Gas Pressure | InH ₂ O | |
| 70. Kiln Burner Tip Pressure | InH ₂ O | |
| 71. Kiln Firing Hood Pressure | InH ₂ O | |
| 72. Cooler Speed | In/min | |
| 73. Primary (3A) Cooling O'Bed Pressure | InH ₂ O | |
| 74. Primary (3A) Cooling U'Bed Pressure | InH ₂ O | |
| 75. Primary (3A) Cooling Fan Power | Amps | |
| 76. Primary (3A) Cooling Damper | % Open | |
| 77. Primary (3A) Cooling Mass Flow | Lbs/min | |
| 78. Secondary (3B) Cooling O'Bed Pressure | InH ₂ O | |
| 79. Secondary (3B) Cooling U'Bed Pressure | InH ₂ O | |
| 80. Secondary (3B) Cooling Fan Power | Amps | |
| 81. Secondary (3B) Cooling Damper | % Open | |
| 82. Secondary (3B) Cooling Mass Flow | Lbs/min | |
| 83. Cooling Fan Inlet Temperature | °F | |
| 84. Cooler Vent Stack Damper | % Open | |
| 85. Cooler Vent Stack Temperature | °F | |
| 86. Cooler Vent Stack Mass Flow | Lbs/min | |
| 87. Cooler Secondary Vent Stack Temperature | °F | |
| 88. Bentonite Consumption | Lbs/lt | |
| 89. Coal Consumption | Lbs/hr | |
| 90. Total Line Fuel Consumption | Btu/lt | |
| 91. % of Gas through Grate Burners | % | |

APPENDIX II

JMP STATISTICAL SOFTWARE - DEFINITIONS

Parameter Estimates

The Parameter Estimates table lists the estimates and standard errors for each parameter in the model. The t ratio and observed probability for the t test are given that compare each parameter to zero. The terms in the Parameter Estimates table for a linear fit are the intercept and the single X variable. For a polynomial fit of order k, there is an estimate for the model intercept and a parameter estimate for each of the k powers of the X variable.
click on a table item for more help

Parameter Estimates: t Ratio

t Ratio lists the test statistics for the hypotheses that each parameter is zero. It is formed by the ratio of the parameter estimate to its standard error. If the hypothesis is true, then this statistic has a Student's t distribution. Looking for a t ratio greater than 2 in absolute value is a common rule-of-thumb for judging significance because it approximates the .05 significance level.

Effect Tests

The Effect Tests in the Effect Test Table are joint tests that all the parameters making up an individual effect are zero. If an effect has only one parameter, as is the case with simple regressors, then the tests are no different from the t tests in the Parameter Estimates table.


Effect Tests: F Ratio

F Ratio is the F statistic for testing that the effect is zero. It is formed as the ratio of the mean square for the effect divided by the mean square for Error. The mean square for the effect is the Sum of Squares for the effect divided by its degrees of freedom. In situations where a subsequent term is specified to be an error term, the mean square for this error term is used instead of Mean Square for Error as the denominator of the F Ratio. Effects designated as error terms are marked with the message {Error Effect} on the right. This specification is used in split-plot and repeated-measure models where there are different observational units for different layers of the model.

The leverage plot for the linear effect in a simple regression is the same as the traditional plot of actual response values and the regressor. The example leverage plots in Figure 8.10 result from a simple linear regression to predict the variable Oxy with RunPulse (see the FITNESS (or fitness.jmp) data table in the SAMPLE DATA folder). The plot on the left is the Whole Model test for all regressors, and the plot on the right is the leverage plot for the effect RunPulse. Because there is only one regressor, the two plots are equivalent. The X scales of the two plots are related by a simple linear transformation.

Figure 8.9 is a schematic of Figure 8.10. Recall that the distance from a point to the line of fit is the actual residual, and the distance from the point to the mean is the residual error if the regressor is removed from the model.

Figure 8.10 Whole Model and Effect Leverage Plots




The points on a leverage plot for simple regression are actual data coordinates, and the horizontal line for the constrained model is the sample mean of the response. But when the leverage plot is for one of multiple effects, the points are no longer actual data values. The horizontal line then represents a partially constrained model instead of a model fully constrained to one mean value. However, the intuitive interpretation of the plot is the same whether for simple or multiple regression. The idea is to judge if the line of fit on the effect's leverage plot carries the points significantly better than does the horizontal line.

Confidence Curves

The leverage plots show with confidence curves. These indicate whether the test is significant at the 5% level by showing a confidence region for the line of fit. If the confidence region between the curves contains the horizontal line, then the effect is not significant. If the curves cross the line, the effect is significant.

Figure 8.11 Comparison of Significance Shown in Leverage Plots




Interpretation of X Scales

If the modeling type of the regressor is interval, then the X axis is scaled like the regressor and the slope of the line of fit in the leverage plot is the parameter estimate for the regressor as illustrated to the right in Figure 8.12.

If the effect is a nominal or ordinal effect or a complex effect, like an interaction instead of a simple regressor, then the X axis cannot represent the values of the effect directly. In this case the X axis is scaled like the Y axis, and the line of fit is a diagonal with a slope of 1. The whole model leverage plot is a version of this, where the X axis turns out to be the predicted response of the whole model as illustrated by the plot to the left in Figure 8.12.

The influential points in all leverage plots are the ones far out on the X axis. If two effects in a model are closely related, then these effects as a whole don't have much leverage. This problem is called *collinearity*. By scaling regressor axes by their original values, collinearity shows as shrinkage of points in the X direction.

Figure 8.12 Leverage Plots for Simple Regression and Complex Effects




See Appendix A, "Statistical Details," for the details of leverage plot construction.

The Desirability Function

To use a variable's desirability function, drag each of the three function points vertically to represent a response value and horizontally to choose the desirability of that response.

Figure 9.6 shows and describes four commonly used desirability settings.

Figure 9.6 Desirability Settings



As you drag a desirability function point, the changing response value and the desirability value (between 0 and 1) show in the cell labeled Desirability at the lower right of the plots. The dotted line is the response for the current factor settings. The overall desirability shows to the left of the row of desirability traces. Alternatively, you can OPTION-click (ALT-click under Windows) in a desirability function to enter specific values for the points in a dialog.

(1) The default desirability function setting is "higher is better." The top function point is positioned at the maximum Y value and aligned with the maximum desirability of 1. The bottom function point is positioned at the minimum Y value and aligned with the minimum desirability of 0.

(2) You can designate a target value as "best." In this example, the middle function point is positioned at a Y value of 55 and aligned with the maximum desirability of 1. Y becomes less desirable as its value approaches either 70 or 42. The top and bottom function points at Y=70 and Y=42 are positioned at the minimum desirability of 0.

(3) You can show a response constraint. This example constrains Y to be greater than 55. The middle function point is positioned at Y=55 and set to most desirable. Likewise, the top function point (Y=98) is set to most desirable. A Y value less than 55 becomes less desirable. The bottom function point is positioned at the minimum Y value and is set to least desirable.


(4) The "lower is better" desirability function is constructed by setting the top function point to the maximum Y value and minimum desirability, and the bottom function point to the minimum Y value and the maximum desirability.

The Desirability Profile

The last row of plots shows the desirability trace for each response. The numerical value beside the word Desirability on the vertical axis is the geometric mean of the desirability measures. This row of plots shows both the current desirability, and the trace of desirabilities that result from changing one factor at a time.

For example, suppose the desirability function in Figure 9.5 is set for a target value of 60. The plots in Figure 9.7 indicate that you could reach the optimum desirability for the target by either lowering Ct halfway to the left toward its low value, or by lowering T to its minimum value. Increasing Cn is also an option. The profile in Figure 9.7 results from changing Ct to -0.5. The desirability is at a maximum, and the Y response is close to the target of 60.

Figure 9.7 Prediction Profile Plot with Adjusted Desirability and Factor Values



Desirability Profiling for Multiple Responses

A desirability index becomes especially useful when there are multiple responses. The idea was pioneered by Derringer and Suich (1980), who give the following example:

Suppose there are four responses, ABRASION, MODULUS, ELONG, and HARDNESS.

- ABRASION and MODULUS are to be maximized
- ELONG is to be near a target of 500
- HARDNESS near a target of 67.5.

Three factors, SILICA, SILANE, and SULPHUR, were used in a central composite design.

The data are in the TIRETREAD data table in the SAMPLE DATA folder (tire tread.jmp file in the data folder under Windows). Use the Fit Model dialog to define a screening fit for the